



Government of India

Ministry of Road Transport & Highways

Office of the Chief Engineer- Regional Officer, (Civil)

No. 32, 2nd Floor, KSCFL Building, Race Course Road, BENGALURU-560 001

Email: robengaluru@gmail.com; Telephone: 080-22267457, 080-22265765

No.RW/BNG/PER.CASES/ MNG DVN/2020

Dated: 28.04.2026

Notice inviting Public Comments for obtaining permission of NH-73 crossing proposal and grant of NOC for installation of 400kV D/c Udupi at Km 24.65 to Kasargode Transmission line under Udupi to Kasargode transmission ltd - Reg.

Reference: Your Letter No. EE/NHD/MG/AE-1/NH-73/Km. 24.65/crossing/Transmission Line/2025-26/3071-73 Dtd 31.03.2026.

The Executive Engineer, NH Division, Mangalore vide letter cited under reference above, has submitted proposal seeking Permission of NH-73 crossing proposal and grant of NOC for installation of 400kV D/c Udupi at Km 24.65 to Kasargode Transmission line under Udupi to Kasargode transmission ltd.

2. The proposal has been examined as per Ministry's Guidelines vide letter no.RW/NH-33044/29/2015/S&R(R) dated 22.11.2016 and dated 17.04.2023 is generally found in order.

3. In view of above, as per Ministry's said guidelines Para 4, public comments are invited on the above proposal making claims and raising objections (on grounds of public inconvenience, safety and general public interest) if any within 30 days on public portal i.e., website of Ministry of Road Transport and Highways (morth.nic.in) in Form-A (copy enclosed) for "Accommodation of Public and Industrial Utility Services along and across National Highways".

Comment Inviting Authority

The Regional Officer-Civil

Ministry of Road Transport & Highways

No.32, 2nd Floor, Race Course Road, Bangalore-560 001

Email: robengaluru@gmail.com; Telephone: 080-22217457, 080-22105765

Encl:As above


(Sandesh.K)

Asst. Engineer(C)

for RO-MoRTH Bengaluru

- Copy to: (i) The Senior Technical Director, NIC, Transport Bhawan, New Delhi- 110001 for uploading on Ministry's website.
(ii) The Executive Engineer, National Highway Division, Mangalore, for information.


(Sandesh.K)

Asst. Engineer(C)

for RO-MoRTH Bengaluru

FORM A

Form for seeking claims and objections (on grounds of public inconvenience, safety and general public interest) on the application for Accommodation of Public and Industrial Utility Services along and across National Highways.

Subject: Proposal seeking Permission of NH-73 crossing proposal and grant of NOC for installation of 400kV D/c Udupi at Km 24.65 to Kasaragode Transmission line under Udupi to Kasargode transmission ltd - Reg.

The claims and objections (on grounds of public inconvenience, safety and general public interest) by the general public needs to be given within 30 days of uploading the online application for comments.

Sl. No	Item	Details
1	Name of the person who is desiring to give claims and objections (on grounds of public inconvenience, safety and general public interest)	
2	Address of the person	
3	Details of the application for Accommodation of Public and Industrial Utility Services along and across National Highways against which claims and objections are being given (name of applicant and other details like site address etc.)	
	a) Application No.	
	b) Name of applicant (who applied to Accommodation of Public and Industrial Utility Services along and across National Highways)	
	c) Details of Application	
4	The claims and objections (on grounds of public inconvenience, safety and general public interest)	



GOVERNMENT OF KARNATAKA
(Public Works Department)
NATIONAL HIGHWAYS

Office of the Executive Engineer, National Highway Division,
Ashoknagar Post, Urva Store Mangalore-575006.

Phone No.0824-2450415

email : eenhdmng@gmail.com

No.EE/NHD/MNG/AE-1/NH-73/Km.24.65/Crossing/Transmission Line/Compliance/2025-26/

Date:31/03/2026

3071-73

To,

✓ The Chief Engineer,
Regional Officer, M.o.R.T.& H.,
No.32, 2nd Floor, KSCFL Building,
Race Course Road, Bengaluru.

O/o. THE CE-RO
MORT&H, BENGALURU
Entry No.: 49
Date: 06-04-2026

Sir,

Sub: Request for permission of NH-73 Crossing proposal and grant of NOC for installation of 400kV D/c Udupi at Km 24.65 on NH-73 to Kasaragode Transmission line under Udupi to Kasaragode transmission Limited - **Submission of Compliance Reg.**

- Ref:**
1. Office of Chief Engineer-Regional officer, MoRT&H, Bengaluru letter No:RW/BNG/PER.CASES/MNG.DVN/2013/2418 dated:24.02.2026
 2. This office letter dated:10.03.2026
 3. Sterlite Power, Udupi Kasargodu Transmission Limited, Kottara Chowki, Mangalore letter no. UKTL/2025-26/20260309/KA/TL/Com./1214 dated:12.03.2026
 4. Assistant Executive Engineer, National Highway Sub Division, Mangalore letter no.AEE/NHSD/MNG/AE-2/NH-73/Km.24.65/Crossing/Transmission Line/Compliance /2025-26/1141 dated:17.03.2026

With reference to the above subject, the proposal for permission of NH-73 Crossing proposal and grant of NOC for installation of 400kV D/c Udupi to Kasaragode Transmission line under Udupi to Kasaragode transmission Limited at Km 24.65 on NH-73, Mangaluru-Tumkur Section has been examined by the Chief Engineer-Regional officer, MORT&H, Bengaluru and returned with the observations vide letter cited at ref (1). The same has been returned to Assistant Executive Engineer, National Highway Sub Division, Mangalore with an intimation to submit the corrected proposal as per Ministry's guidelines along with compliance for observations vide this office letter cited at ref (2).

In this regard, Sterlite Power, Udupi Kasargodu Transmission Limited, Kottara Chowki, Mangalore has resubmitted the proposal for permission of NH-73 Crossing proposal and grant of NOC for installation of 400kV D/c Udupi to Kasaragode Transmission line under Udupi to Kasaragode transmission Limited at Km 24.65 of NH-73, Mangaluru-Tumkur Section vide letter cited at ref (3) to Assistant Executive Engineer, N.H. Sub Division, Mangalore.

The revised proposal submitted by the Sterlite Power, Udupi Kasargodu Transmission Limited, ABCO Trade Centre, Kottara Chowki, Mangalore has been verified by the Assistant Executive Engineer, N.H. Sub Division, Mangalore in accordance with Ministry guidelines. Pursuant to the observations raised by the **Regional Officer (Civil), MoRTH, Bengaluru**, the compliance report and revised drawings have been submitted vide the letter cited at ref (4). The compliance to the observations is as under:

Sl.No.	Observations	Compliance
1	The proposal needs to be examined with respect to the ongoing/proposed works in the said stretch. The status of the development work along with land acquisition status is to be submitted.	The stretch from Km 20.150 to Km 40.00 of NH-73 is developed to 2lane with paved shoulder and DLP is completed on 31.01.2026. At present in the above stretch PBMC work is sanctioned from the Ministry and the above work is under tender process. No Land Acquisition is involved in PBMC Work.
2	The proposal in two sets along with License Agreement in original (two sets) and 1 copy as per the Ministry's guidelines dated 22.11.2016 needs to be submitted with seal of authorized signatory in all pages and witness signature. The agreement is to be made between "The Regional Officer, MoRTH Bangalore" (Authority) and the licensee, leaving date/month/year blank without any topographical errors along with witness signature.	Two sets of the License Agreement in original along with one additional copy as per Ministry guidelines dated:22.11.2016 is enclosed. All pages bear the seal of the authorized signatory and witness signatures. The date/month/year fields have been intentionally left blank as requested.
3	All the undertakings mentioned in the checklist, as per the Ministry norms, need to be submitted in original copies duly signed by the Executive Engineer, NH Division, Mangalore.	All undertakings mentioned in the checklist prepared in accordance with Ministry norms are submitted in original signed by the Executive Engineer, National Highway Division, Mangaluru.
4	All the particulars of the checklist, including the methodology of crossing the NH, need to be verified and certified by the field authority i.e., Executive Engineer, NH Division, Mangalore. Further, it is requested to rectify all handwritten / pen corrections made in the checklist and submit a clean, error-free copy duly signed and sealed by the competent authority.	A clean and error-free copy of the checklist including the crossing methodology has been prepared. All previous handwritten / pen corrections have been rectified and the document is duly certified and sealed.

Sl.No.	Observations	Compliance
5	As per the Ministry guidelines, when the utilities are allowed overhead, the horizontal and vertical clearance in accordance with the IRC shall be maintained. As such the Executive Engineer NH Division Mangalore is requested confirm whether the proposal is in accordance with the IRC: 32-1969.	An undertaking confirming compliance with IRC:32-1969 and the relevant Ministry guidelines is enclosed.
6	It needs to be clarified whether the proposed crossing falls within any notified toll plaza stretch on NH-73. If so, necessary clearance / approval from the toll operating agency (Concessionaire / NHAI) may also be obtained and submitted along with the proposal.	The proposed crossing does not fall within any notified toll plaza stretch on NH-73.

In view of the above, the proposal is verified and herewith resubmitted along with revised documents, layout drawings for kind perusal and further needful.

Encl: Proposal - 2 sets

Yours faithfully,


Executive Engineer
National Highway Division
Mangaluru.