



भारतीय राष्ट्रीय राजमार्ग प्राधिकरण

(सड़क परिवहन और राजमार्ग मंत्रालय, भारत सरकार)

क्षेत्रीय कार्यालय - गुजरात

National Highways Authority of India

(Ministry of Road Transport & Highways, Govt. of India)

Regional Office - Gujarat

235-239, दुसरी मंजील, सुपरमॉल-1, एच.डी.एफ.सी. फाइनेंस के ऊपर, इन्फोसिटी, गांधीनगर - 382007 (गुजरात)

235-239, 2nd Floor, Supermall-1, Above HDFC Finance, Infocity, Gandhinagar - 382007 (Gujarat)

दूरभाष / Phone : 079-40306838, 40306839

फैक्स / Fax : 079-40190631

ई-मेल / e-mail : rogujarat@nhai.org

NHAI/18013/01/2010-RO-GNR/OFC/Pipeline/Vol.01/D-61

6th Jan. 2020

Invitation of Public Comments

SUB: Proposal seeking permission for Overhead Crossing of 66KV S/C line on D/C Panther Tower from existing 220KV Bhachau (Vondh) S/S to proposed 66KV Bhachau (Vondh) S/S to proposed 66KV HPCL S/S with ACSR Dog Conductor crossing on NH-41 Extn. At Km Stone 322.323 at Chainage 322.222 Electric Line Crossing NH-41.

The proposal is regarding permission for erection of 66KV Overhead Electric Line Crossing at Km Stone 322.323 and at Chainage 322.222 of NH-41 was forwarded to this office by RO-MoRT&H, Gandhinagar as submitted by PD, PIU-Gandhidham vide letter no. NHAI/PIU/GDM/OFC/Permission/2019/G-8524 dt. 04.09.2019 for approval of Highway Administration.

2. The recommended proposal of PD, PIU-Gandhidham has been examined by this office and detailed features of the proposal are as under:

Sr. No.	Items	Information/Status
1	Crossing type and purpose	Electrical Overhead Crossing
2	NH No.	NH-41
3	Chainage of NH	Km Stone 322.323 (Chainage 322.222)
5	Methodology for laying power supply line	Overhead Line
6	Span of overhead line crossing	170 Mtrs
7	Whether Towers/Poles of overhead crossing fall under ROW	No
8	Skew Angle with NH	88°59'50"
9	Tower/Pole Height	19.47 Mtrs
10	Vertical Clearance from FRL to lowest cable of overhead crossing	15.05 Mtrs

2. As per Ministry vide OM No RW/NH-33044/29/2015/S&R(R) dt.22.11.2016, the Highway Administration will make available the proposal seeking permission for utility laying for public comments for 30 days on ground of general public interest for seeking claims and objections.

3. In view of above, the comments of public are invited on captioned proposal and the same should reach to below mentioned address till 05.02.2020 beyond which no comments will be considered.


The Highway Administration-cum-Regional Officer
National Highways Authority of India
235-239, 2nd Floor, Supermall-1, Above HDFC Finance, Infocity,
Gandhinagar-382 007 (Email: rogujarat@nhai.org).

Contd...2

Sand
06/01/2020

/// 2 ///

4. This issues with the approval of Highway Administration-cum-Regional Officer, NHAI-Gandhinagar.


(Sandeep Patidar)
Manager (Tech)

For, Chief General Manager(T) &
Regional Officer, NHAI-Gandhinagar

- Copy to:
1. Sr. Technical Director, NIC, Transport Bhavan, New Delhi-110001: For uploading on Ministry's website.
 2. RO-MoRT&H, Gandhinagar: For information please.
 3. PD-NHAI, PIU-Gandhidham: For information and with request to work out the amount of Performance Security as per site conditions and Para-6 of the MoRT&H guidelines issued vide Circular No. RW/NH-33044/29/2015/S&R(R) dt. 22.11.2016 and convey the same to the applicant with intimation to this office.
 4. **The Ex. Engineer (Const.), GETCO, Anjar, Kutch:** For information and with request to submit the requisite performance BG as worked out by the PD, PIU-Gandhidham. The Performance Bank Guarantee should be in favour of Project Director, NHAI, PIU-Gandhidham and to be submitted to PD, NHAI-PIU, Gandhidham custodian of BGs.