## भारतीय राष्ट्रीय राजमार्ग प्राधिकरण

(सड़क परिवहन और राजमार्ग मंत्रालय, भारत सरकार)

## National Highways Authority of India

(Ministry of Road Transport and Highways, Government of India) परियोजना कार्यान्वयन इकाई:कृष्णागिरी

Project Implementation Unit : Krishnagiri

#२५९/१ सेलम मार्ग, के ए केसी पेट्रोल बंक के पास,कृष्णागिरी,तमिलनाड् -६३५००१ # 259/1, Salem Main Road, Near KAKC Petrol Bunk, Krishnagiri ( Tamil Nadu ) - 635 001.

दूरभाष/ Tel: 04343 234250, ईमेल / Email : nhaikrishnagiri@gmail.com, kri@nhai.org



15th July 2024

NHAI, PIU, Krishnagiri - laying of Drinking water pipeline from km.138/150 to km.138/500 (RHS) and road crossing at km.138/150 on Krishnagiri Walajahpet section of NH-48 by Executive Officer, Vilapakkam Town Panchayat, Vilapakkam, Ranipet District - Invitation of Public Comments - Reg.

The proposal is regarding permission for laying of Drinking water pipeline from km.138/150 to km.138/500 (RHS) and road crossing at km.138/150 on Krishnagiri Walajahpet section of NH-48 by Executive Officer, Vilapakkam Town Panchayat, Vilapakkam, Ranipet District submitted to this office on 28.06.2024.

- 2. The details of the proposal is as under:
  - a) The above proposal pertains to the laying of water pipeline from km.138/130 to km.138/390 (LHS), km.138/390 to km.138/500(RHS) and road crossing at km.138/390 on Krishnagiri Walajahpet section of NH-48.
  - b) The details of ROW available along with the distance at which Water Pipeline is proposed to lay from the centerline is as follows:

SI no.	Description			Pipe Dia	Length in mtrs	ROW in Meters		Distance of Water Pipeline from centreline of the Main Carriageway		Depth
	From	То	side			LHS	RHS	LHS	RHS	Along the road by open trench method duly
1	138.150	138.500	RHS	150mm dia DI Pipe	350	30.50	30.50	-	29.00	keeping the top of the casing at 1.5 m below the top of sub grade level
	Total length				350		ii.			



E:\KRISHNAN -2\Access Permission\TWAD\EO, Vilapakkam Town Panchayat\138.500 to km.138.390(RHS) and km.138.130 to

2	Road Crossing	138.150	61	Road crossing by HDD Method duly keeping the top of the pipe at 1.5 m
				from bottom of crust.

- 3. Executive Officer, Vilapakkam Town Panchayat, Vilapakkam, Ranipet District has furnished an undertaking to indemnify the concerned agency in coordination with NHAI, against all damages and claims if any, due to the digging of trenches for laying of water pipeline. Further, the applicant has furnished undertaking that they will adopt HDD method wherever, the available width of ROW is less than 15m and undertaking not to damage other utility, if damaged then to pay the losses either to NHAI or to the concerned agency. Further, the applicant has furnished undertaking that the HDD method will be adopted for crossing of road at grade separators at grade junction and wherever required and in the built up areas as per the instruction of NHAI officials.
- 4. As per the guidelines issued by the Ministry vide letter No.RW/NH33044/29/2015/ S&R(R) dated 22.11.2016, the proposal submitted by Executive Officer, Vilapakkam Town Panchayat, Vilapakkam, Ranipet District will be made available for 30 days seeking public comments/objections and the comments shall be furnished within 30 days from the day of closure of public objections.

In view of the above, comments of the public on the above proposal are invited any may be sent to the below mentioned address:

The Project Director,
National Highways Authority of India,
Project Implementation Unit,
No.259/1, Salem Main Road,
Near KAKC Petrol Bunk,
Krishnagiri (T.N) - 635 001.

Yours faithfully,

(G. Ramesh) Project Director

Copy to:

- 1. Regional Officer, NHAI, Chennai Region, Chennai for kind information.
- 2. NHAI website.
- 3. The NIC, New Delhi- for uploading in the Ministry's website.