

भारत सरकार  
सडक परिवहन और राजमार्ग मंत्रालय  
क्षेत्रीय कार्यालय, भुवनेश्वर  
प्लट संख्या - 184 (फायर स्टेशन चौक के पास)  
बरमुन्डा, भुवनेश्वर-751003  
दूरभाषा : (0674) 2960994 & 2952994  
ई-मेल : robbsr.morth@gmail.com



Government of India  
Ministry of Road Transport & Highways  
Regional Office, Bhubaneswar  
Plot No. - 184 (Near Fire Station Square)  
Baramunda, Bhubaneswar-751003  
Ph. No.: (0674) 2960994 & 2952994  
E-mail: robbsr.morth@gmail.com

File No. RO/BBSR/Utility Services/NH-63/JPR/88/2024 -424

Date: 10<sup>th</sup> Jun, 2024

Invitation of Public Comments

Sub: Permission for crossing of 400 KV D/C transmission line (overhead) of Power Grid ERWR, Jagadarpur in between chainage 2/000 to 3/000 on NH-63 - reg.

1. Executive Engineer, NH Division, Jeypore vide letter dated 04.05.2024 has submitted a proposal on the above mentioned subject as detailed below:

NH No: 63  
Chainage: In between Km 2/000 to km 3/000  
Carriageway width: 10.0 m  
Crossing span: 217 m  
Vertical clearance from FRL: 18.60 m  
ROW width: 46.0 m  
Distance of tower from road center: 93.85 m & 123.10 m

2. As per Ministry's OM No. RW/NH-33044/29/2015/S&R(R) dated 22.11.2016, the Highway Administrator will put out the application in the public domain for 30 days for seeking claims and objections (on grounds of public inconvenience, safety and general public interest, if any.

3. In view of the above, comments of public for claims/objections, if any, on the above proposal are invited online as well as in hard copy. The strip plan/location details are enclosed herewith. The same should reach to the below mentioned address within 30 days from the date of uploading it in the website, beyond which no objection will be considered.

Address:

Regional Officer,  
Ministry of Road Transport & Highways,  
Plot No -184, Infront of CRPF Stadium,  
Baramunda, Bhubaneswar - 751003.

Yours faithfully,

(Sudhansu Sekhar Sahu)  
Senior Technical Assistant  
For Regional Officer

Copy to :

- 1) The Senior Technical Director, NIC, Transport Bhawan, New Delhi - 110001- along with strip chart for uploading on the Ministry's website.
- 2) General public with request to furnish comments, if any, to the above mentioned address or by e-mail to "[robbsr.morth@gmail.com](mailto:robbsr.morth@gmail.com)"


Name of Transmission Line : 400kv d/c (Quad AL59 Moose) Jeypore-  
Jagdalpur Transmission Line


NH – 63 Crossing Detail

National Highway Crossing Between Location Number AP-10 To AP-11


Line which is Crossing	: 400kv D/C (Quad AL59 Moose) Jeypore- Jagdalpur Transmission Line
NH which is Being Crossed	: NH – 63
NH-63 Road Width	:10 Mtr.
Crossing Angle	: 72° 52' 33" RT Degree
Village Name	:Lahanja
Crossing Span	:217 Mtr.
AP-10 Angle	:10°37'06" RT
AP-11 Angle	:00°00'00"
Type of Tower	: AP-10 (DD45+06), AP-11 (DD45+03)
Distance of Tower from Centre of the Road	:AP-10 (93.85 Mtr.) AP-11 (123.1 Mtr.)
Virtual Clearance from Lowest Point of Conductor	: 18.60 Mtr.
Right Of Way for Line	: 46 Mtr.

  
Rahul Sonalikar  
Project Manager  
Bajel Projects Ltd.

  
Asst. Executive Engineer  
NH Sub Division, Jeypore

  
24/04/2024  
एस.एस. जांगडे / S.S. JANGDE  
मुख्य प्रबंधक / CHIEF MANAGER  
POWERGRID ERWR POWER  
TRANSMISSION LTD., JAGDALPUR (C.G.)

**PROPOSAL FOR 400KV D/C TL FROM JEYPORE (KORAPUT DIST) TO JAGDALPUR (BASTAR DIST)  
CROSSING NHAI BETWEEN KM 02 / 00 AND 03 / 00 OF JAGDALPUR - JEYPORE ROAD.**



**Note :-**

- 1.) 400kV line Corridor width : 46mtr.
- 2.) Angle of Crossing : 72°52'33"
- 3.) Height of Bottom Conductor above road level is 18.60mtr.
- 4.) Road Center to Tower Edge Distance: (Left:83.08mtr.), (Right:113.18mtr.)

*Rebut*  
24.4.24  
Asst. Executive Engineer  
NH Sub Division, Borigumma

*Rebut*  
31.04.24  
Executive Engineer  
NH Division, Jeypore

*28/04/24*  
मुख्य प्रबंधक / CHIEF MANAGER  
POWER GRID ERWR POWER  
TRANSMISSION LTD., JAGDALPUR (BASTAR DIST)