

Government of India

Ministry of Road Transport & Highways
(Chief Engineer - Regional Office, Lucknow)

N.H. Bhawan, Biotech Chowk, Lucknow Ring Road, Vikas Nagar, Lucknow - 226 022
Ph.: (0522) 2967112, 2738226 (Tele-Fax)

Dated: 18.07.2023

Invitation of public comments

Sub.: Proposal for NOC permission for laying & crossing of 33KV XLPE insulated cable by trenchless HDD method & overhead with installation of electric pole in Km.62.891 - Km.64.193 along NH-330 in the industrial area Trisundi, UPSIDC, near CRPF Camp, District - Amethi in the state of Uttar Pradesh - Reg.

M/s SLMG, Beverages Pvt. Ltd., (Unit-II), Amethi has submitted the proposal for laying & crossing of 33KV XLPE insulated cable through overhead laying with installation of 34 numbers of electric pole at the extreme edge of ROW in (Km.62.891 to Km.63.691 & Km.63.731 to Km.64.193 with total length=1262 meters) & trenchless HDD method in (Km.63.691 to Km.63.731 & crossing at Km.64.193 with total length=170 meters) along NH-330 in the industrial area Trisundi, UPSIDC, near CRPF Camp, District -Amethi in the state of Uttar Pradesh to the Executive Engineer, NH Division, PWD, Sultanpur for consideration.

2. The above proposal has been examined in this office in light of Ministry's guidelines issued vide OM No.RW/NH-33044/29/2015/ S&R(R) dated 22.11.2016. As per the guidelines, issued by the Ministry vide OM No.RW/NH-33044/29/2015/S&R(R) dated 22.11.2016, the application shall be put out in the public domain for 30 days for seeking claims and objections (on grounds of public inconvenience, safety and general public interest).

3. In view of the above, comments of the public on the above application (checklist enclosed) is invited to the below mentioned address:

The Chief Engineer - Regional Officer,
Ministry of Road Transport & Highways,
N.H. Bhawan, Biotech Chowk, Lucknow Ring Road,
Vikas Nagar, Lucknow - 226 022.

Encl.: As above.

Yours faithfully,



(Ritesh Yadav)

Assistant Executive Engineer
for Chief Engineer - Regional Officer

Copy to:

- (i) NIC, New Delhi - for uploading on the Ministry's website.
- (ii) The Chief Engineer (NH), Public Works Department, Nirman Bhavan, 96, M. G. Marg, Lucknow - 226 001.

(Ritesh Yadav)

Assistant Executive Engineer
for Chief Engineer - Regional Officer

CHECK LIST

Guidelines for Project Directors for processing the proposal of laying Optical fiber/HT cables/Sewer pipe line etc. by private parties in the land along National Highway with State PWD

(Relevant circulars)

Check-list for getting approval for laying U/G MS Pipe dai 150mm for 3 Corex 400 sqmm XLPE insulated cable from Ch.-63.691 to Ch.-63.731 (2x40=80m) (LHS) & including one no. U/G crossing at Ch.-64.193 (2x45m=90m) & O/H 33 Kv Line from Ch. 62.891 to 63.691 (800m) & Ch.- 63.731 to 64.193 (462m). Total length -UIG 170m + O/H 1262m = 1432m

Ministry Circular No. RWINH-33044/29/2015/S&R (R) Dated 22.11.2016
MinistryCircularNo.RWINH-33044/2712005/S&R(RYPt.) Dated 06.08.2013

SI	ITEM	INFORMATION/STATUS	REMARKS
1	General Information		
1.1	Applicant/Agency	SLMG BEVERAGES PVT. LTD. Plot No. A-1-4/B1-2, Industrial Area Trishundi, UPSIDC, Near CRPF camp Amethi-228159	
1.2	National Highway Number	NH-330	
1.3	State	Uttar Pradesh	
1.4	Location	District – Amethi	
1.5	(Chainages in KM)	Ch.-62.891 to 64.193 (LHS)	
1.6	Length in Meters	170+1262=1432.00M	
1.7	Width of available ROW	25.00M to 42.00M	
	(a) Left side from center line towards increasing chainage/km direction	12.5M to 21.00M	
	(b)Right side from center line towards increasing chainage/km direction	12.5M to 21.00M	
1.8	Proposal to lay the XLPE line		
	(a) Left side from center line towards increasing chainage/ km direction	YES	
	(b) Right side from center line towards increasing chainage/km direction	N/A	
1.9	Proposal to acquire land		
	(a) Left side from center line	Not Required	

Assistant Engineer
N.H. Division P.W.D. Sultanpur

Executive Engineer
N.H. Division P.W.D.
Sultanpur

SLMG Beverages Pvt. Ltd.
Unit-II
Authorized Signatory


	(b) Right side from center line.	Not Required	
1.10	Whether proposal is in the same side where land is not to be acquired	YES	
	If not then where to lay the cable	The Extreme Edge of PROW	
1.11	Details of already laid services, if any along the proposed route.	N/A	
1.12	Number of lanes (2/4/6/8 lanes) existing	2 Lane with paved shoulder	
1.13	Proposed Number of lanes (2 lanes with paved shoulder/4/6/8 lanes)	4 Lanes (with paved Shoulder)	
1.14	Service which road existing or not If yes then side		
	(a) Left side from center line	No	
	(b) Right side from Center line.	No	
1.15	Proposed Service Road		
	(a) Left side from center line	N/A	
	(b) Right side from center line.	N/A	
1.16	Whether proposal to lay CABLE is after A the service road or between the service road and main carriageway	At Extreme edge of PROW	
1.17	The permission for laying OFC / HT cables/ water supply pipe line shall be considered for approval/rejection.	For Approval	
	(i) Where the ROW is more than 45m then the duct cable shall be laid at the edge of right of way within the utility corridor of 2m width, duly keeping in view the future widening	No	
	(ii) Where land is yet to be acquired for 4 laning and the position of new carriageway has been decided then the cable shall be laid at the edge of right of way within the utility corridor of 2m width, on that side of existing carriageway where extra land is not proposed to be acquired for 4- laning	Applicable	
	(iii) Where the widening plan for 4- laning is not yet decided and available ROW is around 30m or less, a judicious decision would need to be taken for permitting the Laying of cable/duct. This could be Within 1.5m to 2 m of utility corridor at the edge of existing ROW,	N/A	


Assistant Engineer
N.H. Division, Sultanpur

Executive Engineer
N.H. Division P.W.D
Sultanpur

SLMG Beverages Pvt. Ltd.
Unit-II
Authorized Signatory

	duly Keeping in view the possible Widening plans.		
	(v) Where row is restricted and adequate only to accommodate the carriageway, Central verge, shoulders and drains (eg Highways in currying through hilly, rolling terrain) the cable shall be laid clear of the drain.	Plain Terrain at the edge of PROW	
	(V) Where land strip for utility corridor cannot be conveniently earmarked (available ROW restricted to the toe of the embankment) for laying of cable/ducts, the permission may be refused.	Available	
1.18	Number of applicants of the same stretch	Single Applicant	
1.19	Whether the case of multiple licenses	No	
1.20	If, so Furnish joint implement programmer to lay respective ducts with stipulated time frame	Not Required	
1.21	If crossing of the road involved if yes, shall only be through trench less technology	Yes (Trenchless Technology)	
2	Document/drawing enclosed with the proposal.		
2.1	Cross section showing the size of trench for open trenching method (Is its normal size of 1.20m deep x0.5m wide	Yes	
2.2	Cross section showing the size of pit location of pipe line for HDD method	Yes Enclosed	
2.3	Strip plan / Route Plan showing the OFC/pipe line, chainage, width of ROW, important mile stone, intersections, cross drainage works etc.	Shown in the drawing	
2.4	Methodology of laying of MS Pipe and cable	Yes	
2.4.1	Open Trench Method, if yes methodology of refilling of trench.	N/A	
2.4.2	Horizontal Directional Drilling (HDD) method	Yes, Enclosed	
2.4.3	Laying OFC/ HT cable through CD works and method of laying (Whether to be hung outside parapet)	N/A	
3	Draft license agreement signed by two witnesses	Yes	
4	Performance Bank Guarantee	Yes	
5	Affidavit Undertaking from the applicant for		


Assistant Engineer
 N.H., P.W.D., Subangar


 N.H. Division P.W.D.
 Subangar

SLMG Beverages Pvt. Ltd.
 Unit-II

 Authorized Signatory

5.1	Not to Damage to other utility, if damaged then to pay the losses either to State PWD or to the concerned agency	Yes, Enclosed	
5.2	Renewal of Bank Guarantee.	N/A	
5.3	Confirmation all standard condition of State PWD guidelines.	Yes, Enclosed	
5.4	Shifting of optical fiber cable as and when required by State PWD	Yes, Enclosed	
5.5	Shifting due to 6-laning / widening of NH.	Yes, Enclosed	
5.6	Indemnity against all damages and claims clause (xxiv)	Yes, Enclosed	
5.7	Traffic movement during laying of MS Pipe/Cable to be managed by the applicant	Yes, Enclosed	
5.8	If any claim raised by the Concessionaries, then the same has to be paid by the applicant.	Yes, Enclosed	
5.9	Certificate for 6-laning from the applicant in following format. "We do undertake that I will relocate shoulder service road/approach road/utilities at my own cost not with standing the permission granted within such time as will be stipulated by NHAI for future six-lane or any other development."	Yes, Enclosed	
6	Affidavit /Power of Attorney in favor of authorized signatory	Yes, Enclosed	
7	Copy of DOT license	Not Required	
8	Certificate from the Executive Engineer	Not Required	
8.1	Certificate from confirming of all standard condition issued vide Ministry Circular No. RWINH-33044/27/2005/S&R(R)\Pt.)	Yes, Enclosed	
8.2	Certificate for 2-laning from Executive Engineer in the following format	Already 4 Lane	
	(a) There feasibility is available " do certify that there will be no hindrance to proposed 6-Waning base on the feasibility report considering proposed structure at the said location.	N/A	
	(b) In case feasibility report is not available I do certify that sufficient ROW is available at sight for accommodate proposed 6-laning.	N/A	
9	As per guidelines license fee shall be Charged	Yes	

Assistant Engineer
N.H., P.W.D. Sultangpur
JEU

Executive Engineer
N.H. Division P.W.D.
Sultangpur

SLMG Beverages Pvt. Ltd.
Unit-II
Authorized Signatory

10	If NH Section proposed to be taken up State PWD on BOT basis a clause in para 17 to be inserted in the agreement. "The permitted Highway on which Licensee has been granted the right of way to the concessionaire under the concession agreement for up- gradation of [. Section From Km....to Km of State PWD No...on Build, Operate and Transfer Basis	N/A	
11	Who will supervise the work of laying of insulated cable	SLMG BEVERAGES PVT. LTD. Plot No. A-1-4/B1-2. Industrial Area Trishundi, UPSIDC, Near CRPF camp Amethi-228159	
12	Who will ensure that the defects in road portion after lay of Water Pipeline are corrected and if not corrected then what action will be taken.	SLMG BEVERAGES PVT. LTD. Plot No. A-1-4/B1-2. Industrial Area Trishundi, UPSIDC, Near CRPF camp Amethi-228159	
13	Who will pay the claims for damages done/ disruption concessionaire concessionaire.	SLMG BEVERAGES PVT. LTD. Plot No. A-1-4/B1-2. Industrial Area Trishundi, UPSIDC, Near CRPF camp Amethi-228159	
14	A permission in the register of records Certificate from PD that he will enter the proposed of the permissions in the prescribed Performa (copy enclosed) issued vide Ministry Circular RW/NH 33044/29/2015/S&R(R)(Pt.) dated 22/11/2016	Yes	
15	If any previous approval is accorded for after lay of Water line then photocopy if register of records of permissions accorded as maintained by PD (as per Ministry Circular RW/NH33044/29/2015/S&R(R)(Pt.) dated 22/11/2016	Not Required	

[Signature]
Assistant Engineer
 N.H. P.W.D., Sultanpur

[Signature]
 Executive Engineer
 N.H. Division P.W.D.
 Sultanpur

[Signature]
SLMG Beverages Pvt. Ltd.
 Unit-11
 Authorized Signatory