



भारतीय राष्ट्रीय राजमार्ग प्राधिकरण

(सड़क परिवहन और राजमार्ग मंत्रालय, भारत सरकार)

NATIONAL HIGHWAYS AUTHORITY OF INDIA

(Ministry of Road Transport & Highways, Government of India)



क्षेत्रीय कार्यालय - हैदराबाद

डो. नं. ८-२-२६९/एस/९४, तीसरी और चौथी मंजिल, प्लॉट नंबर ९४, रोड नं.२, सागर सोसाइटी, बंजारा हिल्स, हैदराबाद-५०००३४, तेलंगाना.

REGIONAL OFFICE - HYDERABAD

D.No. 8-2-269/S/94, 3rd & 4th Floors, Plot No.94, Road No.2, Sagar Society, Banjara Hills, Hyderabad-500034, Telangana.

टेली / Tele : 040 - 29562147 / 48 ई-मेल / Email: rohyderabad@nhai.org / nhairohyd@gmail.com

Notice Inviting Public Comments

NHAI/RO-HYD/25011/1/71/2025/Utility/Powergrid/196

Dt.15.04.2025

विषय: भा.रा.रा.प्रा- क्षेत्रीय कार्यालय, हैदराबाद - प.का.इ हैदराबाद - Proposal of M/s.Power Grid Corporation of India Ltd., for over Head Power line erection and crossing of 765KV D/C Transmission line from Kurnool-III PS - Maheswaram PG on NH-765 at Km.48+830 near Maisigandi Village, Kadthal Mandal, Rangareddy District, across Hyderabad to Dindi section of NH-765 in the State of Telangana - Reg.

Ref: 1. PD, PIU Hyd Lr.no.NHAI/PIU-HYD/NH-765/Hyd-Dindi/Power grid/2025/317, dt:07.04.2025.

The Project Director, NHAI vide letter cited above has recommended the proposal of by M/s.Power Grid Corporation of India Ltd., for over Head Power line erection and crossing of 765KV D/C Transmission line from Kurnool-III PS - Maheswaram PG on NH-765 at Km.48+830 near Maisigandi Village, Kadthal Mandal, Rangareddy District, across Hyderabad to Dindi section of NH-765 in the State of Telangana.

2. As per para 4 of the Ministry's guidelines no. RW/NH-33044/29/2015/S&R(R) dated 22.11.2016, public comments is hereby invited on the above proposal seeking claims and objections (on grounds of public inconvenience, safety and general public interest) within 30 days on public portal i.e. website of Ministry of Road Transport and Highways (www.morth.nic.in) in Form-A (copy enclosed) for "Accommodation of Public and Industrial Utility Services along and across National Highways".

Comment Inviting Authority

The Regional Officer,
National Highways Authority of India,
Regional Office: Hyderabad,
3rd & 4th Floors, Plot No.94,
Road No.02, Sagar Society,
Banjara Hills, Hyderabad-500034.,
Telangana State,
Phone: 040-29562147, 040-29562148,
Email: rohyderabad@nhai.org, nhairohyd@gmail.com

Encls: Above Proposal


(T. Sailaja)

Dy.General Manager (Tech.)
for Regional Officer cum
Highway Administrator, Hyderabad

To:

1. Senior Technical Director, NIC, Transport Bhawan, New Delhi- 110001 for uploading on Ministry's website.
2. Shri S.Manivasagam, Dy. GM (IT), NHAI HQs, New Delhi for uploading on NHAI website.

Copy to:- The PD, PIU Hyderabad: for information

कारपोरेट कार्यालय : जी-५ एवं ६, सेक्टर- १०, द्वारका, नई दिल्ली - ११००७५. वेबसाइट : www.nhai.gov.in

Corporate Office: G-5 & 6, Sector - 10, Dwarka, New Delhi - 110075. Website : www.nhai.gov.in

FORM-A

Form for seeking claims and objections (on grounds of public inconvenience, safety and general public interest) on the application for Accommodation of Public and Industrial Utility Services along and across National Highways

विषय:भा.रा.रा.प्रा- क्षेत्रीय कार्यालय, हैदराबाद - प.का.इ हैदराबाद - Proposal of M/s.Power Grid Corporation of India Ltd., for over Head Power line erection and crossing of 765KV D/C Transmission line from Kurnool-III PS - Maheswaram PG on NH-765 at Km.48+830 near Maisigandi Village, Kadthal Mandal, across Hyderabad to Dindi section of NH-765 in the State of Telangana - Reg.

The claims and objections (on grounds of public inconvenience, safety and general public interest) by the general public needs to be given within 30 days of uploading the online application for comments

Sl. No	Item	Details
1	Name of the person who is desiring to give claims and objections (on grounds of public inconvenience, safety and general public interest)	
2	Address of the person	
3	Details of the application for Accommodation of Public and Industrial Utility Services along and across National Highways against which claims and objections are being given (name of applicant and other details like site address etc.)	
	d) Application No.	
	e) Name of applicant (who applied to Accommodation of Public and Industrial Utility Services along and across National Highways)	
	f) Details of Application	
4	The claims and objections (on grounds of public inconvenience, safety and general public interest)	





भारतीय राष्ट्रीय राजमार्ग प्राधिकरण

(सड़क परिवहन और राजमार्ग मंत्रालय, भारत सरकार)

NATIONAL HIGHWAYS AUTHORITY OF INDIA

(Ministry of Road Transport & Highways, Government of India)



परियोजना कार्यान्वयन इकाई - हैदराबाद

डी.नं.8-2-269/एस/94, प्लॉट नंबर. 94, पहली मंजिल, रोड नंबर. 2, सागर सोसायटी, बंजारा हिल्स, हैदराबाद-500034, तेलंगाना

PROJECT IMPLEMENTATION UNIT - HYDERABAD

D.NO.8-2-269/S/94, Plot No.94, 1st Floor, Road No.2, Sagar Society, Banjara Hills, Hyderabad - 500034. Telangana
टेली Tel : 040 - 29550558 ई-मेल Email: nhaihyd@gmail.com; hyd@nhai.org,

NHAI/PIU-HYD/NH-765/Hyd-Dindi/Power grid/2025/317

To

The Regional Officer
3rd&4th Floor, Plot
No:94, Road No:02,
Sagar Society,
Banjara Hills,
Hyderabad-500034.



DGM (T) - I	Date: 07.04.2025	✓
DGM (T) - II		
DGM (T) - III		
Manager (T) - I		✓
Manager (T) - II		
Manager (T) - III		
DM (F&A)		

Sub: NHAI-PIU-HYD- Construction of 765KV D/C Kurnool III PS- Maheshwaram PG transmission line submission of documents -Approval for O/H power line crossing at Loc No AP133, AP134 with National Highway NH-765 near Maisigandi village, Kadthal Mandal, Rangareddy District near Km.48.800 - Km.48.900-Approval Requested-Reg.

- Ref:** 1. Circular no. RW/NH-33044/29/2015-S&R ® dated 22.11.2016.
2. MoRTH circular NH-36094/01/2022- S&R(P&B) dated 17.04.2023.
3. Powergrid letter no.SR1/NGKL/F-18D/NHAI/NH-765 dated.05.12.2024
4. Powergrid letter no.SR1/NGKL/F-18D/NHAI/ dated.19.02.2025
5. Sc lr.no. AA/TL/NH-765/NHAI/2512/24-25/388 dated.07.03.2025

Sir,

1. This is reference to the proposal for crossing for construction of 765KV D/C transmission line from Kurnool-III PS (Kolimigundla Mandal, Nandyala District) to Maheshwaram SS (PG). The said Transmission line of 765 KV will cross the National Highway No. 765 at Km. 48.830 near Maisigandi village, Kadthal Mandal in Ranga Reddy District of Telangana and requested for permission of overhead crossing of the line.

2. The applicant submitted the proposal vide reference 4th cited along with the proposal, the applicant submitted following documents :

- Checklist
- Undertaking and certificates
- Methodology for stringing of conductor
- Details of overhead transmission line
- conductor and earth wire properties.
- Drawings

4. The proposal was forwarded to SC vide letter dated.28.02.2025, with a request to inspect the site and furnish the detail report as per the Circular no. RW/NH-33044/29/2015-S&R ® dated 22.11.2016 & MoRTH circular NH-36094/01/2022- S&R(P&B) dated 17.04.2023.

5. Supervision Consultant vide letter dated.07.03.2025 (Received on 17.03.2025) recommended the proposal and informed that FRL of Highway and Conductor is 31.43 meters which is satisfying the CEA guidelines of minimum of 22.75 meters for 765 KV.

6. Based on SC's recommendation and documents submitted by the applicant the proposal is examined and generally found in order.

7. In view of the above, the proposal is recommended to Highway Administrator for according approval for crossing of subject transmission line over NH-765.

Encl: As above

Yours faithfully



(P. Nageswara Rao)
GM (T) & Project Director