



No. RO/BBSR/Utility Services/NH-26/KSNG/85/2024 - 855

Date: 22nd Aug, 2024

Invitation of Public Comments

Sub: Proposal for laying of drinking water supply pipelines along NH-26 from km 268/000 to 294/280 (Maidalpur to Nabarangpur) under RWSS Division, Kesinga in the State of Odisha - reg.

1. Executive Engineer, NH Division, Kesinga vide letter dated 01.08.2024 has submitted a proposal for the above mentioned subject as detailed below:
 Along the NH:

Sl. No.	Chainage from km - to km	Details of RoW	Width of carriageway (in mt)	Dia of pile including casing (In mm)	Total length (In km)	Methodology
1	Km 268/864 to 269/374 (RHS)	15.0	10.6	150	0.510	Open trench
2	Km 271/020 to 271/200 (LHS)	15.0	10.6	400	0.180	Open trench
3	Km 283/920 to 284/250 (LHS)	18.0	7.0	600	0.330	Open trench
4	Km 284/625 to 285/585 (LHS)	14.0	10.6	600	0.960	Open trench
5	Km 285/585 to 285/693 (LHS)	14.0	10.6	400	0.108	Open trench
6	Km 285/693 to 286/570 (LHS)	14.0	7.0	400	0.877	Open trench
				Total	2.965	

Across the NH:

Sl. No.	NH Chainage	Available RoW (in mt)	Dia of Pipe (In mm)	Width of carriageway (in mt)	Depth of laying of utility from GL	Methodology
1	266/773	15.0	400	7.0	The pipeline is proposed to be laid below the Ground level at a depth of 1.50 m to 2.00 m.	HDD
2	268/864	15.0	700	10.6		HDD
3	269/388	15.0	150	10.6		HDD
4	270/140	15.0	400	7.0		HDD
5	270/824	15.0	600	7.0		HDD
6	271/140	15.0	400	10.6		HDD
7	271/410	17.0	200	7.0		HDD
8	272/180	13.0	300	7.0		HDD
9	272/535	13.0	200	7.0		HDD
10	272/815	13.0	300	7.0		HDD
11	275/540	16.0	300	7.0		HDD
12	277/295	14.0	300	7.0		HDD
13	278/360	15.0	400	7.0		HDD
14	280/880	15.0	400	7.0		HDD
15	284/530	15.0	900	7.0		HDD
16	284/860	15.0	450	10.6		HDD
17	285/585	17.0	900	15.0		Open trench
18	285/650	14.0	400	10.6		HDD
19	289/900	15.0	450	7.0		HDD
20	291/000	20.0	900	7.0		HDD

[Signature]
 22/08/24.

2. As per Ministry's OM No. RW/NH-33044/29/2015/S&R(R) dated 22nd November, 2016 the Highway Administrator will put out the application in the public domain for 30 days for seeking claims and objections (on grounds of public inconvenience, safety and general public interest, if any).

3. In view of the above, comments of public for claims/objections, if any, on the above proposal are invited online as well as in hard copy. The strip plan/location details are enclosed herewith. The same should reach to the below mentioned address within 30 days from the date of uploading it in the website, beyond which no objection will be considered.

Address:

**Regional Officer,
Ministry of Road Transport & Highways,
Plot No -184, Infront of CRPF Stadium,
Baramunda, Bhubaneswar - 751003.**

Yours faithfully,



(Sudhansu Sekhar Sahu)
Senior Technical Assistant
For Regional Officer

Copy to:

- 1) The Senior Technical Director, NIC, Transport Bhawan, New Delhi - 110001- along with strip chart for uploading on the Ministry's website.
- 2) General public with request to furnish comments, if any, to the above mentioned address or by e-mail to "robbsr.morth@gmail.com"