

NHAI/15018/3.4.7/2019/RO Madurai/E:85639/1097

05th July 2021

INVITATION OF PUBLIC COMMENTS

Sub: NHAI, Madurai Region - PIU, Thanjavur - Erection of 2 Nos of Towers on LHS & RHS & Over Head crossing of 11KV Line across Highway at Km108/450 on Thanjavur - Trichy section of of NH-83 (Old 67) in Sanoorapatti village of BudalurTaluk in Thanjavur District by TANGEDCO, Pudukottai

Ref: PD, Thanjavrlr.No.NHAI/PIU/Thanj/11021/107/2021/1240 dated 18.05.2021

The proposal received from PD, Thanjavr vide cited under reference therein it is requested NOC for the proposal submitted by TANGEDCO, Pudukottai for erection of 2 Nos of Towers on LHS & RHS & Over Head crossing of 11KV Line across Highway at Km108/450 on Thanjavur - Trichy section of of NH-83 (Old 67) in Sanoorapatti village of BudalurTaluk in Thanjavur District by TANGEDCO, Pudukottai

2) The instant proposal has been examined in light of Ministry's latest guidelines dated 22.11.2016 and the following are brought out;

- i. The alignment proposed by Superintending Engineer, Pudukottai had in a length of 60m as detailed under:

Sl. No	Description	Length in Meters	Width in meters	Name of Village	Remarks
Across the Road NH at Km 108/450 Overhead HT line					
1	Km.108/450	60	2.44	Sanoorapatti	Manual Erection of 33/11 KV Overhead HTLine

- ii. The right of way is 60 m in the aforesaid stretch. Superintending Engineer, TANGEDCO, Pudukottai has proposed to erect 33 KV Overhead Line at the edge of the ROW and for a crossing for a length of 60 m across National Highways Proposed Vertical Clearance for the Overhead Crossing is 8.
 - iii. The erection of 2 Nos. of 33 KV overhead line Electrical towers are proposed to be laid at a distance 9.50m on LHS & 8.30m on RHS from the edge of nearest shoulder, which is in conformity with Ministry's guidelines vide letter no. NHIII/ P/ 66/76 dated 19.11.1976.
3. The Superintending Engineer, TANGEDCO Pudukottai has furnished an undertaking to the effect that they will remove the erected 33/11 KV overhead line in future if required by NH Authority at any time for expansion of the NH

at their own cost without claiming any compensation from NHAI. Also, certified that, the proposed erection of 33/11 KV Overhead line work will not affect the design, stability, traffic safety and future improvement of the proposed stretch.

4. As per the guidelines issued by the Ministry vide letter No.RW/NH-33044/29/2015/ S&R (R) dated 22.11.2016 the relaxation application submitted by the applicant will be made available for public comments and the comments may be invited within 30 days from the day of uploading.

In view of the above, comments of the public on the above proposal may be invited to the below mentioned address:

The Regional Officer
National Highways Authority of India
No.2nd& 3rdFloor, Vijay Krishna Plaza,
No.1, Lake Area, Melur Main Road, Mattuthavani,
Madurai - 625 007.

This is issued with the approval of Competent Authority

Yours faithfully,

MS Chaithanya
Manager(Tech)

Copy to:

1. The NIC, New Delhi - for uploading in the Ministry's website.
2. PD, PIU, Thanjavur - for information