

भारत सरकार  
सडक परिवहन और राजमार्ग मंत्रालय  
क्षेत्रीय कार्यालय, भुवनेश्वर  
प्लट संख्या - 184 (फायर स्टेशन चौक के पास)  
बरमुन्डा, भुवनेश्वर-751003  
दूरभाषा : (0674) 2960994 & 2952994  
ई-मेल : robbsr.morth@gmail.com



Government of India  
Ministry of Road Transport & Highways  
Regional Office, Bhubaneswar  
Plot No. - 184 (Near Fire Station Square)  
Baramunda, Bhubaneswar-751003  
Ph. No.: (0674) 2960994 & 2952994  
E-mail: robbsr.morth@gmail.com

File No. RO/BBSR/Utility Services/NH-57/BBSR/106/2025 - 204

Date: 28<sup>th</sup> Apr, 2025

**Invitation of Public Comments**

**Sub:** Permission for laying of 33 KV UG cable from km 266/000 to km 279/900 (Begunia Post office to Binodpada) on RHS and crossing at km 266/000 of NH-57 near Rajsunakhala College - reg.

1. Superintending Engineer, NH Division, Bhubaneswar vide letter dated 19.03.2025 has submitted a proposal on the above mentioned subject as detailed below:

Sl. No.	Chainage from km to km	Details of RoW	Carriageway width (m)	Dia of pipe (In mm)	Total length (km)	Methodology
1	Km 266/000 to 269/800 (RHS)	16.0	10.0	200	3.800	HDD
2	Km 270/400 to 272/200 (RHS)	16.0	10.0	200	1.800	HDD
3	Km 272/800 to 273/300 (RHS)	16.0	10.0	200	0.500	HDD
4	Km 273/600 to 274/100 (RHS)	16.0	10.0	200	0.500	HDD
5	Km 275/500 to 278/200 (RHS)	16.0	10.0	200	2.700	HDD
6	Km 279/800 to 279/900 (RHS)	16.0	10.0	200	0.100	HDD
7	Crossing at Km 266/000	16.0	10.0	200	0.016	HDD
				<b>Total</b>	<b>9.416</b>	

2. As per Ministry's OM No. RW/NH-33044/29/2015/S&R(R) dated 22.11.2016, the Highway Administrator will put out the application in public domain for a period of 30 days for seeking claims and objections (on grounds of public inconvenience, safety and general public interest, if any).

3. In view of the above, comments of public for claims/objections, if any, on the above proposal are invited online as well as in hard copy. The strip plan/location details are enclosed herewith. The same should reach to the below mentioned address within 30 days from the date of uploading it in the website, beyond which no objection will be considered.

**Address:**

Regional Officer,  
Ministry of Road Transport & Highways,  
Plot No -184, Infront of CRPF Stadium,  
Baramunda, Bhubaneswar - 751003.

Yours faithfully,

(Sudhansu Sekhar Sahu)  
Senior Technical Assistant  
For Regional Officer

Encl: As above

**Copy to :**

- 1) The Senior Technical Director, NIC, Transport Bhawan, New Delhi - 110001- along with strip chart for uploading on the Ministry's website.
- 2) General public with request to furnish comments, if any, to the above mentioned address or by e-mail to "robbsr.morth@gmail.com".



बायरी संख्या 2835-  
 तारीख 19.03.2025  
 सडक परिवहन और राजमार्ग मंत्रालय  
 क्षेत्रीय कार्यालय, भुवनेश्वर

TEL -0674-2972908-(O)  
 eenh\_bbsr@yahoo.co.in

OFFICE OF THE EXECUTIVE ENGINEER  
 NATIONAL HIGHWAY DIVISION BHUBANESWAR  
 PLOT NO-184, NAYAPALLI, PO-BARAMUNDA, BHUBANESWAR

No. 1889 / Dt. 19-3-2025

To

The Regional Officer  
 MoRT&H, Bhubaneswar

Sub: - Permission for erection of 33 KV newline with 13 Mtr. WPB poles and laying 33KV UG cable 1R X 3C X 400 from 220/ 132/33KV Atri Grid to Binodpada 33/11 KV PSS under CMPDP on NH-57 from KM 266/000 to 279/900 KM (Begunia Post office to Binodpada) & crossing at. KM 266/000 of NH-57 near Rajsunakhala College.

Sir,

In inviting a reference to the subject cited above, it is to submit herewith the following documents as received from TPCODL, Bhubaneswar-II Circle, Khordha alongwith the site inspection report in the prescribed format duly signed for favour of information and necessary approval.

1. The layout plan alongwith cross section drawing & methodology are enclosed.
2. A strip plan showing across with chainages and LHS/RHS of road NH-57 is enclosed.
3. A site inspection report in the prescribed proforma duly signed by the all concerned is enclosed.
4. The Bench Mark value issued by the concerned Sub-Registrar is enclosed herewith.
5. Calculation sheet for Performance Bank Guarantee & License fees are enclosed herewith.

Encl: - As above

Yours faithfully,

*[Signature]*

Superintending Engineer  
 N.H. Division, Bhubaneswar

Memo No. 1890 / Dt. 19-3-2025

Copy to the HOG Projects Bhubaneswar-II, Circle ([trupti.mohanty@tpcentralodisha.com](mailto:trupti.mohanty@tpcentralodisha.com)) for information and necessary action with reference to his office letter no.191 dt.18.11.2024.

*[Signature]*

Superintending Engineer  
 N.H. Division, Bhubaneswar

Memo No. 1891 / Dt. 19-3-2025

Copy to the Executive Engineer, TPCODL, Khordha for information and necessary action.

*[Signature]*

Superintending Engineer  
 N.H. Division, Bhubaneswar

Memo No. 1892 / Dt. 19-3-2025

Copy to the Asst. Executive Engineer, NH Sub-Division, Khordha for information and necessary action.

*[Signature]*


Superintending Engineer  
 N.H. Division, Bhubaneswar


Please examine


Sr 7A


em  
 20/03/25

Encloser to site inspection report for laying of 200 mm HDPE pipe for 33 KV Line along the road at Beguniya to Binodpada NH 57										
sl.no	NH NO	NH Chainage from km to km	side of laying (Lsh /Rhs/crossing)	Available ROW	Carriageway width	Embankment	Dia of utility including casing	Methodology( OPEN TRENCH/HDD)	Depth of Laying from Ground Level	Width of Trench
1	NH-57	266/00	CROSSING	16 MTR	10M	AVG 1.5 MTR	200MM	HDD	1500 MM	
2		266/00 TO 269/800	ALONG THE ROAD RHS	16 MTR	10M	AVG 1.5 MTR	200MM	HDD	1500 MM	
3		270/400 TO 272/200	ALONG THE ROAD RHS	16 MTR	10M	AVG 1.5 MTR	200MM	HDD	1500 MM	
4		272/800 TO 273/300	ALONG THE ROAD RHS	16 MTR	10M	AVG 1.5 MTR	200MM	HDD	1500 MM	
5		273/600 TO 274/100	ALONG THE ROAD RHS	16 MTR	10M	AVG 1.5 MTR	200MM	HDD	1500 MM	
6		275/500 TO 275/900	ALONG THE ROAD RHS	16 MTR	10M	AVG 1.5 MTR	200MM	HDD	1500 MM	
7		275/900 TO 278/200	ALONG THE ROAD RHS	16 MTR	10M	AVG 1.5 MTR	200MM	HDD	1500 MM	
8		279/800 TO 279/900	ALONG THE ROAD RHS	16 MTR	10M	AVG 1.5 MTR	200MM	HDD	1500 MM	

  
 Rupali Sundar Mohanty  
 HOG-Projects

  
 Junior Engineer  
 N.H. Section, Khordha


  
 Assistant Executive Engineer  
 N.H. Sub-Division Khordha

  
 Superintending Engineer  
 N.H Division, Bhubaneswar

SINGLE LINE DIAGRAM OF 33 KV ATRI TO BINODPARA NEW LINE

BINODPARA 33/11 KV PSS

TOWARDS KHORDA



NEAR RAJSUNAKHELA COLLEGE

UG 3C\*300 SQMM 33 KV

OH LINE OF NEW 33 KV

UG 3C\*300 SQMM 33 KV

UG 3C\*300 SQMM 33 KV

OH LINE OF NEW 33 KV WITH 13 MTR WPB POLE

PROPOSED ROUTE OF 33 KV NEW LINE ATRI TO BINODPARA  
APPROX LENGTH 15 CKM

(RHS)

(RHS)

NEAR BEGUNIA POST OFFICE

*Dr. Shanti*  
18/11/24