



दूरभाष / Tele : +91-452-258 8999
वेब / Website : www.nhai.gov.in
ई-मेल / E-mail : romadurai@nhai.org
nhairomadurai@gmail.com

भारतीय राष्ट्रीय राजमार्ग प्राधिकरण
(सड़क परिवहन और राजमार्ग मंत्रालय)
National Highways Authority of India
(Ministry of Road Transport & Highways)
क्षेत्रीय कार्यालय, मदुरै / **Regional Office, Madurai**
दूसरा व तीसरी तल, विजय कृष्ण प्लाज़ा, संख्या-1 लेक एरिया, मेलूर मेन रोड, माटुतावनी, मदुरै-625 107
2nd & 3rd Floor, Vijay Krishna Plaza, No.1, Lake Area, Melur Main Road, Mattuthavani, Madurai-625 107



BHARATMALA
ROAD TO PROSPERITY

NHAI/15018/3.7.5/2019/RO Madurai/E:88419/1150

20th July 2021

INVITATION OF PUBLIC COMMENTS

Sub: NHAI, Madurai Region - Highway Administration - Tuticorin - Tirunelveli section from Km.0/000 to Km.47/250 of NH-138(Old 7A) in the State of Tamil Nadu -Erection of 400 KV DC Overhead Electrical line crossing at Km.25+800 in Near Vagaikulam village by TANTRANSCO.

Ref: PD, Tuticorin Lr.No. NHAI/PIU/TUTY/NH-45B/2021/531, dt. 15.06.2021.

The proposal received from PD, Tuticorin vide reference cited above recommending for issuing NOC for erection of 400 KV Overhead Line in Vagaikulam village

- Across highway @ Km.25+800 on Tuticorin - Tirunelveli section of NH-7A (Old No. NH-138) by TANTRANSCO.

2) The instant proposal has been examined in light of Ministry's guidelines dated 22.11.2016 and the following are brought out;

The alignment proposed by TANTRANSCO, Madurai is proposing to erect Over Head Line as hereunder:

Sl. No	Description	Length in Meters	Width in meters	Name of Village	Remarks
Across the road NH					
1	Km.25+800	45	20	Vagaikulam	Manual erection of 400 KV DC Tower line

3) The right of way is 45 m in the aforesaid stretch. The Applicant proposed to erect 400 KV Overhead Electrical Line crossing the NH at Km.25+800 in Tuticorin - Tirunelveli section of NH 138 (old NH7A). Further the Superintendent Engineer, TANTRANSCO, Madurai has given undertaking that the vertical clearance is 25.25 m from the Top of the crown of the road which is in conformity with Ministry's latest guidelines dated 22.11.2016.

4) The applicant has furnished an undertaking that they will shift the erected electrical line in future when required by NH Authority at any time for expansion of the NH at their own cost without claiming any compensation from NHAI. Also, certified that, the proposed erection of 400 KV overhead electrical line work will not affect the design, stability, traffic safety and future improvement of the proposed stretch.

5) As per the guidelines issued by the Ministry vide letter No. RW/NH-33044/29 /2015/S&R(R) dated 22.11.2016, the application submitted by the applicant will be made available for public comments and the comments will be invited within 30 days from the day of uploading.

In view of the above, comments of the public on the above proposal is invited to the below mentioned address:

The Regional Officer
National Highways Authority of India
No.2nd & 3rd Floor, Vijay Krishna Plaza,
No.1, Lake Area, Melur Main Road, Mattuthavani,
Madurai - 625 007.

This is issued with the approval of competent authority

Yours faithfully,

MS Chaithanya
Manager(Tech)

Copy to:

1. The NIC, New Delhi - for uploading in the Ministry's website.
2. PD, PIU, Tuticorin - for information.