



# भारतीय राष्ट्रीय राजमार्ग प्राधिकरण

(सड़क परिवहन और राजमार्ग मंत्रालय, भारत सरकार)  
क्षेत्रीय कार्यालय - गुजरात

## National Highways Authority of India

(Ministry of Road Transport & Highways, Govt. of India)  
Regional Office - Gujarat

235-239, दुसरी मंजील, सुपरमॉल-1, एच.डी.एफ.सी. फाइनेंस के उपर, इन्फोसिटी, गांधीनगर - 382007 (गुजरात)  
235-239, 2<sup>nd</sup> Floor, Supermall-1, Above HDFC Finance, Infocity, Gandhinagar - 382007 (Gujarat)

दूरभाष / Phone : 079-40306838, 40306839

फैक्स / Fax : 079-40190631

ई-मेल / e-mail : rogujarat@nhai.org

NHAI/18013/01/2010-RO-GNR/US/Vol.-1/NOC-111/D-155

14<sup>th</sup> Jan. 2020

### Invitation of Public Comments

**SUB:** Proposal seeking permission for overhead crossing of NH-53 between Km 102&103 by transmission power line in LILO of One Circuit of 220KV D/C Ukai-Achhaliya line NO-3 at 220KV Virpore S/s between Vyara and Songadh National Highway in Gujarat.

**REF:** Project Director, PIU-Surat's letter no. 7442 dated 14.12.2019.

The proposal is regarding permission for overhead crossing of NH-53 between Km 102-103 by transmission power line in LILO of One Circuit of 220KV D/C Ukai-Achhaliya line NO-3 at 220KV Virpore S/s between Vyara and Songadh, was forwarded to this office by PD, PIU-Surat vide letter u/ref. for approval of Highway Administration.

2. The recommended proposal of PD, PIU-Surat has been examined by this office and detailed features of the proposal are as under:

Sr. No.	Items	Information/Status
1	Crossing type and purpose	Electrical Overhead Crossing
2	NH No.	NH-53
3	Crossing Name	Vyara-Songadh
4	Chainage of NH	Km 102 & 103
5	Methodology for laying power supply line	Overhead Line
6	Span of overhead line crossing	350 Mtrs
7	Whether Towers/Poles of overhead crossing fall under ROW	No
8	Angle of Road Crossing	85 Degree
9	Tower/Pole Height	42.22 & 45.22 Mtrs
10	Vertical Clearance from FRL to lowest cable of overhead crossing	17.9mtr

2. As per Ministry vide OM No RW/NH-33044/29/2015/S&R(R) dt.22.11.2016, the Highway Administration will make available the proposal seeking permission for utility laying for public comments for 30 days on ground of general public interest for seeking claims and objections.

3. In view of above, the comments of public are invited on captioned proposal and the same should reach to below mentioned address till **13.02.2020** beyond which no comments will be considered.


The Highway Administration-cum-Regional Officer  
National Highways Authority of India  
235-239, 2<sup>nd</sup> Floor, Supermall-1, Above HDFC Finance, Infocity,  
Gandhinagar-382 007 (Email: rogujarat@nhai.org).

Contd...2

*Sandeep*  
14/01/2020

/// 2 ///

4. This issues with the approval of Highway Administration-cum-Regional Officer, NHAI-Gandhinagar.

  
14/01/2020  
(Sandeep Patidar)  
Manager (Tech)

For, Chief General Manager(T) &  
Regional Officer, NHAI-Gandhinagar

- Copy to:
1. Sr. Technical Director, NIC, Transport Bhavan, New Delhi-110001: For uploading on Ministry's website.
  2. PD-NHAI, PIU-Surat: For information and with request to work out the amount of Performance Security as per site conditions and Para-6 of MoRT&H guidelines issued vide Circular No. RW/NH-33044/29/2015/S&R(R) dt. 22.11.2016 and convey the same to the applicant with intimation to this office.
  4. The Ex. Engineer(Const.), GETCO, Construction Division Office, Navsari-396424: For information and with request to submit the requisite performance BG as worked out by the PD, PIU-Surat. The Performance Bank Guarantee should be in favour of Project Director, NHAI, PIU-Surat and to be submitted to PD, NHAI-PIU, Surat custodian of BGs.