



भारतीय राष्ट्रीय राजमार्ग प्राधिकरण
(सड़क परिवहन और राजमार्ग मंत्रालय)
National Highways Authority of India
(Ministry of Road Transport & Highways)
क्षेत्रीय कार्यालय, चेन्नई / **Regional Office, Chennai**
'श्री टावर' 3rd मंजिल, DP-34 (SP), इंडस्ट्रीयल एस्टेट, गिण्डि, चेन्नई - 600 032
'SRI TOWER', 3rd Floor, DP-34 (SP), Industrial Estate, Guindy, Chennai - 600 032.

दूरभाष/Tele : 91-44-2225 2635
फैक्स/Fax : 91-44-2225 2636
ई-मेल/ E-mail: rochennai@nhai.org

NHAI/11019/16/2009/RO Chennai 149

10th January, 2020

Invitation of Public Comments

Sub: NHAI, RO, Chennai - PIU, Viluppuram – Four Laning and Strengthening of existing two lane from Pondy cherry (Km 0/000) to Tindivanam (Km 37/920) Section of NH-66 on BOT Basis under NHDP-III – Crossing of 110 KV Underground Power Cable & OFC from 110/22 KV Kurumbapet Substation to upcoming 110/22 KV GIS Substation at JIPMER at Km 2/585 of NH-66 – Regarding.

The proposal is regarding permission sought for laying of 110 KV Underground Power Cable & OFC from 110/22 KV Kurumbapet Substation to upcoming 110/22 KV GIS Substation at JIPMER across NH-66 at Km 2/585 by M/s. Power Grid Corporation of India Limited, Pudhucherry submitted to this office by the PD, NHAI, Viluppuram vide letter No. 11024/NH-66/06/Vol-1/2018/PIU-VPM/2626 dated 05.12.2019.

2. The available width of ROW is 14.90m on LHS and 18.50m on RHS. M/s. Power Grid Corporation of India Limited, Pudhucherry proposed to lay (3 + 1 spare) Underground Electrical Cable of size 630 Sqm, each kept in 200 mm dia HDPE Pipe and one number of OFC Cable (24 Core) is kept in 40mm dia HDPE Pipe. M/s. Power Grid Corporation of India Limited, Pudhucherry proposed to lay the Electrical Cables and OFC cable across National highway by HDD method duly keeping the top of HDPE Pipes at a depth of 2.5m below the ground level. The size of the HDD pit proposed is 2m x 2m x 3m and it is proposed outside the ROW

3. Deputy Director, JIPMER, Pudhucherry has furnished an undertaking to accept any claims raised by the Concessionaire if any and the same will be paid by them. An undertaking to indemnify the concerned agency in coordination with NHAI, against all damages and claims, if any, due to the digging of trenches for laying cables/ducts.. Further, undertaking has been furnished not to damage other utility and in case damaged then to pay the losses either to NHAI or to the concerned agency.

4. As per the guidelines issued by the Ministry vide letter No.RW/NH-33044/29/2015/ S&R(R) dated 22.11.2016, the proposal submitted by M/s. Power Grid Corporation of India Limited, Pudhucherry of Deputy Director, JIPMER, Pudhucherry will be made available for 30 days seeking public comments/objections and the comments shall be furnished within 30 days from the day of closure of public objections.

National Highways Authority of India

In view of the above, comments of the public on the above proposal are invited and may be sent to the below mentioned address:

The Regional Officer
National Highways Authority of India
(Ministry of Road, Transport & Highways)
SRI Tower, 3rd Floor
DP - 34 (SP), Industrial Estate,
Guindy - Chennai-600 032

Yours faithfully,



(A. Savithri Devi)
Deputy General Manager (Tech)
For Regional Officer, NHAI, Chennai

Copy to:

1. NHAI website
2. The NIC, New Delhi - for uploading in the Ministry's website.
3. PD, NHAI, Viluppuram – for information