

भारतीय राष्ट्रीय राजमार्ग प्राधिकरण (सड़क परिवहन और राजमार्ग मंत्रालय) National Highways Authority of India (Ministry of Road Transport & Highways) क्षेत्रीय कार्यालय, मदुरे / Regional Office, Madurai दूसरा व तीसरी तल, विजय कृष्ण 'लाज़, संख्या-1 लेक एरिया, मेलूर मेन रोड, माहुतावनी, मदूरे-625 107 2" & 3" Floor, Vijay Krishna Plaza, No.1, Lake Area, Melur Main Road, Mattuthavani, Madurai-625 107



NHAI/15018/3.7.6/2019/RO Madurai/E:99210/1861

30th September 2021

INVITATION OF PUBLIC COMMENTS

Sub: NHAI, Madurai Region - Highway Administration - Operation and Maintenance of Madurai - Tuticorin section from Km.138.800 to Km.266.865 of NH-45B in the State of Tamil Nadu - Erection of 11 KV Overhead transmission line along the road from Km.196+400 to Km.197+400 RHS and crossing at Km.196+400 in Near Vembur village by M/s. Sarkan Energy Ventures Pvt. Ltd

The proposal received from PD, Tuticorin vide reference cited above recommending for issuing NOC for erection of 11 KV Overhead Line in Vembur village.

- (i) Across highway @ Km.196+400
- (ii) Along the highway at from Km 196+400 to Km 197+400(RHS) on Madurai-Tuticorin section of NH-45B by M/s. Sarkan Energy Ventures Pvt. Ltd
- 2) The instant proposal has been examined in light of Ministry's guidelines dated 22.11.2016 and the following are brought out;

The alignment proposed by M/s. Sarkan Energy Ventures Pvt. Ltd, Kanchipuram is proposing to erect Over Head Line as hereunder:

SIN o.	Description	Length in Meters	Width in meters	Name of Village	Remarks
1	Along the road NH to Km.196+400 Km.197+400	1000	1.5	Vembur	Manual erection of 11 KV Tower line
2	Across the road NH Km196+400	60	1.5		TT KV TOWEI TITIE

3. The right of way is 60 m in the aforesaid stretch. The Applicant proposed to erect 11 KV Overhead Electrical Line along the road from Km.196+400 to Km.197+400 RHS and crossing the NH at Km.196+400 in Madurai - Tuticorin section of NH45B. Further the M/s. Sarkan Energy Ventures Pvt. Ltd, Kanchipuram has given undertaking that the vertical clearance is 11.00m

from the Top of the crown of the road which is in conformity with Ministry's latest guidelines dated 22.11.2016.

- 4. The applicant has furnished an undertaking that they will shift the erected electrical line in future when required by NH Authority at any time for expansion of the NH at their own cost without claiming any compensation from NHAI. Also, certified that, the proposed erection of 11 KV overhead electrical line work will not affect the design, stability, traffic safety and future improvement of the proposed stretch.
- 5. As per the guidelines issued by the Ministry vide letter No. RW/NH-33044/29 /2015/S&R(R) dated 22.11.2016, the application submitted by the applicant will be made available for public comments and the comments will be invited within 30 days from the day of uploading.

In view of the above, comments of the public on the above proposal is invited to the below mentioned address:

The Regional Officer
National Highways Authority of India
No.2nd& 3rdFloor, Vijay Krishna Plaza,
No.1, Lake Area, Melur Main Road, Mattuthavani,
Madurai - 625 007.
This is issued with the approval of competent authority

Yours faithfully,

MS Chaithanya Manager(Tech)

Copy to:

- 1. The NIC, New Delhi for uploading in the Ministry's website.
- 2. PD, PIU, Tuticorin for information.