



GOVERNMENT OF INDIA  
MINISTRY OF ROAD TRANSPORT & HIGHWAYS

TELEFAX: 0141-2811776, 2811883  
E-mail: ro.jaipur.morth@gmail.com

O/o REGIONAL OFFICER,  
DCM, AJMER ROAD,  
JAIPUR - 302019

No. RW/JAI/RJ/PS/Utility/2025/576 / 3690-92

Dated: 27.02.2025

**Invitation of Public Comments**

Sub: Proposal for the approval of overhead crossing of NH-62 (Bikaner to Sriganganagar, between chainage-49.188 km & 49.256 km) by TL02 of 765 KV DC Bikaner III – Neemrana II transmission line (part-I) associated with Transmission system for evacuation of power from REZ Ph-IV (part-I) (Bikaner Complex:7.7 GW) Part-A through tariff based competitive bidding (TBCB) route.

**Authorized Signatory Powergrid Bikaner Neemrana Transmission Ltd** has submitted a proposal to this office on above mentioned subject through EE PWD NH-Div-Bikaner (Raj), which has certified the proposal as per extant practice.

2. As per Ministry's OM No.RW/NH-33044/29/2015/S&R dated 22.11.2016, the application shall be put out in the public domain for 30 days for seeking claims and objections (on grounds of public inconvenience, safety and general public interest).

3. In view of the above the comments of public are invited on captioned proposal on online portal at [www.morth@nic.in](http://www.morth@nic.in) or on below mentioned address.

Regional Officer cum Highway Administration.  
Ministry of Road Transport and Highways  
DCM, Ajmer Road, Jaipur-302019

4. This issues with the approval of Highway Administration-cum-R.O. (Civil), MoRTH, Jaipur.

Yours faithfully,

(Ravi Chanchal)  
Executive Engineer  
For Regional Officer

Copy to:-

1. Senior Technical Director, NIC, Transport Bhawan, New Delhi -110 001 for uploading on Ministry's website.
2. Powergrid Bikaner Neemrana Transmission Ltd Leela Gauri Heights B-1, Karni Nagar, Nagnechi Road, Bikaner, Rajasthan-334003.
3. EE PWD NH-Division-Bikaner (Raj).



GOVERNMENT OF INDIA

MINISTRY OF ROAD TRANSPORT & HIGHWAYS

TELEFAX: 0141-2811776, 281183

E-mail: ro.jaipur.morth@gmail.com

O/o Regional Officer,  
DCM, AJMER ROAD,  
JAIPUR - 302 019

No. RW/JAI/RJ/PS/Utility/2025/576/3693-94

Dated:- 27.02.2025

To,

Executive Engineer  
PWD NH-Division  
Bikaner (Raj)

Sub: Proposal for the approval of overhead crossing of NH-62 (Bikaner to Sriganganagar, between chainage-49.188 km & 49.256 km) by TL02 of 765 KV DC Bikaner III – Neemrana II transmission line (part-I) associated with Transmission system for evacuation of power from REZ Ph-IV (part-I) (Bikaner Complex:7.7 GW) Part-A through tariff based competitive bidding (TBCB) route.

Sir,

Please refer to your letter no.967 dated 13.02.2025 received on 18.02.2025 vide which the above proposal has been forwarded to this office for approval. The proposal has been examined and following are observations:-

- (i) Width of available ROW has been mentioned 67m in checklist. The same may be confirmed based on the available LA records and supporting documents.
- (ii) It is requested to submit exact chainage and NH section name where overhead lines are crossing.
- (iii) It is noted that in Checklist is not showing MoRTH norms compliance i.e. whether it is Yes or No. It is requested to submit corrected checklist.
- (iv) It is requested to submit sketch of overhead transmission line showing Tower location and no of towers.
- (v) The instant proposal may be checked with future upcoming widening scheme on the NH section, if any.
- (vi) It may be confirmed that towers are not getting erected in NH ROW.
- (vii) Clearance of overhead lines in respect of NH as per norms may be mentioned.

2 In view of the above, the proposal is returned herewith request to submit the compliance of observation along with recommendation.

Encl:-As above

Yours faithfully,

(Ravi Chanchal)

Executive Engineer  
For Regional Officer

Copy to:- Powergrid Bikaner Neemrana Transmission Ltd Leela Gauri Heights B-1, Karni Nagar, Nagnechi Road, Bikaner, Rajasthan-334003.