

Government of India
Ministry of Road Transport & Highways
(Chief Engineer - Regional Office, Lucknow)

N.H. Bhawan, Biotech Chowk, Lucknow Ring Road, Vikas Nagar, Lucknow - 226 022
Ph.: (0522) - 2967112, 2738226 (Tele-Fax)

Dated: 24.05.2023

Invitation of public comments

Sub.: Proposal for NOC for overhead crossing of 132 KV D/C (Campierganj to Anand Nagar) overhead transmission line at km.465.062 of NH-730, in the State of Uttar Pradesh - Reg.

The Executive Engineer, M/s Uttar Pradesh Power Transmission Corporation Ltd., Mohaddipur, Gorakhpur submitted the proposal for overhead crossing of 132 KV D/C at Km.465.062 of NH-730 in the State of Uttar Pradesh to the Executive Engineer, NH Division, PWD, Gorakhpur.

2. From the submitted drawing, it is noted that the height of both the pylons on which the proposed overhead line is hanging is 41.915 m. The pylons on either side are erected at distance of 97 m & 108 m from the National Highway boundary. Further, it noted that the minimum clearance between the lowest conductor of the proposed line and NH carriageway is 15.80 m.

3. As per the guidelines, issued by the Ministry vide OM No.RW/NH-33044/29/2015/S&R(R) dated 22.11.2016, the application shall be put out in the public domain for 30 days for seeking claims and objections (on grounds of public inconvenience, safety and general public interest).

4. In view of the above, comments of public on the above application is invited to the below mentioned address:

The Chief Engineer - Regional Officer,
Ministry of Road Transport & Highways,
N.H. Bhawan, Biotech Chowk, Lucknow Ring Road,
Vikas Nagar, Lucknow - 226 022.

Encl.: As Above.

Yours faithfully,



(Ritesh Yadav)

Assistant Executive Engineer
For Chief Engineer - Regional Officer

Copy to:

- (i) NIC, New Delhi - for uploading on the Ministry's website.
- (ii) The Chief Engineer (NH), UP PWD, Lucknow - for information.




(Ritesh Yadav)


Assistant Executive Engineer
For Chief Engineer - Regional Officer


CHEK LIST


1. National Highway Number : NH - 730
2. Name of Crossing : RAGHUNATHPUR - KASHIPUR (NH -730)
3. Crossing at Chainage : 465.062 km from KASHIPUR towards
RAGHUNATHPUR
4. Position of towers : Outside the ROW of NH-730
5. Crossing Span : 240 M
6. Clearance over the road level : 15.80 M
7. Angle of road crossing : 86^0
8. Distance from NH Boundary to : Loc. No.21/0 (DD+12) = 97 M.
center of tower : Loc. No.AP-22 (DD+12) = 108 M
9. Perpendicular distance from center : Loc. No. AP-21 (DD+12) = 117 M
of tower to center of road : Loc. No.AP-22 (DD+12) = 123 M
10. No. of stay required : Not applicable
11. Minimum Factor of Safety : 2.0 (Normal condition)
12. Size of power conductor mm. : ACSR ZEBRA (Conductor dia. 28.62MM
Al. : 54/3.18 mm., Steel : 7/3.18 mm.
13. Size of Earth Wire/OPGW : 24 FIBRE


20/9/21
Surveyor
RS JPL

Sudeep
S.D.O., ETSD-IT
Fertiliser, GKP.
21.09.21


स्थानिक अभियन्ता
क. वि. नि. ई०, रा० मार्ग
गो० नि० वि० गोरखपुर


कार्य प्रवीक्षक
क. वि. नि. ई. (रा. मार्ग) गो. नि.
गोरखपुर


क. वि. नि. ई. (रा. मार्ग) गो. नि.
गोरखपुर