



भारतीय राष्ट्रीय राजमार्ग प्राधिकरण

(सड़क परिवहन एवं राजमार्ग मंत्रालय, भारत सरकार)

National Highways Authority of India

(Ministry of Road Transport & Highways, Govt. of India)

क्षेत्रीय कार्यालय: "नारंग टॉवर", तिसरी मंजिल, उपआयुक्त यातायात पुलिस (नागपुर शहर) कार्यालय के सामने, पाम रोड, सिविल लाईन्स नागपुर-440 001 महाराष्ट्र
Regional Office: "Narang Tower", 3rd Floor, Opp. to Office of Dy. Commissioner of Police Traffic (Nagpur City), Palm Road, Civil Lines, Nagpur- 440 001 Maharashtra
Tel/Fax : 0712-2520091, 0712-2980554 ई-मेल/ Email : ronagpur@nhai.org



NHAI/RO/NAG/U-82/NH-53/MSEDCL-33KV/2021-22/2069 Date: 24.09.2021

Invitation of Public Comments

Sub: Four laning Madhya Pradesh / Maharashtra Nagpur section of NH-7 from km.652.00 (New km 653.225) to km.729.00, including construction of Kamptee - Kanhan & Nagpur Bypass and Maintenance of already, 4 landed section from km.14.585 to km.36.600 NH-7 (Nagpur-Hyderabad Section) in State of Maharashtra under NHDP Phase-II on DBFOT Basis - **Permission of laying of electrical underground cable along NH-44 from km 725+455 to km 724+500 (RHS) and Crossing at 724+500 of Jabalpur - Nagpur of NH-44-Reg.**

Ref.:

1. PD, PIU-1, Nagpur letter no. 1598 dated 20.09.2021.
2. Executive Engineer, O&M Division, MSEDCL, Mouda office letter No. 2722 dated 09.07.2021.

It is to inform all concern that M/s Maharashtra State Electricity Distribution Co. Ltd. vide letter under reference (2) has submitted a proposal for the subjected work and PD, NHAI, PIU, Nagpur 1 has recommended the above proposal vide letter under reference (1) for approval of the Competent Authority / Highway Administrator.

2. The alignment proposed by that M/s Maharashtra State Electricity Distribution Co. Ltd. along on Jabalpur - Nagpur section from km 725+455 to km 724+500 (RHS) on NH-44 in the State of Maharashtra as follows:

- Underground 33 KV Cable to be laid from km 725+455 to km 724+500 (RHS) along the Highway in utility corridor.
- Cable to be laid with 4 Ducts in 1.20m below ground level.
- Crossing at 724+500
- Cable to be crossed by HDD method

3. As per Para-4 of Ministry's Circular No.RW/NH-33044/29/2015/S&R(R), dated 22.11.2016, the Highway Administration shall be put out in the public domain for 30 days for seeking claims and objections (on grounds of public inconvenience, safety and general public interest).

4. In view of the above, the comments / objections of affected public is hereby invited with reference to the Ministry's circular dated 22.11.2016 due to above underground line on the subjected stretch. The objections / comments may be addressed to the below mentioned address upto 06.02.2021, beyond due date, no comments/ objections will be accepted.

The Regional Officer,
Regional Office - Nagpur
National Highways Authority of India,
"Narang Towers", 3rd Floor,
Opp.to Office of Dy. Commissioner of Police Traffic (Nagpur City),
Palm Road, Civil Lines, Nagpur-440 001, Maharashtra
Tel : 0712-2520091
Email : ronagpur@nhai.org

N. Wadetur
24.09.21
(Naresh Y. Wadetur)
General Manager (Tech.)
NHAI, RO, Nagpur

Copy to: (i) Web Admn., NHAI, HQ, New Delhi - for uploading in NHAI's website
[web-admin@nhai.org]

(ii) Director, NIC, New Delhi - for uploading in Ministry's website
[mansoor@nic.in]