



दूरभाष / Tele : +91-452-258 8999  
वेब / Website : www.nhai.gov.in  
ई-मेल / E-mail : romadurai@nhai.org  
nhairomadurai@gmail.com

**भारतीय राष्ट्रीय राजमार्ग प्राधिकरण**  
(सड़क परिवहन और राजमार्ग मंत्रालय)  
**National Highways Authority of India**  
(Ministry of Road Transport & Highways)  
क्षेत्रीय कार्यालय, मदुरै / Regional Office, Madurai  
दूसरा व तीसरी तल, विजय कृष्ण प्लाज़ा, संख्या-1 लेक एरिया, मेलुर मेन रोड, माटुतावनी, मदुरै-625 107  
2<sup>nd</sup> & 3<sup>rd</sup> Floor, Vijay Krishna Plaza, No.1, Lake Area, Melur Main Road, Mattuthavani, Madurai-625 107



**BHARATMALA**  
ROAD TO PROSPERITY

NHAI/15018/4.3.3/2019/RO Madurai/E:119819/2571

20<sup>th</sup> December, 2021

### INVITATION OF PUBLIC COMMENTS

**Subject:** NHAI, Madurai Region - Highway Administration - Permission for laying of water Pipe line under PIU, Karaikudi - laying Water pipe line by TWAD Board, Project Division, Karaikudi Along the Road at Km.71/899 to Km91/054 (RHS) & Km.76/286 Km.76/686 (LHS) by open trench method & across at 10 locations by trenchless method in Trichy - Karaikudi section of NH-210 (New NH 336, 36 & 536) in the state of Tamilnadu- Invitation of Public Comments - Reg.

The Proposal is regarding permission for laying of water supply pipeline from

- i. Along the road
    - a. Km.71/899 to Km91/054 (RHS)
  - ii. Across the road at
    - a) Km.76/286
    - b) Km.76/686 (LHS) on Trichy - Karaikudi section of NH 210 (New NH - 336, 36 & 536) TWAD Board, Karaikudi.
- 2) TWAD Board, Karaikudi has proposed to lay the Water supply pipeline for a length of 20525 m along the edge of the ROW, which is at a distance of 23.5m from centerline of the project and across the project at 10 locations at a depth of 1.5m below ground level. The proposal is in conformity with Ministry's guidelines vide letter No. NHIII/P/66/76 dated 19.11.1976.
- 3) Further TWAD Board, Karaikudi has mentioned that the Water supply pipeline along the NH by Open Trench Method at a depth of 1.10m for along portion and by HDD at a depth of 1.5m for across portion.
- 4) TWAD Board, Karaikudi has furnished an undertaking to the effect that the applicant will remove the laid Water supply pipeline in future if required by NHAI/MoRTH, Govt. of India at any time for expansion of the NH at their own cost without claiming any compensation. Further, mentioned that TWAD Board, Karaikudi will also restore the surfaces to its original condition soon after removal of the Water supply pipelines.
- 5) As per the guidelines issued by the Ministry vide letter No. RW/NH33044/29/2015/ S&R(R) dated 22.11.2016 the proposal submitted by the applicant will be made available for public comments and the comments is invited within 30 days from the day of uploading. In view of

the above, comments of the public on the above proposal is invited to the below mentioned address:

The Regional Officer,  
National Highways Authority of India,  
No.2nd & 3rd Floor, Vijay Krishna Plaza,  
No.1, Lake Area, Melur Main Road, Mattuthavani,  
Madurai - 625 007.

Yours Faithfully,

**Encl:** As Above.

**(MS Chaithanya),  
Manager (Tech.,)**

**Copy to:**

1. The NIC, New Delhi - for uploading in the Ministry's website.
2. The PD, Karaikudi - for information.