



दूरभाष / Tele : +91-452-258 8999  
वेब / Website : www.nhai.gov.in  
ई-मेल / E-mail : romadurai@nhai.org  
nhairomadurai@gmail.com

**भारतीय राष्ट्रीय राजमार्ग प्राधिकरण**  
(सड़क परिवहन और राजमार्ग मंत्रालय)  
**National Highways Authority of India**  
(Ministry of Road Transport & Highways)  
क्षेत्रीय कार्यालय, मदुरै / Regional Office, Madurai  
दूसरा व तीसरी तल, विजय कृष्ण प्लाज़ा, संख्या-1 लेक एरिया, मेलुर मेन रोड, माट्टुतावनी, मदुरै-625 107  
2<sup>nd</sup> & 3<sup>rd</sup> Floor, Vijay Krishna Plaza, No.1, Lake Area, Melur Main Road, Mattuthavani, Madurai-625 107



**BHARATMALA**  
ROAD TO PROSPERITY

NHAI/15018/4.4.3/2019/RO Madurai/E:121599/2607

20<sup>th</sup> December, 2021

### INVITATION OF PUBLIC COMMENTS

**Sub:** NHAI, Madurai Region - Highway Administration - Permission for laying of water Pipe line under PIU, Thanjavur - laying Water pipe line by M/s. EE, TWAD Board, RWD Division, Cuddalore Along the Road at from Km.49+700 to Km50+900 (LHS); Km 52+000 to Km.54+800(RHS) and Across the road at Km.50+400; Km.54+450 & Km.54+650 by open trench & HDD method in Vikravandi - Sethiyathope section of NH-45C in the state of Tamilnadu- Invitation of Public Comments - Reg.

The Proposal is regarding permission for laying of water supply pipeline from

- i. Along the road
  1. Km.49+700 to Km50+900 (LHS);
  2. Km 52+000 to Km.54+800(RHS)
- ii. Across the road
  1. Km.50+400;
  2. Km.52+100;
  3. Km.54+450;
  4. Km.54+650

on Vikravandi to Sethiyathope section of NH 45C M/s.EE, TWAD Board, RWD Division, Cuddalore.

2) EE, TWAD Board, RWD Division, Cuddalore has proposed to lay the Water supply pipeline for a length of 4000 m along the edge of the ROW, which is at a distance of 1.5zm from centerline of the project and across the project at 4 locations at a depth of 1.5m below ground level. The proposal is in conformity with Ministry's guidelines vide letter No. NHIII/P/66/76 dated 19.11.1976.

3) Further EE, TWAD Board, RWD Division, Cuddalore has mentioned that the Water supply pipeline along the NH by Open Trench Method at a depth of 1.00m for along portion and by HDD at a depth of 1.5m for across portion.

4) EE, TWAD Board, RWD Division, Cuddalore has furnished an undertaking to the effect that the applicant will remove the laid Water supply pipeline in future if required by NHAI/MoRTH, Govt. of India at any time for expansion of the NH at their own cost without claiming any compensation. Further, mentioned that EE, TWAD Board, RWD Divison, Cuddalore will also restore the surfaces to its original condition soon after removal of the Water supply pipelines.

5) As per the guidelines issued by the Ministry vide letter No.RW/NH33044/29/2015/ S&R(R) dated 22.11.2016 the proposal submitted by the applicant will be made available for public comments and the comments is invited within 30 days from the day of uploading. In view of the above, comments of the public on the above proposal is invited to the below mentioned address:

The Regional Officer,  
National Highways Authority of India,  
No.2nd & 3rd Floor, Vijay Krishna Plaza,  
No.1, Lake Area, Melur Main Road, Mattuthavani,  
Madurai - 625 007.

Yours Faithfully,

**Encl:** As Above.

**(MS Chaithanya),  
Manager (Tech.,)**

**Copy to:**

1. The NIC, New Delhi - for uploading in the Ministry's website.
2. The PD, Thanjavur - for information.