



भारतीय राष्ट्रीय राजमार्ग प्राधिकरण
(सड़क परिवहन और राजमार्ग मंत्रालय, भारत सरकार)
National Highways Authority of India
(Ministry of Road Transport & Highways, Government of India)
क्षेत्रीय कार्यालय, मदुरै / Regional Office, Madurai

दूसरा व तीसरी तल, विजय कृष्ण प्लाजा, संख्या-1, लेक एरिया, मेलूर मेन रोड, माट्टुतावनी, मदुरै-625 007
2nd & 3rd Floor, Vijay Krishna Plaza, No.1, Lake Area, Melur Main Road, Mattuthavani, Madurai-625 107
दूरभाष/ Tele : +91-452-258 8999 वेब /Website : www.nhai.gov.in ई-मेल/ E-mail : romadurai@nhai.org



NHAI/15018/3.7/03/2022/RO-Madurai/E-157243/2709 28th November, 2022

INVITATION OF PUBLIC COMMENTS

Sub: NHAI - Madurai Region - PIU-Tuticorin - Madurai - Aruppukottai section of NH 45B - Permission for Erection of 230KV SC Overhead Transmission line Crossing at Km.229+700 Proposal submitted by M/s. JSW Future Energy Limited, Mumbai - In-Principle Approval Requested - Public Comments Invited - Reg.

The proposal received from PD, PIU-Tuticorin vide letter NHAI/PIU/TUTY/NH-45B/2022/934 dated 02.08.2022 thereby requesting Permission for Erection of 230KV SC Overhead Transmission line Crossing at Km.229+700 in Madurai - Aruppukottai section of NH 45B in the State of Tamil Nadu proposed by M/s. JSW Future Energy Limited, Mumbai vide letter dated 05.03.2022.

2) The alignment proposed by M/s. JSW Future Energy Limited, Mumbai requesting Permission for Erection of 230KV SC Overhead Transmission line Crossing at Km.229+700 in Madurai - Aruppukottai section of NH 45B in the State of Tamil Nadu as detailed under;

Stretch in Km	Length in Meters	Remarks
Across NH-45B: At Km 229+700	60	Laying of 230KV SC line on DC tower with AL 59 Zebra conductor & OPGW Cable

3) As mentioned in the checklist, the ROW is 60 m at Km 229/700 i.e. 30 m on LHS and 30 m on RHS from the Centerline. As observed from the drawing, the Overhead tower are to be erected across NH at Km 229+700.

4) In this instant proposal, the as certified by PD, Tuticorin Vertical Clearance for the proposed erection overhead electrical 230KV SC overhead Transmission line is 24.2 m.

5) M/s. JSW Future Energy Limited, Mumbai has furnished necessary undertaking to the effect that they will relocate the Over Head Transmission line and when requested by the NHAI at their own cost. It is also mentioned that, the proposed erection work of 230KV SC Over Head Transmission line across NH will not

नेहरू जी

NHAI/15018/3.7/03/2022/RO-Madurai/E-157243/2709 28th November, 2022

cause damage to any other utility, if damaged they will pay the losses either to NHAI or to the concerned agency as per Ministry Guidelines dated 22.11.2016.

6) Accordingly, As per the MoRTH guidelines vide letter No. RW/NH-33044/29/2015/S&R(R) dated 22.11.2016. The application is being uploaded on public domain for 30 days for seeking claims and objections (on grounds of public inconvenience, safety and general public interest).

In view of the above, comments of the public on the above proposal is invited to the below mentioned address:

The Regional Officer,
National Highways Authority of India,
No. 3rd Floor, Vijay Krishna Plaza,
No.1, Lake Area, Melur Main Road, Mattuthavani,
Madurai - 625 007.

This is issued with approval of Regional Officer-Madurai.


(Mahendra Meena)
Dy. Manager (Tech)

Copy to:

1. The NIC, New Delhi - for uploading in the Ministry's website.
2. The PD, Trichy - for information.