



भारतीय राष्ट्रीय राजमार्ग प्राधिकरण

(सड़क परिवहन एवं राजमार्ग मंत्रालय, भारत सरकार)

National Highways Authority of India

(Ministry of Road Transport & Highways, Govt. of India)

क्षेत्रीय कार्यालय : "नारंग टावर", पहली मंजिल, उपआयुक्त यातायात पुलिस (नागपुर शहर) कार्यालय के सामने, पाम रोड, सिविल लाईन्स नागपुर-440 001 महाराष्ट्र
Regional Office : "Narang Towers", 1st Floor, Opp. to Office of Dy. Commissioner of Police Traffic (Nagpur City), Palm Road, Civil Lines, Nagpur- 440 001 Maharashtra

Tel/Fax : 0712-2520091, 0712-2980554 ई-मेल / Email : ronagpur@nhai.org



भारतमाला
प्रगति के पथ पर अग्रसर

NHAI/RO-NAG/UEC/NH-361/Suenebs-Km.14.815/2020/ 2844

Date: 27.01.2020

Invitation of Public Comments

Sub: Proposal for grant of NOC for laying / crossing of 33 KV overhead line across NH-361 at Km.14.815 from Tuljapur City in Internal Lane from Lohara PSS of M/s. Siemens Gamesa Renewable Private Limited Cehnnai Line from wind farm – Reg.

Ref.: (i) PD, PIU, Nanded Lr.No.NHAI/PIU/NED/NH361/NOC-SIEMENS/DLBL TAHL/LION/2019/31, dtd.04.01.2020
(ii) M/s. Siemens Games Renewable Energy Lr.No.SG/MH/PD/108/2019-20, dated 01.10.2019

It is to inform all concern that the M/s. Siemens Gamesa Renewable Energy, Chennai vide letter under reference (ii) has submitted a proposal for the subjected work and PD, NHAI, PIU, Nanded has recommended the above proposal vide letter under reference (i) for approval of the Competent Authority / Highway Administrator.

2. The alignment proposed by that the M/s. Siemens Gamesa Renewable Energy, Chennai across Tuljapur- AUSA Section of NH-361 in the State of Maharashtra is as follows:

- Crossing 33 KV Overhead line is at Km.14.815 from Tuljapur City
- The Tower on LHS and RHS are located at a distance of 45m and 41m respectively from PCL of Highway.
- The locations of Tower comes out of Building line i.e. 40m on each side.
- The Tower Height 12.96m, proposed to be installed beyond ROW.
- The vertical clearance from RTL is 11.60m

3. As per Para-4 of Ministry's Circular No.RW/NH-33044/29/2015/S&R(R), dated 22.11.2016, the Highway Administration shall be put out in the public domain for 30 days for seeking claims and objections (on grounds of public inconvenience, safety and general public interest).

4. In view of the above, the comments / objections of affected public is hereby invited with reference to the Ministry's circular dated 22.11.2016 due to crossing of 33KV Overhead line on the subjected stretch. The objections / comments may be addressed to the below mentioned address upto 26.02.2020, beyond due date, no comments/ objections will be accepted.

Contd...2

The Regional Officer,
Regional Office - Nagpur
National Highways Authority of India,
"Narang Towers", 3rd Floor,
Opp.to Office of Dy. Commissioner of Police Traffic (Nagpur City),
Palm Road, Civil Lines, Nagpur-440 001, Maharashtra
Tel : 0712-2520091
Email : ronagpur@nhai.org

This is issued with the approval of the Regional Officer, RO, Nagpur

(Signature)
27/01/2020

(Arun P. Sarodaya)

Dy. General Manager (Tech.)
NHAI, RO, Nagpur

- Copy to : (i) Web Admn., NHAI, HQ, New Delhi - for uploading in NHAI's website
[web-admin@nhai.org]
(ii) Director, NIC, New Delhi - for uploading in Ministry's website
[mansoor@nic.in]