




भारतीय राष्ट्रीय राजमार्ग प्राधिकरण
(सड़क परिवहन एवं राजमार्ग मंत्रालय, भारत सरकार)
National Highways Authority of India
(Ministry of Road Transport and Highways Govt. of India)
परियोजना कार्यान्वयन इकाई—औरंगाबाद (बिहार)
Project Implementation Unit – Aurangabad (Bihar)



Email: piuaurangabad@nhai.org
Ph: 06186-467974

प्लॉट सं०-211, वार्ड सं०-4, क्षत्रिय नगर, आर्यन पब्लिक स्कूल (शिव मंदिर) के नजदीक, रा0रा0-19, औरंगाबाद, (बिहार) – 824101
Plot No. – 211, Ward No.- 4, Kshatriya Nagar, Near Aryan Public School (Shiv Temple), NH-19, Aurangabad, (Bihar)-824101

Ref: NHAI/PIU-Aurangabad/Aur-Cho/NH-19/Pkg-2/Permission/2024/837

July 03, 2024

Invitation of Public Comments

Sub: - Proposal for NH-19 (AH-1) crossing of 132 KV D/C GSS Chandauti to Barachatti Transmission Line in between Dobhi & Barachatti at road Chaniage 232.233 – reg.

The Electrical Executive Engineer, M/s Bihar State Power Transmission Company Limited, Transmission Division, Gaya vide letter no 407 dated 11.04.2023 has submitted the aforesaid proposal for permission for NH-19 (AH-1) crossing of 132 KV D/C GSS Chandauti to Barachatti Transmission Line in between Dobhi & Barachatti at road Chaniage 232.233 in Gaya District.

2. From the submitted proposal, it is seen that as per checklist the crossing of 132 KV D/C GSS Chandauti to Barachatti Transmission line is proposed along the road between Dobhi & Barachatti at road Chaniage 232.233. Applicant has proposed Methodology for crossing of 132 KV D/C GSS Chandauti to Barachatti Transmission Line with span length has been kept 245.00M, which is sufficient enough to accommodate the proposed six laining of existing carriageway. The proposed ROW for six laining is 60mtr at the crossing location. Also, proposed the vertical clearance shown is submitted drawing is 15.495M between conductor and road surface across highway, which is more than 11.60M as per prescribed limit.

3. As per the guidelines issued by the Ministry vide OM No. RW/NH-33044/29/2015/S&R® dated 22.11.2016, the application is to be put out in the public domain for 30 days for seeking claims and objections (on grounds of public inconvenience, safety and general public interest).

In view of the above, comments of the public on the above application is invited to the below mentioned address, which should reach by this office within 30 days from the date of issue beyond which no comment shall be entertained.

Yours Faithfully,

Ah
03/07/24
(Amit Kumar Ojha)
Project Director

Sne

Copy to: (i) Regional Officer (Bihar), Patna for kind information please
(ii) Web Admin, NHAI, HQ-With a request for uploading on the NHAI website.
(iii) The Technical Director NIC, Transport Bhawan New Delhi with a request for Uploading on Ministry's website.
(iv) The Executive Engineer, Transmission Division, M/s BSPTCL, Const, Gaya for kind information.