



भारतीय राष्ट्रीय राजमार्ग प्राधिकरण

(सड़क परिवहन और राजमार्ग मंत्रालय, भारत सरकार)

National Highways Authority of India

(Ministry of Road Transport and Highways, Government of India)

श्रेणीय कार्यालय : 41-29-45A, सर्वे नं: 373/2A, कोदंडरामालयम्, चलासानी नगर,

रानीगारीतोटा, कृष्णालंका, विजयावाडा - 520 013, आन्ध्र प्रदेश

Regional Office : D.No. 41-29-45A, RS.No. : 373/2A, Kodandaramalayam, Chalasani Nagar,

Ranigari Thota, Krishna Lanka, Vijayawada - 520 013, Andhra Pradesh.

फोन / Tel : 0866-2483910, ई-मेल/e-mail: rovijayawada@nhai.org, nhairovja@gmail.com

वेब/ web: www.nhai.gov.in



Lr.No. NHAI/RO-VJA/PIU-VJA/NH-65/V-N/NOC/2025/ 737

Dt.11.03.2025

To

The Sr. Technical Director,
NIC, Transport Bhawan,
New Delhi- 110001.

Sub: Permission for providing and laying of Utility Pipeline across NH-65 at Km.262+624 from RHS to LHS and along NH from Km.262+583 to 262+624 RHS for a total length of 80m on Vijayawada - Nandigama section of NH-65(Old NH-09) at Guntupalli Village, Ibrahimpatnam Mandal of NTR District, Andhra Pradesh - **Public comments** - Reg.

Sir,

Please find enclosed herewith a proposal submitted by M/s.Guntupalli Panchayat, Executive Officer for providing and laying of Utility Pipeline across NH-65 at Km.262+624 from RHS to LHS and along NH from Km.262+583 to 262+624 RHS for a total length of 80m on Vijayawada - Nandigama section of NH-65(Old NH-09) at Guntupalli Village, Ibrahimpatnam Mandal of NTR District, Andhra Pradesh.

2. As per MORTH guidelines vide letter No. RW/NH-33044/29/2015/S&R(R) dated 22nd November 2016, the application along with the recommendations of PD, PIU-Vijayawada & notice inviting public comments are enclosed herewith with a request to host the same in the Ministry's website for 30 days seeking claims and objections (on grounds of public inconvenience, safety and general public interest), for taking further necessary action.

Yours faithfully,

(R.K. Singh, IES),
CGM (Tech.) & Regional Officer

Encl: As above

Copy to:

- (i) PD, PIU - Vijayawada
- (ii) Executive Officer, M/s. Guntupalli Panchayat



भारतीय राष्ट्रीय राजमार्ग प्राधिकरण

(सड़क परिवहन और राजमार्ग मंत्रालय, भारत सरकार)

National Highways Authority of India

(Ministry of Road Transport and Highways, Government of India)

श्रेणीय कार्यालय : 41-29-45A, सर्वे नं: 373/2A, कोदंडरामालयम्, चलासानी नगर,

रानीगारीतोटा, कृष्णलंका, विजयावाडा - 520 013, आन्ध्र प्रदेश

Regional Office : D.No. 41-29-45A, RS.No. : 373/2A, Kodandaramalayam, Chalasani Nagar,

Ranigari Thota, Krishna Lanka, Vijayawada - 520 013, Andhra Pradesh.

फोन / Tel : 0866-2483910, ई-मेल/e-mail: rovijayawada@nhai.org, nhairovja@gmail.com

Lr.No. NHAI/RO-VJA/PIU-VJA/NH-65/VN/NOC/2025/738

Dt.11.03.2025



INVITATION OF PUBLIC COMMENTS

Sub: Permission for providing and laying of Utility Pipeline across NH-65 at Km.262+624 from RHS to LHS and along NH from Km.262+583 to 262+624 RHS for a total length of 80m on Vijayawada - Nandigama section of NH-65(Old NH-09) at Guntupalli Village, Ibrahimpatnam Mandal of NTR District, Andhra Pradesh - **Public comments - Reg.**

The Project Director, PIU - Vijayawada, submitted a proposal of M/s. Guntupalli Panchayat, Executive Officer for providing and laying of Utility Pipeline across NH-65 at Km.262+624 from RHS to LHS and along NH from Km.262+583 to 262+624 RHS for a total length of 80m on Vijayawada - Nandigama section of NH-65(Old NH-09) at Guntupalli Village, Ibrahimpatnam Mandal of NTR District, Andhra Pradesh.

As per MORTH guidelines vide letter No. RW/NH-33044/29/2015/S&R(R) dated 22nd November 2016, the Highway Administration will put out the application in the Ministry's website for 30 days seeking claims and objections (on grounds of public inconvenience, safety and general public interest).

In view of the above, the comments of public, if any, on the above mentioned proposal is invited on below mentioned address.

Regional Officer - Vijayawada,
National Highways Authority of India,
Regional Office, Dr. No.41-29-45A, R. S. No.373/2A
Near Kodandaramalayam, Chalasani Nagar,
Ranigarithota, Krishnalanka, Vijayawada - 520 013.
Email: rovijayawada@nhai.org

(R.K. Singh, IES),
CGM (Tech.) & Regional Officer



भारतीय राष्ट्रीय राजमार्ग प्राधिकरण
(सड़क परिवहन और राजमार्ग मंत्रालय)
National Highways Authority of India
(Ministry of Road Transport & Highways)



परियोजना कार्यान्वयन ईकाई

Project Implementation Unit

प्लॉट नं:74, वनमाली भवन, एन.ए.सि. कल्याणा वेदिका के बगल में,
कमर्शियल टैक्सेज कॉलोनी, गुरुनानक नगर रोड, विजयवाड़ा-520 008.

Plot No. 74, Vanamali Building, Beside N.A.C. Kalyana Vedika, Commercial Taxes Colony,
Gurunanak Nagar Road, Vijayawada-520 008.

दूरभाष / Phone : 0866 - 2543496, ई-मेल / E-mail : vij@nhai.org, nhaipiuvi@gmail.com

Ref:11070-GP/PIU/V/NHAI/2025/1918

Dt:21.02.2025

To
The CGM(T) &Regional Officer,
National Highways Authority of India
Regional Office, Vijayawada
Door No.41-29-45A, R.S.No.373/2A
Near Kodandaramalayam
Chalasani Nagar, Ranigarithota
Krishnalanka
Vijayawada - 520 013

Sir,

UPC:N/04007/15001/AP - RCW

Sub : NHAI, PIU, Vijayawada - Permission for providing and laying of Utility Pipeline across NH-65 at Km.262+624 from RHS to LHS and along NH from Km.262+6583 to 262+624 RHS on Vijayawada - Nandigama section of NH-65(Old NH-09) at Guntupalli Village, Ibrahimpatnam Mandal of NTR District, Andhra Pradesh-Request for Provisional Approval- Reg.

Ref:

- 1) M/s Guntupalli Panchayat, letter No. GUNTUPALLI/NH-65/RWS dated 19.12.2024.
- 2) T/o, email dt.21.12.2024.
- 3) Independent Engineer, M/s.Theme Engineering Services Pvt. Ltd., Lr.No.TES/TL/PIU/NH-65/STPL/2425/38 dt.24.01.2025.

It is to submit that M/s. Guntupalli Panchayat, Executive Officer vide reference 1st cited has requested to issue permission for laying of utility pipeline of 150mm dia HDPE drinking water purpose across Project Highway at Km.262+624 & along Project Highway from Km.262+583 to Km.262+624 on RHS respectively of Vijayawada - Nandigama section of NH-65 by using HDD method (Horizontal Directional Drilling).

2. In this regard, the IE, M/s Theme Engineering Services Pvt. Ltd, has reviewed the proposal and submitted vide reference 3rd cited that the checklist, drawings are found in order as per the MoRT&H guidelines Lr.no. RW/NH-33044/29/2015/S&R(R) dated 22.11.2016. The proposal of the agency and the comments/recommendations of IE have been examined in line with the MoRT&H Guidelines and the following are submitted.

- I) The applicant has submitted Checklist, Drawings and other relevant documents as per NHAI guidelines.

- II) The applicant has submitted all relevant undertakings such as:
- a. Submission of Bank Guarantee for laying of pipeline along the Highway for a period of one year.
 - b. Not to damage to other utility, if damaged then to pay the losses either to NHAI or to the concerned agency.
 - c. To renew bank guarantee as and when asked by MORTH/NHAI.
 - d. To confirm all standard conditions of Ministry circular and NHAI's guidelines.
 - e. Indemnity against all damages and claims.
 - f. For Management of traffic movement during laying of pipeline without hampering the traffic.
 - g. If any claim is raised by the Concessionaire/ Contractor then the same will be paid by applicant.
 - h. Prior approval of NHAI shall be obtained before undertaking of any work of installation, shifting or repairs, or alterations of the water pipe lines located in the National Highway right of way.
 - i. Expenditure, if any, incurred by NHAI for repairing any damages caused to the National Highway by the laying, maintenance or shifting of the pipe line will be borne by the agency owning the utility line.
 - j. If the NHAI considers, if necessary, in future to move the utility line for any work of improvement or repairs to the road, it will be carried out as desired by NHAI at the cost of the agency owning the utility line within a reasonable time(not exceeding 40 days) of the intimation given.
 - k. Draft license Agreement regarding granting of Right of way permissions for laying utility services on National Highways.
- III) As per the plan submitted, the applicant has proposed for laying of 150mm dia HDPE water pipeline from Km.262+583 to Km.262+624 on RHS and crossing at Km.262+624 for a length of 41m& crossing of 39m along the Main Carriageway within the utility corridor with HDD & Open Trench method.
- IV) Applicant submitted the typical cross sections for Open Trench along with methodology.

3. While submitting the above, IE recommended the proposal of Executive Officer, Guntupalli Panchayat, Gollapudi, Vijayawada, requesting for approval of Competent Authority for laying water pipeline as requested by the applicant.

4. The request of the applicant has been examined and it is observed that the applicant has proposed to lay 150mm Dia HDPE water supply pipe line from Km.262+583 to Km.262+624 RHS on Vijayawada - Nandigama section of NH-65 by Open Trench/HDD method.

5. The applicant has submitted calculation of license fee for an amount of Rs. 56,371/-. The Independent Engineer has calculated & revised the license fee to an amount of Rs.65,475/- (as per amendments made to clause 5& 5.2 vide MoRT&H circulars No. 36094/01/2022-S&R (P&B)Dt: 17.04.2023 to MoRTH Circular No. RW/NH-33044/29/2015/S&R(R) Dt:23.11.2016(Public Cutility). Hence the same may be considered.

6. The applicant has submitted the calculation of performance bank guarantee for Rs. 4,387.50/-. The Independent Engineer has calculated & verified the Performance Bank Guarantee for an amount of Rs. 17,950/- as per amendments made to clause & MoRTH Circular No. RW/NH-33044/29/2015/S&R(R) Dt:23.11.2016. Hence the same may be considered.

7. Further, PIU vide reference 2nd cited requested Concessionaire, M/s. STPL to offer comments/ objections, if any on the above proposal.

8. The proposal of laying of water pipeline has been examined in this office along with the comments of IE and found to be in line with guidelines issued vide MoRTH Circular dated 22.11.2016.

In light of the above, the proposal along with the copies of all the above mentioned documents are herewith submitted with a request to communicate the approval of the Competent Authority for laying of water supply pipeline of 150mm dia HDPE from Km.262+583 to Km.262+624 RHS for a length of 41m& crossing of 39m on Vijayawada- Nandigama section of NH-65 in the state of Andhra Pradesh.

Encl : As above.

Yours faithfully,


(Latha Kodem)

DGM (Tech.) & Project Director
NHAI, PIU-Vijayawada

INSPECTION REPORT

Sub: Permission for providing and laying of Utility Pipeline across NH-65 at Km.262+624 from RHS to LHS and along NH from Km.262+6583 to 262+624 RHS on Vijayawada - Nandigama section of NH-65(Old NH-09) at Guntupalli Village, Ibrahimpatnam Mandal of NTR District, Andhra Pradesh.

The access permission location was inspected by me and details are certified as below:

- i) The width of RoW from Km.262+583 to Km.262+624 is 24m towards RHS and 15m towards LHS from center line of Highway.
- ii) The Proposed Pits for HDD method (Horizontal Directional Drilling method) are not falling under National Highway ROW.
- iii) The Proposed pipeline of 150mm water supply pipeline will not disturb the Existing Crust of National Highway at the above said locations as the pipe will be laid at a depth of 1.5m below ground level.



(Latha Kodem)

DGM (Tech.) & Project Director
NHAI, PIU-Vijayawada

CERTIFICATE

1. It is certified that all Standard Conditions specified in the proposal from M/s Guntupalli Panchayat for laying of pipe line 150mm dia HDPE water pipeline from Km.262+583 to Km.262+624(RHS) & crossing at Km.262+624 (RHS to LHS) on Vijayawada - Nandigama section of NH-65 in the State of Andhra Pradesh is in conformity as per MoRT&H guidelines vide Lr.no. RW/NH-33044/29/2015/S&R(R) dated 22.11.2016.
2. It is to certify that upon receipt of approval for the above proposal, the same will be entered in the Register of Records of the Permissions in the prescribed proforma.


(Latha Kodem)
DGM (Tech.) & Project Director
NHAI, PIU-Vijayawada