



भारतीय राष्ट्रीय राजमार्ग प्राधिकरण

(सड़क परिवहन और राजमार्ग मंत्रालय, भारत सरकार)

National Highways Authority of India

(Ministry of Road Transport & Highways, Government of India)

प.क.ई. अलीगढ़, ग्राम भीकपुर, एन.एच.-34 के 132.400 किमी० आर०एच०एस०
अलीगढ़ बाईपास, अलीगढ़-202001 (उ०प्र०)

PIU Aligarh, Village Bhikampur, At Km. 132.400 RHS on NH-34,
Aligarh Bypass, Aligarh - 202001 (U.P.)

Email: aligarh@nhai.org, nhaipiubsr001@gmail.com



NHAI/PIU-ALG/44016/GAP/2025/D- 24005

29.03.2025

Invitation of Public Comments

Sub: Proposal for permission of laying 11KV HT line from Km. 141+200 to Km. 141+610 (Mathura Road) (BHS) including 01 no. UG road crossing at Km. 141+200 on NH-34 (Ghaziabad - Aligarh Section) in District Aligarh in the State of Uttar Pradesh.

Executive Engineer, EUCD-1, DVVNL Aligarh submitted the proposal for permission of laying laying 11KV HT line from Km. 141+200 to Km. 141+610 (Mathura Road) (BHS) including 01 no. UG road crossing at Km. 141+200 on NH-34 (Ghaziabad - Aligarh Section) in District Aligarh in the State of Uttar Pradesh.

2. From the submitted proposal, it is seen that the proposed underground laying length is 820m and crossing length is 60m. As per the guidelines, issued by the Ministry vide OM No.RW/NH-33044/29/2015/ S&R(R) dated 22.11.2016, the application shall be put out in the public domain for 30 days for seeking claims and objections (on grounds of public inconvenience, safety and general public interest).

3. In view of the above, comments of the public on the above application is invited to the below mentioned address, which should reach by this office within 30 days from the date of publication beyond which no comments shall be entertained.

The Project Director,

National Highways Authority of India

Project Implementation Unit- Aligarh

Village- Bhikampur, At Km. 132.400 (RHS) on NH-34,
Aligarh Bypass, Aligarh -202001 (U.P.)

Encl: As above.

Indresh Kumar
(Indresh Kumar)
Project Director

Copy to:

1. Technical Director, NIC, Transport Bhawan, New Delhi- with request for uploading on the Ministry's website. (Email: mansoor@nic.in)
2. Regional Officer (W-UP), NHAI-Lucknow for kind information.
3. Executive Engineer, EUCD-1, DVVNL Aligarh for information. (Email: xen.urbanaligarh1@dvvn1.org, eeeudd1alg@gmail.com)



कार्यालय अधिशासी अभियन्ता विद्युत नगरीय वाणिज्यिक खण्ड-प्रथम
दक्षिणांचल विद्युत वितरण निगम लिमिटेड,
लाल डिग्गी, अलीगढ़-202001

पत्रांक:

दिनांक 01.03.2025

सेवा में,

परियोजना निदेशक,

भारतीय राष्ट्रीय राजमार्ग प्राधिकरण,

ग्राम-भीकमपुर, किमी0 132.400, रा0रा0-34,

अलीगढ़ बाईपास, अलीगढ़-202001

विषय: वाणिज्यिक टाउनशिप पृथक लाइन हेतु राष्ट्रीय राजमार्ग-34 के किमी0 141.200 (मथुरा रोड़) से किमी0 141.610 (मार्ग के दोनो ओर) मय 01 भूमिगत रोड़ क्रॉसिंग किमी0 141.200 के निर्माण/स्थापन हेतु अनुमति प्रदान करने के सम्बन्ध में।

महोदय,

अवगत कराना है कि मथुरा रोड़ स्थित वाणिज्यिक टाउनशिप हेतु नवीन पृथक 11 के0वी0 विद्युत आपूर्ति लाइन का निर्माण किया जाना प्रस्तावित है। जो कि राष्ट्रीय राजमार्ग-34 के किमी0 141.200 (मथुरा रोड़) से किमी0 141.610 तक (मार्ग के दोनो ओर) मय 01 भूमिगत रोड़ क्रॉसिंग का कार्य किया जाना है।

उक्त कार्य की अनुमति हेतु प्रस्ताव, सड़क परिवहन एवं राजमार्ग मंत्रालय, भारत सरकार के दिशा-निर्देशानुसार तैयार कर प्रस्तुत किया जा रहा है। अतः उपरोक्तानुसार नवीन 11के0वी लाइन निर्माण/स्थापन हेतु अनुमति प्रदान करने का कष्ट करें, जिससे कि उक्त लाइन का निर्माण कार्य यथाशीघ्र प्रारम्भ किया जा सके।

भारतीय राष्ट्रीय राजमार्ग प्राधिकरण
अलीगढ़-अलीगढ़

प्रति सं. 41808

दिनांक 11/03/2025

आपका हेतु अनुमति

प्रस्ताव लाना	✓
लाइन	✓
पूरी करने-11/03	
दिनांक	
स्थान/स्थान	

11/03

11/03

अधिशासी अभियन्ता,
विद्युत नगरीय वाणिज्यिक खण्ड-प्रथम,
द0वि0वि0नि0लि0, लाल डिग्गी,
अलीगढ़

CHECK – LIST

Proposal for permission to erection/laying of separate 11 KV HT line from Ch.141+200 to Ch.141+610 (Mathura Road VUP) (BHS) including 01 no. U/G Road Crossing at Ch.141+200 under Distt.-Aligarh in the State of Uttar Pradesh.

Relevant circulars

- Ministry Circular No. RW/NH/33044/27/2005/S&R(R)(Pt.) dated 07.08.2013.
- Ministry Circular No. RW/NH-33044/29/2015/S&R/(R) dated 22.11.2016.
- Ministry Circular No. 36094/01/2022-S&R(P&B) dated 17.04.2023.

S. No.	Item	Information / Status	Remarks
1	General Information		
1.1	Name and Address of the Applicant	Executive Engineer, EUCD-1, DVVNL, Lal Diggi, Aligarh (U.P.)	
1.2	National Highway Number	NH-91 (New NH-34)	
1.3	State	Uttar Pradesh	
1.4	Location	Near Village- Daultabad	
1.5	(Chainage in Km.)	Ch.141.200 to Ch.141.610 (BHS) Road Crossing at Ch.141.200	
1.6	Length in Meter	880 Meter (O/H=410*2Mtr. & U/G=60Mtr.)	
1.7	Width of available ROW	60 Meter	
1.8	Side of NH (left or right side of NH towards increasing Chainage /KM/ Direction)	Ch.141.200 to 141.610 (LHS), Ch.141.200 to 141.610 (RHS) Road Crossing Ch.141+200	
1.9	Highway Administration Address	Regional Officer, National Highways Authority of India, 3/248, Vishal Khand, Gomti Nagar, Lucknow	
1.10	Proposal to acquire land	N/A	
	(a) Left side from centre line	N/A	
	(b) Right side from Centre line	N/A	
1.11	Whether proposal is in the same side where land is not to be acquired	N/A	
	If not then where to lay the cable	N/A	
1.12	Details of already laid services, if any, along the proposed route	NIL	

अधिरासी अभियाना
विद्युत नगरीय न्यायिक सङ्केत
लाल डिग्गी, अलार्ह

1.13	Number of lanes (2/4/6/8) existing		
1.14	Proposed Number of lanes (2 lane with paved shoulder/4/6/8 lanes)	4/6 lane	
1.15	Service Road existing or not	-	
	If yes then which side	Yes	
	(a) Left side from center line	-	
	(b) Right side from Centre line	No	
1.16	Proposed Service road	Yes	
	(a) Left side from center line	N/A	
	(b) Right side from Centre line	-	
1.17	Whether proposal to lay 11KV electric line is service road and main carriageway.	Edge of ROW (Service road & MCW)	
1.18	The permission of laying of 11KV HT line shall be considered for approval/rejection based on the Ministry Circular mentioned as above	Yes	
	(a) Carrying of Sewage/ electric line on highway bridges shall not be permission as Fumes/ electric line can accelerate the process of corrosion or may cause explosion, thus, being much more injurious than fault of electric line.,	N/A	
	(b) Carrying of electric line on bridge shall not be discouraged. However, if the electric Authorities seem to have no other viable alternative and approach the highway authority will in time before the design of the bridge if finalized, they may be permitted to carry the electric on independent superstructure, supported on extended portions of piers and abutment in such a manner that in the final arrangement enough free spade around the superstructure of the bridge remains available for inspection and repair etc.	N/A	
	(c) Cost of required extension of the sub-structure as well as that of the supporting superstructure shall be borne by the agency-in-charge of the utilities.	N/A	
	(d) Services are not being allowed indiscriminately on the parapet/ any part of bridges, Safety of the bridges has to be kept in view while permitting various service along bridge. Approvals are to be accorded in this regard with the concurrence of the Ministry's	N/A	

अधिसूचना अधिसूचना
विद्युत नगरपालिका विकास बोर्ड-१
ज्वाल विनी, अमीनद

	Project Chief Engineer only.		
1.19	If crossing of the road involved. If yes, it shall be done by HDD method or through structure or conduits specially built for that purpose of the expenses of the agency owning the line.	Yes	
	(a) Existing drainage structure shall not be allowed to carry the lines.	Agreed	
	(b) The utility services shall cross the National Highway preferably on a line normal to it or as nearly show as practicable. DVVN\ shall be permitted to cross the National Highway either through structure or conduits specially built for that purpose. The conduit pipe should, as minimum, extend from drain to drain in cuts and toe of slope to tope of slope in the fills and shall be designed in accordance with the provision of IRC and executed following the Specifications of the Ministry.	Yes	
	(c) The casing pipe may be installed under the route embankment either by boring or digging a trench. Installation by boring method shall prefer.	N/A (HDD method will be used concurring with HDPE pipe of 140mm dia for U/G laying)	
	(d) The casing pipe (or conduit pipe in the case of electric cable) carrying the utility line shall be of steel, cast iron, or reinforced cement concrete and have adequate strength and be large enough to permit ready withdrawal of the carriage pipe/cable.	N/A (HDD method will be used concurring with HDPE pipe of 140mm dia for U/G laying)	
	(e) End of the casing/ conduit pipe shall be sealed from the outside, so that if does not act as a drainage path.	N/A (HDD method will be used concurring with HDPE pipe of 140mm dia for U/G laying)	
	(f) The carrier pipe should, as minimum extend from drain to drain in cuts and toe of slope toe of slope in the fills.	Agreed	
	(g) The top of the carrier pipe/line should be at least 1.2 meter below the surface of the road subject to being at least 0.3 meter below the drain inverts.	Agreed	
	(h) Crossing shall be done by HDD method specially where	Crossing by HDD Method	

अधिकासी अधिसूचना
विद्युत नगरपालिका प्रमुख कार्यालय-१
लाल डिग्री, अस्मिता

	(i) The casing/conduit pipe shall be installed with an even bearing throughout its length and in such a manner as to prevent the formation of waterway along it.	Agreed	
2	Documents / Drawing enclosed with the proposal	Yes, 04 sets of proposal	
2.1	Cross section of trench for open trenching method (is it normal size of 1.2m dept/0.3m wide)	N/A	
	i) Should not be greater than 60cm wider than the outer diameter of the pipe.	N/A	
	ii) Location as closer to the extreme edge of the right-of-way as possible but not less than 15 meter from the center line of the nearest carriageway.	N/A	
	iii) Shall not be permitted to run along the National Highways when the road formation is situated in double cutting. Nor shall these be laid over the existing culverts and bridges.	N/A	
2.2	Cross section showing the size of pit and location of cable for HDD method	Shown in the enclosed drawing.	
2.3	Strip plan/ Route plan showing Water Supply pipe line/ Electrical cable Chainage, width of ROW, distance of proposed cable from the edge of ROW, important mile stone, intersecting cross drainage work etc.	Strip plan/ Drawing enclosed.	
2.4	Methodology for laying of showing electric line etc.	Overhead line/pole & underground electric line work will be done inside the edge of ROW	
2.4.1	Open Trenching method (May be allowed in utility corridor only where perimeter is neither cement concrete type. If yet, Methodology of refilling of trench.	N/A	
	a) The trench width should be at least 30cm, but not more than 60cm wider than the out diameter of the pipe	N/A	
	b) For filling of the trench, Bedding shall be to depth of not less than 30cm it shall consist granular material unsuitable soil and rock edge should be excavated and replaced by selected material.	N/A	

અધિકારી અધિકારી
વિદ્યુત નગરિકા સંસ્થા
ગાંધી ડિમો, ગાંધી

	c) The back shall be completed two stages (1) side fill to the level of the top of the pipe and (ii) overfill to the bottom of the road crust.	N/A	
	d) The side fill shall consist of granular material laid in 15cm layers each consolidated by mechanical tampering and controlled addition of moisture to 95% of the Proctor's Density. Overfill shall be compacted to the same density as the material that had been removed. Consolidation by saturation or ponding will not be permitted.	N/A	
	e) The road crust shall be bolt to the same strength as the existing crust on either side of the trench. Care shall be taken to avoid the formation of a dip at the trench.	N/A	
	f) The excavation shall be protected by flagman, signs and barricades and red-light during night hours.	Agreed	
	g) If required, a diversion shall be constructed at the expenses of agency owning the utility line	Agreed	
2.4.2	Horizontal Directional Drilling (HDD) Method	Yes (for crossing/ parallel XLPE Cable)	
2.4.3	Laying of Electric line through CD work and method of laying	-	
	(a) The utility services shall cross the National Highway preferably on a line normal to it of as nearly so as practicable and subject to all other stipulation contained in this Ministry's guidelines issued on dated 22.11.2016	Yes	
3	Draft License Agreement signed by to witnesses	Enclosed	
4	Performance Bank Guarantee in four of NHAI has to be obtain @ Rs..... per running meter, for period one year initially (extendable if required till satisfactory completion of work) as a security for ensuring/ making good the excavated trench for laying the cable by proper filling and compaction, clearing debris/ loose earth produced due to execution for trenching at least 50 meters away from the edge of the right of way. No payment shall be payable by	Shall be submitted, as demanded by NHAI	

अधिकासी अनियमा
विद्युत नगरिय न्यायिक मण्डल-
कोल डिग्री, अरुमड

	the NHAI to the licensee for clearing debris/ loose earth.		
4.1	Performance BG as per above is to be obtained.		
4.2	Confirmation of BG has been obtained as per NHAI guidelines	Yes	
5	Affidavit/ Undertaking from the Applicant for	Yes	
5.1	Not to Damage to other utility, if damaged then to pay the losses either to NHAI or to the concerned agency.	Yes	
5.2	Renewal of Bank Guarantee	Yes	
5.3	Confirming all standard condition of NHAI guidelines	Yes	
5.4	Shifting of Electric line as and when required by NHAI at their own cost.	Yes, it will be carried out if required	
5.5	Shifting due to widening of NH	Yes	
5.6	Indemnity against all damages and claims Clause (xxiv)	Yes	
5.7	Traffic movement during laying/ erection of electric line to be managed by the applicant.	Yes, the same will be managed at the time of work execution.	
5.8	If any claim raised by the Concessionaire then the same has to be paid by the applicant.	Yes	
5.9	Prior approval of the NHAI shall be obtained before undertaking any work installation, shifting or repairs or alteration to the showing electric line located in the National Highway right-of-way	Yes, Necessary permission to be taken before starting the work.	
5.10	Expenditure, if any, incurred by NHAI for repairing and damage caused to the National Highway by the laying, maintenance or shifting of the electric line will be borne by the agency owning the line.	Yes	
5.11	If the NHAI considers it necessary in future to move the utility line for any work of improvement or repair to the road, it will be carried out as desired by the NHAI at the cost of the agency owning the utility line within a reasonable time (not exceeding 60 days) of the intimation given.	Yes	

अधिकासी अभिप्राय
विद्युत विभाग, दिल्ली
डिप्टी, अवर
[Signature]

5.12	Certificate from the applicant in the following format	-	
	(i) Laying of electric line will not have any deleterious effects on any of the bridge components and roadway safety for traffic.	Yes	
	(ii) for widening – "We do undertake that I will relocate, service road/ approach road/ utilities at my own cost notwithstanding the permission granted with such time as will be stipulated by NHAI" for future widening or any other development.	Yes, it will be certified	
6	Who will sign the agreement	Executive Engineer, EUDD-1, DVVNL, Sasni Gate, Aligarh	
7	Certificate from the Project Director	N/A	
7.1	Certificate for confirming of all standard condition issued vide ministry various circulars	Enclosed	
7.2	Certificate from PD in the following format:	Yes	
	(i) It is certified that any other location of the Electrical line would be extremely difficult and unreasonable costly and the installation of Electric line within Row will not adversely affect the design, stability & traffic safety of the highway nor the likely future improvement such as widening of the carriageway, easing of curve etc.		
	(ii) For 6 – lanning (a) Where feasibility is available "I do certify that there will be no hindrance to 6 laning based on the feasibility report considering proposed structures at the side location". (b) In case feasibility report is not available "I do certify that sufficient ROW is available at site for accommodating proposed six laning".		
8	If NH section proposed to be taken up by NHAI on BOT basis – a Clause is to be inserted in the alignment. "The permitted Highway on which Licensee has been granted the right of lay cable/ duct has also been granted as a right of way to the Concessionaire under the Concession Agreement for up-gradation of		

अधिरासी अभियन्ता
विद्युत नगरपालिका कार्यालय खण्ड-1
लाल डिग्री, अलीगढ़

	Ghaziabad – Aligarh Section and therefore, the licensee shall honour the same".		
9	Who will supervise the work of Erection/UG crossing of 11KV HT line ?	Executive Engineer, EUCD-1, DVVNL, Lal Diggi, Aligarh	
	Who will ensure that the defects in road portion after Erection of 11KV HT line are correct and if not correct then what action shall be taken.		
	Who will pay the claims for damages done/disruption in working of Erection of 11KV HT line, if asked by the Concessionaire.		
	A certificate from PD that he will enter the proposed permission in the register of records of the permission in the prescribed Performa (copy enclosed) issued vide Ministry Circular No. RW/NH-33044/27/2005/S&R (R)(Pt.) dated 07.08.2013.	N/A	
	If any previous approval is accorded for laying of cable then Photocopy of register of records of permissions accorded as maintained by PD (as per Ministry Circular No. RW/NH-33044/27/2005/S&R (R)(Pt.) dated 07.08.2013) as referred in para 13 above in enclosed or not.	N/A	

The ROW of the National Highway available at the proposed location from the centre line of divided carriageway is 30m from edge of ROW towards proposed electric utility.

The above particular along with the drawing and document has been verified and certified as cored as per prevailing site condition.

<p><i>Ganesh</i> Executive Engineer Electricity Urban Commercial Division-1 DVVNL, Lal Diggi, Aligarh (Uttar Pradesh).</p>	<p>Project Director, National Highway Authority of India, PIU-Aligarh</p>
---	--

अधिसारी - डिप्टी
विद्युत नगरीय वाणिज्यिक डिवीजन-1
लाल डिगी, अलीगढ़