



# भारतीय राष्ट्रीय राजमार्ग प्राधिकरण

(सड़क परिवहन एवं राजमार्ग मंत्रालय, भारत सरकार)

## National Highways Authority of India

(Ministry of Road Transport & Highways, Govt. of India)

क्षेत्रीय कार्यालय : "नारंग टावर", तिसरी मंजिल, उपआयुक्त यातायात पुलिस (नागपुर शहर) कार्यालय के सामने, पाम रोड, सिविल लाईन्स नागपुर-४४० ००१ महाराष्ट्र  
Regional Office : "Narang Tower", 3<sup>rd</sup> Floor, Opp. to Office of Dy. Commissioner of Police Traffic (Nagpur City), Palm Road, Civil Lines, Nagpur-440 001 Maharashtra  
Tel/Fax : 0712-2520091, 0712-2980554 ई-मेल/ Email : ronagpur@nhai.org



भारतमाला  
प्रगति के पथ पर अग्रसर

NHAI/RO-NAG/UT-56/NH-53/MSEDCL/2021/ 3115

Date: 01.03.2021

### Invitation of Public Comments

**Sub:** Proposal for grant of permission for laying of 11 KV 300 Sqm 3-CORE XLPE underground HT cable across the NH-53 (old NH-6) at km. 67.100 near Thanegaon Village on Kondhali-Talegaon Section - Reg.

**Ref.:** (i) PD, PIU-Amravati Lr.No.NHAI/PIU/ AMT/K-T/NOC/2020/988, dated 22.10.2020.

(ii) Executive Engineer, MSEDCL O&M Division, Arvi office letter No. 2409 dated 23.09.2020.

\* \* \*

It is to inform all concern that M/s Maharashtra State Electricity Distribution Co. Ltd. vide letter under reference (ii) has submitted a proposal for the subjected work and PD, NHAI, PIU, Amravati has recommended the above proposal vide letter under reference (i) for approval of the Competent Authority / Highway Administrator.

2. The alignment proposed by that M/s Maharashtra State Electricity Distribution Co. Ltd. along on Kondhali - Talegaon section at km 67.100 on NH-53 in the State of Maharashtra as follows:

- Underground 11 KV Cable at km 67.100 on NH-53.
- Alignment of the cable is along Kondhali - Talegaon section on NH-53.
- Cable to be laid in Duct 1.8m below ground level.
- Cable to be laid by HDD method

3. As per Para-4 of Ministry's Circular No.RW/NH-33044/29/2015/S&R(R), dated 22.11.2016, the Highway Administration shall be put out in the public domain for 30 days for seeking claims and objections (on grounds of public inconvenience, safety and general public interest).

4. In view of the above, the comments / objections of affected public is hereby invited with reference to the Ministry's circular dated 22.11.2016 due to above underground line on the subjected stretch. The objections / comments may be addressed to the below mentioned address upto 26.03.2021, beyond due date, no comments/ objections will be accepted.

मुख्यालय : जी-5 एवं 6, सेक्टर-10, द्वारका, नई दिल्ली - 110 075  
Head Office : G-5 & 6, Sector-10, Dwarka, New Delhi - 110 075

**The Regional Officer,**  
Regional Office - Nagpur  
National Highways Authority of India,  
"Narang Towers", 3<sup>rd</sup> Floor,  
Opp.to Office of Dy. Commissioner of Police Traffic (Nagpur City),  
Palm Road, Civil Lines, Nagpur-440 001, Maharashtra  
Tel : 0712-2520091  
Email : ronagpur@nhai.org

*NWadeth*  
01-03-21

( Naresh Wadetwar )  
General Manager (Tech.)  
NHAI, RO, Nagpur

Copy to: (i) Web Admn., NHAI, HQ, New Delhi - for uploading in NHAI's website  
[web-admin@nhai.org]

(ii) Director, NIC, New Delhi - for uploading in Ministry's website  
[mansoor@nic.in]