



भारतीय राष्ट्रीय राजमार्ग प्राधिकरण

(सड़क परिवहन एवं राजमार्ग मंत्रालय, भारत सरकार)

National Highways Authority of India

(Ministry of Road Transport & Highways, Govt. of India)

क्षेत्रीय कार्यालय : "नारंग टावर", पहली मंजिल, उपआयुक्त यातायात पुलिस (नागपुर शहर) कार्यालय के सामने, पाम रोड, सिविल लाईन्स नागपुर-440 001 महाराष्ट्र
Regional Office : "Narang Towers", 1st Floor, Opp. to Office of Dy. Commissioner of Police Traffic (Nagpur City), Palm Road, Civil Lines, Nagpur- 440 001 Maharashtra
Tel/Fax : 0712-2520091, 0712-2980554 ई-मेल / Email : ronagpur@nhai.org



भारतमाला
प्रगति के पथ पर अग्रसर

NHAI/RO-NAG/NH-52/DMC/WSL-Km.233.1-Km.236.3/Ut.40&46/2020/ 364 Date : 10.06.2020

Invitation of Public Comments

Sub: Proposal for permission for laying of Water Supply Lines for Dhule City in the Utility Corridor from Km.233.100 to Km.236.300 on RHS on MP/MH Border to Dhule Section in the State of Maharashtra by the Commissioner, Dhule Municipal Corporation, Dhule

Ref.: (i) Your office Lr.No.NHAI/PIU-Dhule/Water Supply/NH-3/2019-20/321, dated 18.02.2020
(ii) Your office Lr.No.NHAI/PIU-Dhule/NH-3/Water Supply/2019-20/497, dated 18.03.2020
(iii) Your office Lr.No.NHAI/PIU- Dhule/NH-3/Water Supply/2019-20/634, dated 28.05.2020
(iv) The Commissioner, DMC, Dhule letter dated 12.02.2020

* * *

It is to inform all concern that The Commissioner, Dhule Municipal Corporation, Dhule vide letter under reference (iv) has submitted a proposal for the subjected work and PD, NHAI, PIU, Dhule has recommended the above proposal vide letter under reference (i) to (iii) for approval of the Competent Authority / Highway Administrator.

2. The alignment proposed by the Commissioner, Dhule Municipal Corporation, Dhule for laying of Water Supply Lines for Dhule City in the Utility Corridor from Km.233.100 to Km.236.300 on RHS on MP/MH Border to Dhule Section in the State of Maharashtra is as detailed below:

- The laying of WS lines is from Km.233.100 to Km.236.300 on NH-52 on RHS.
- The proposed WS Lines are 965mm dia 10mm thick MS pipe for Pure Water Rising Main with a depth 1.5m above the grounds level on RCC chairs & some part of the line 1.2m below the ground level with RCC incasing.

3. As per Para-4 of Ministry's Circular No.RW/NH-33044/29/2015/S&R(R), dated 22.11.2016, the Highway Administration shall be put out in the public domain for 30 days for seeking claims and objections (on grounds of public inconvenience, safety and general public interest).

4. In view of the above, the comments / objections of affected public is hereby invited with reference to the Ministry's circular dated 22.11.2016 due to laying of underground Optical Fiber Cable on the subjected stretch. The objections / comments may be addressed to the below mentioned address upto 09.07.2020, beyond due date, no comments/ objections will be accepted.

Contd...2

JP

The Regional Officer,
Regional Office - Nagpur
National Highways Authority of India,
"Narang Towers", 3rd Floor,
Opp.to Office of Dy. Commissioner of Police Traffic (Nagpur City),
Palm Road, Civil Lines, Nagpur-440 001, Maharashtra
Tel : 0712-2520091
Email : ronagpur@nhai.org

This is issued with the approval of the Regional Officer, RO, Nagpur

Arun P. Sarodaya
10/06/2020

(Arun P. Sarodaya)
Dy. General Manager (Tech.)
NHAI, RO, Nagpur

Copy to : (i) Web Admn., NHAI, HQ, New Delhi [web-admin@nhai.org] - for uploading in NHAI's website
(ii) Director, NIC, New Delhi [mansoor@nic.in] - for uploading in Ministry's website