



# भारतीय राष्ट्रीय राजमार्ग प्राधिकरण

(सड़क परिवहन एवं राजमार्ग मंत्रालय, भारत सरकार)

## National Highways Authority of India

(Ministry of Road Transport & Highways, Govt. of India)

क्षेत्रीय कार्यालय : "नारंग टावर", पहली मंजिल, उपआयुक्त यातायात पुलिस (नागपुर शहर) कार्यालय के सामने, पाम रोड, सिविल लाईन्स नागपुर-440 001 महाराष्ट्र  
Regional Office : "Narang Towers", 1<sup>st</sup> Floor, Opp. to Office of Dy. Commissioner of Police Traffic (Nagpur City), Palm Road, Civil Lines, Nagpur-440 001 Maharashtra  
Tel/Fax : 0712-2520091, 0712-2980554 ई-मेल/ Email : ronagpur@nhai.org



भारतमाला  
प्रगति के पथ पर अग्रसर

NHAI/RO-NAG/NH-53/DCM/WSL-Km.530-561.850/Ut.47/2020/ 365

Date : 10.06.2020

### Invitation of Public Comments

Sub: Proposal for permission for laying of Water Supply Lines from Km.530.000 to Km.561.500 on RHS, crossing at Km.561.500 and from Km.561.500 to Km.561.850 on LHS on Fagne –Maharashtra / Gujrat Border Section in the State of Maharashtra by the Commissioner, Dhule Municipal Corporation, Dhule

Ref.: (i) Your office Lr.No.NHAI/PIU-Dhule/NH-6/56/Utility Shifting-MJP/519, dated 20.03.2020  
(ii) Your office Lr.No.NHAI/PIU-Dhule/NH-6/Water Supply/2020-21/642, dated 28.05.2020  
(iii) The Commissioner, DMC, Dhule letter dated 11.02.2020

\*\*\*

It is to inform all concern that The Commissioner, Dhule Municipal Corporation, Dhule vide letter under reference (iii) has submitted a proposal for the subjected work and PD, NHAI, PIU, Dhule has recommended the above proposal vide letter under reference (i) to (ii) for approval of the Competent Authority / Highway Administrator.

2. The alignment proposed by the Commissioner, Dhule Municipal Corporation, Dhule for laying of Water Supply Lines from Km.530.000 to Km.561.500 on RHS, crossing at Km.561.500 and from Km.561.500 to Km.561.850 on LHS on Fagne –Maharashtra / Gujrat Border Section is as detailed below:

- The laying of WS lines is from Km.530.000 to Km.561.500 on RHS, crossing at Km.561.500 and from Km.561.500 to Km.561.850 on LHS.
- The proposed WS Lines are 1200 to 900mm dia. DIK-7 Pipe for Pure Water Gravity Main Width-1.800m to 1.50m and Depth – 2.25m to 1.95m, 1422mm dia. MS pipe Raw Water Rising Main across NH at Minor Bridge of Km.561.500 Width – 2.022m, Depth – 2.472m and 1422mm dia MS pipe for Raw Water rising Main Width – 2.022, Depth – 2.472..

3. As per Para-4 of Ministry's Circular No.RW/NH-33044/29/2015/S&R(R), dated 22.11.2016, the Highway Administration shall be put out in the public domain for 30 days for seeking claims and objections (on grounds of public inconvenience, safety and general public interest).


4. In view of the above, the comments / objections of affected public is hereby invited with reference to the Ministry's circular dated 22.11.2016 due to laying of underground Optical Fiber Cable on the subjected stretch. The objections / comments may be addressed to the below mentioned address upto 09.07.2020, beyond due date, no comments/ objections will be accepted.

Contd...2



**The Regional Officer,**  
Regional Office - Nagpur  
National Highways Authority of India,  
"Narang Towers", 3<sup>rd</sup> Floor,  
Opp.to Office of Dy. Commissioner of Police Traffic (Nagpur City),  
Palm Road, Civil Lines, Nagpur-440 001, Maharashtra  
Tel : 0712-2520091  
Email : ronagpur@nhai.org

This is issued with the approval of the Regional Officer, RO, Nagpur

  
10/06/2020

**(Arun P. Sarodaya)**  
Dy. General Manager (Tech.)  
NHAI, RO, Nagpur

Copy to : (i) Web Admn., NHAI, HQ, New Delhi [web-admin@nhai.org] - for uploading in NHAI's website  
(ii) Director, NIC, New Delhi [mansoor@nic.in] - for uploading in Ministry's website