



भारतीय राष्ट्रीय राजमार्ग प्राधिकरण

(सड़क परिवहन और राजमार्ग मंत्रालय, भारत सरकार)

National Highways Authority of India

(Ministry of Road Transport & Highways, Govt of India)

क्षेत्रीय कार्यालय, ओडिशा / Regional Office, Odisha

301 - ए, तीसरी मंजिल, पाल हाईट्स, प्लॉट नं जे/7, जयदेव विहार, भुवनेश्वर - 751013, ओडिशा

301-A, 3rd Floor, Pal Heights, Plot No : J/7, Jayadev Vihar, Bhubaneswar- 751013, Odisha

दूरभाष / Ph.: 0674 - 2361470/ 570/670 (का/ओ)

ई-मेल/e-mail : roodisha@nhai.org, ronhaiodisha@gmail.com, वेबसाइट/Web : www.nhai.gov.in



NHAI/13011/54/RO/OD/1533/2024

31.07.2024

To

The Sr. Technical Director,
NIC Centre at MoRTH,
Transport Bhawan,
New Delhi 110001

Sub: Four laning of Panikoili-Rimuli section of NH-215 from Km.0.000 to Km.163.000 (Design Chainage Km0+000 to Km166+173) in the State of Odisha - Permission / NOC for laying 11 KV Cable (1 no crossing @ 2 runs) near Mahuladiha, Dhenkikote Ch in Km 91+500 on NH-20 -Reg

Ref: PD, PIU- Keonjhar letter No.949 dated 28.06.2024

Sir,

Please find enclosed herewith a proposal of Executive Engineer, Anandapur Electrical Division, TPNODL, Anandpur regarding permission for laying of 11 kV Cable (1 no crossing @2 runs) near Mahuladiha, Dhenkikote Ch in Km 91+500 on NH-20. The details are as under:

Sl. No.	Description	Chainage	Dia of Casing Pipe (in mm)	Remark
1.	Crossing NH	Km.91+500	180	Crossing of XLPE Cable 11 kV Cable 3C x 400 Sqmm near Mahuladiha, Dhenkikote through HDD method

2. Accordingly, as per guidelines issued by MoRTH vide F. No. RW/NH-33044/29/2015/S&R(R) dt. 22.11.2016, the application along with the recommendations of concerned PD/Consultants are enclosed herewith with request to hoist the same in the Ministry's Website for public comments within 30 days of uploading on the website.

This is issued with the approval of the "Regional Officer, NHAI, Regional Office, Odisha, Bhubaneswar.

Yours faithfully,

Abinash
31.07.24

(Abinash Behera)
Dy. Manager (Tech)



भारतीय राष्ट्रीय राजमार्ग प्राधिकरण

(सड़क परिवहन और राजमार्ग मंत्रालय, भारत सरकार)

National Highways Authority of India

(Ministry of Road Transport & Highways, Govt of India)

क्षेत्रीय कार्यालय, ओडिशा / Regional Office, Odisha

301 - ए, तीसरी मंजिल, पाल हाइट्स, प्लॉट नं जे/7, जयदेव विहार, भुवनेश्वर - 751013, ओडिशा

301-A, 3rd Floor, Pal Heights, Plot No : J/7, Jayadev Vihar, Bhubaneswar- 751013, Odisha

दूरभाष / Ph.: 0674 - 2361470/ 570/670 (का/ओ)

ई-मेल/e-mail : roodisha@nhai.org, ronhaiodisha@gmail.com, वेबसाइट/Web : www.nhai.gov.in



NHAI/13011/54/RO/OD/ 1532/2024

31.07.2024

INVITATION OF PUBLIC COMMENTS

Sub: Four laning of Panikoili-Rimuli section of NH-215 from Km.0.000 to Km.163.000 (Design Chainage Km0+000 to Km166+173) in the State of Odisha - Permission / NOC for laying 11 KV Cable (1 no crossing @ 2 runs) near Mahuladiha, Dhenkikote Ch in Km 91+500 on NH-20 -Reg

Executive Engineer, Anandapur Electrical Division, TPNODL, Anandpur has submitted a proposal for laying of 11 kV Cable (1 no crossing @2 runs) near Mahuladiha, Dhenkikote Ch in Km 91+500 on NH-20. The details are as under:

Sl. No.	Description	Chainage	Dia of Casing Pipe (in mm)	Remark
1.	Crossing NH	Km.91+500	180	Crossing of XLPE Cable 11 kV Cable 3C x 400 Sqmm near Mahuladiha, Dhenkikote through HDD method

2. As per guidelines issued by MoRTH vide F. No. RW/NH-33044/29/2015/S&R(R) dated 22.11.2016, the Highway Administration will put out the application in the public domain for 30 days for seeking claims and objections (on grounds of public inconvenience, safety and general public interest).

3. In view of the above, the comments of public, if any, on the above mentioned proposal is invited on below mentioned address:

The Regional Officer,
National Highways Authority of India,
Regional Office, Odisha
301-A, 3rd Floor, Pal Heights,
J/7, Jayadev Vihar, Bhubaneswar 751013, Odisha
e-mail : roodisha@nhai.org

This is issued with the approval of the "Regional Officer, NHAI, Regional Office, Odisha, Bhubaneswar".

31.07.24

(Abinash Behera)
Dy. Manager (Tech)
National Highways Authority of India,
Regional Office, Odisha
301-A, 3rd Floor, Pal Heights,
J/7, Jayadev Vihar, Bhubaneswar 751013

To,
The Project Director,
NHAI, Keonjhar.

Sub: Submission of Check list for getting approval for Crossing of 11kV, 3Cx400sq.mm. underground Electrical Cable Crossing on NH 20 at Mahuladiha,Dhenkikote.

Ref: This Office Letter No- 484(3) Dt.- 09.03.2023

Dear Sir,

With reference to above, we are submitting the check list duly fill up for laying of underground Electrical cable on NH-20 land for information & necessary approval at your end.

CHECK LIST

S.no	ITEM	Information/ Status	Remarks
1	General information		
1.1	Name &Address of the Applicant/Agency	TPNODL AED,Anandapur	
1.2	National Authority number	NH-20 (Old NH-215)	
1.3	State	ODISHA	
1.4	Location	Mahuladiha,Dhenkikote	
1.5	Chainage in km	Road Crossing in UG Cable. 3x400 sq mm (2 Run) <i>CH: 91+800.</i>	
1.6	Length in meters	90	
1.7	Width of available ROW		
	a) Left side from center line towards increasing chainage/km direction	30	
	b) Right side from center line towards increasing chainage/km direction	30	
1.8	Proposal to lay underground electrical cable	No, It is Crossing proposal.	
	a) Left side from center line towards increasing chainage/km direction	40	
	b) Right side from center line towards increasing chainage/km direction	40	
1.9	Proposal to acquire land		
	a)Left side from center line	NA	
	b) Right side from center line	NA	
1.10	Whether proposal is in the same side where land is nor to be acquired	NA	
	If not then where to lay the cable		
1.11	Details of already laid services ,if any along the proposed route	NA	
1.12	Number of lanes existing	4 Lanes	
1.13	Proposed number of lanes(2 lane with paved shoulders	NA	
1.14	Service road existing or not	Yes	
	If yes then which side	NA	
	a)Left side from center line	NA	
	b) Right side from center line	Yes	
1.15	Proposed service road	NA	
	a)Left side from center line	NA	
	b) Right side from center line	NA	
1.16	Whether proposal to lay water supply Pipe line/Electrical Cable is after the service road or between the service road and main carriageway	Cable will laid crossing the main carriageway and service road in HDD/Cashing Method.	

(Signature)
(R)



(Signature)
Manager (Tech.)
NHAI, PIU
Keonjhar

(Signature)
EXECUTIVE ENGINEER
Anandapur Electrical Division
TPNODL, Anandapur

(Signature)
PROJECT DIRECTOR
Project Implementation Unit
Highways Authority of
NHAI

1.17	The permission for laying of water supply pipe line/Electrical cable Shall be considered for approval/rejection based on the Ministry Circulars mentioned as above	Yes Agreed	
	a) Carrying of sewage/gas pipelines on highway bridges shall not be permitted as fumes/gases pipes can accelerate the process of corrosion or may cause explosions thus being much more injurious than leakage of water	Yes Agreed for not carrying electrical Cable in Bridge.	
	b) Carrying of water pipes on bridges shall also be discouraged. However, if the water supply authorities seem to have no other viable alternative and approach the highway authority well in line before the design of the bridge is finalized they may be permitted to carry the pipeline on independent superstructure supported on extended portions of piers and abutments in such a manner that in the final arrangement enough free space around the superstructure of the bridge remains available for inspection and repairs..etc	Yes Agreed for not carrying electrical cable in Bridge but over independent super structure if required at in present of authority.	
	c) Services are not being allowed indiscriminate on the parapet/any part of the bridges. Safety of the bridges has to be kept in view while permitting various services along bridge. Approvals are to be accorded in this regard with the concurrence of the Ministry's Project Chief Engineers only.	Not Applicable	
1.18	If crossing of the road involved If Yes. It shall be either encased in pipes or through structure or conduits specially built for that purpose at the expenses of the agency owning the line.	YES, The Cables will be encased in HDPE pipes with casing pipe of 180mm dia.	
	a) Existing drainage structures not be allowed to carry the line.	YES, The existing structure will not be used to carry the line	
	b) Is it on a line normal NH	YES	
	c) Crossing Shall not be too near the existing structures on the National Highway, the minimum distance being 15 meters. What is the distance from the existing structures	More than 15mtrs	
	d) The casing pipe or conduit pipe in the case of electric cable carrying the utility line shall be of steel, cast iron or reinforced cement concrete and have adequate strength and be large enough to permit ready withdrawal of the carrier pipe/cable.	Casing pipe will be HDPE Pipe of 180 mm dia.	
	e) Ends of the casing/Conduit pipe should be sealed from the outside, so that it does not act as a slope of the fills	Yes, It will be sealed on both side.	
	f) The casting/conduit pipe should be as minimum extend from drain to drain in cuts and toe slope in the fills	Yes, will be followed.	
	g) The top of the casting/conduit pipe should be at least 1.2 meter below the surface of the road subject to being at least 0.3 m below the drain inverts.	From it will be below 7.5 mtr.	
	h) Crossing shall be by boring method(HDD) specially where the existing road pavement is of cement concrete or dense bituminous concrete type.	Yes Crossing by HDD Method	
	i) The casting/conduit pipe shall be installed with an even bearing throughout its length and in such a manner as to prevent the formation of waterway along it.	Yes	
2	Document/Drawing enclosed with the proposal	Yes, 3 sets	

(RE)



Arish
Manager (Tech.)
NHAI, PIU
Keonjhar

Kundh
EXECUTIVE ENGINEER
Anandapur Electrical Division
TPNODL, Anandapur

2.1	Cross section showing the size of trench for open trenching method (Is it normal size of 1.2 m depth/0.3m wide)	NA	
	I) Should not be greater than 60 cm wider than the outer diameter of the pipe.	NA	
	II) Location as closer to the extreme edge of the right- of-way as possible but not less than 15 meter from the center lines of the nearest carriageway.	NA	
	III) Shall not be permitted to run along the National Highways when the road formation is situated in double cutting. Nor shall these be laid over the existing culverts and bridges.	NA	
	IV) These should be so laid that their top is at least 0.6 meter below the ground level so as not to obstruct drainage of the road land.	NA	
2.2	Cross section showing the size of pit and location of cable for HDD method	Shown in the Enclosed drawing.	
2.3	Strip plan/Route plan showing Water supply pipe line/Electrical Cable Chainage, width of ROW, distance of proposed cable from the edge of ROW, important mile stone, intersecting, cross drainage works etc.	As per the Dwg enclosed.	
2.4	Methodology for laying of showing electrical installation etc.	NA	
2.4.1	Open trenching methods (May be allowed in utility corridor only where pavement is neither cement concrete type. If yes, Methodology of refilling of trench.	NA	
	a) The trench width should be at least 30cm, but not more than 60cm wider than the outer diameter of the pipe.	Yes	
	b) For filling of the trench, Bedding shall be to depth of not less than 30cm it shall consist granular material unsuitable soil and rock edge should be excavated and replaced by selected material.	Yes	
	c) The back shall be completed two stages (I) Side-fill to the level of the top of the pipe and (II) overfill to the bottom of the road crust.	Yes agreed to comply	
	d) 95% of the proctors Density. Overfill shall be connected to the same density as the material that had been removed consolidation by saturation or ponding will not be permitted.	Yes agreed to comply	
	e) The road crust shall be built to the same strength as the existing crust on either side of the trench. Care shall be taken to avoid the formation of a clip at the trench.	Yes agreed to comply	
	f) The excavation shall be protected by flagman, signs and barricades and red lights during night hours.	Yes agreed to comply	
	g) If required, a diversion shall be constructed at the expense of agency owning the utility line.	Yes agreed to comply	
2.4.2	Horizontal Directional Drilling (HDD) Method	Cable laying by opentrenching/HDD Method only. As per morth/IRC Guidelines.	
2.4.3	Laying of Water Supply Pipe line/Electrical Cable through CD Works and method of laying.	HDD Method will be adopted.	
	a) On Approaches the water mains/cables shall be carried along a line as close to the right way as possible up to a distance of 30m from the bridge and subject to all other stipulations in this Ministry's guidelines issued with letter no NH-HI/P/66/76 dated 19.11.197	Yes, will be followed.	



Ashtika
Manager (Tech.)
 NHAI, PIU
 Keonjhar

Number - 9
EXECUTIVE ENGINEER
 Anandapur Electrical Division
 TPNODL, Anandapur
PROJECT DIRECTOR
 Highway Implementation
 NHAI

3	Draft license agreement signed by two witnesses.	Enclosed	
4	Performance Bank Guarantee in favour of NHAI submitted @Rs.50/- per running meter (Parallel to NH) and Rs.1,00,000/- per crossing of NH, for a period of one year initially (Extendable if required till satisfactory completion laying the cables /ducts by proper filling and compaction, clearing debris/loose earth produced due to execution trenching at least 50m away from the edge of the right of way. No payment shall be payable by the NHAI to the license of clearing debris/loose earth	Enclosed, Shall be deposit after obtaining permission/advised.	
4.1	Performance BG as per above obtained	In Conformity with NHAI	
4.2	Confirmation of BG has been obtained as per NHAI guidelines.	Yes, agreed for submission.	
5	Affidavit/Undertaking from the applicant for carrying out the work.	Yes, agreed and submitted	
5.1	Not to damage other utility, If damaged then to pay losses either to NHAI or to the concerned agency	Yes , Agreed to comply and submitted undertaking.	
5.2	Renewal of Bank Guarantee.	Yes , Agreed to comply and submitted undertaking.	
5.3	Confirming all standard condition of NHAI guidelines	Yes , Agreed to comply and submitted undertaking.	
5.4	Shifting of water supply pipe line/Electrical cable as and when required.	Yes , Agreed to comply and submitted undertaking.	
5.5	Shifting due to 5 lanning/widening of NH.	Yes , Agreed to comply and submitted undertaking.	
5.6	Indemnity against all damages and claims clause(XXLV)	Yes , Agreed to comply and submitted undertaking.	
5.7	Traffic movement during laying of Water Supply pipe line/Electrical cable to managed by the applicant.	Yes , the same will be managed at the time of work execution.	
5.8	If any claim is raised by the concessionaire then the same has to be paid by the applicant.	Yes , Agreed to comply and submitted undertaking.	
5.9	Prior approval of the NHAI shall be obtained before undertaking any work of installation, shifting or repairs or alternations to the showing water supply pipe line/Electrical cable located in the National Highway right of ways.	Yes ,Necessary permission to be taken before starting the work.	
5.10	Expenditure ,if any incurred by NHAI for repairing and damage caused to the National Highway by the laying maintenance or shifting of the water supply pipe line/Electrical Cable will be borne by the agency owning the line.	Yes , Agreed to comply and submitted undertaking.	
5.11	If the NHAI considers it necessary in future to move the utility line for any work of improvement or repairs to the road, it will be carried out as desired by the NHAI at the agency owning the utility line within a reasonable time (not exceeding 60 days) of the intimation given.	Yes , Agreed to comply and submitted undertaking.	
5.12	Certificate from the applicant in the following format.		
	I) Laying of Electrical cable line will not have any deleterious effects on any of the bridge components and road way safety for traffic.	Yes , Agreed to comply and submitted undertaking.	
	II) For 6 laning we do undertake that I will reincate service road/approach road/utilities at our own cost not standing the permission granted within such time as will be stipulated by NHAI for future six-lanning or any other development.	Yes , It will be certified.	

(R)



Asish
Manager (Tech.)
NHAI, PIU
Keonjhar

M
EXECUTIVE ENGINEER
Anandapur Electrical Division
PINODL, Anandapur
PROJECT DIRECTOR
Project Implementation Unit
National Highways Authority of India

6	Who will sign the agreement	Executive Engineer, TPNODL, Anandpur Electrical Division , ANANDAPUR.	
7	Certificate from the Project Director.	Attached	
7.1	Certificate for confirming of all standard condition issued vide ministry Circular No NH-41(581/68 dated 31.01.4969,Ministry circular no NH-III/P/66/76 dated 18/19.11.1976, Ministry circular no RW/NH-III/P/66/76 dated 11.05.1982' Ministry circular no RW/NH-11037/1/86/DOI dated 19.01.1995, Ministry circular no RW/NH-34066/2/95/S&R dated 25.10.1999 & Ministry circular no RW/NH-34066/7/2003 S&R (B) dated 17.09.2003.	Enclosed	
7.2	Certificate from PD in the following format.		
	I) It is certified that any other location of the electrical cable would be extremely difficult unreasonable costly and the installation of Water Supply pipe line/Electrical Cable within ROW will not adversely affect the design, stability & traffic safety such as widening of the	Enclosed	
	II) For 6-Lanning.	NA	
	a) Where feasibility is available I do certify that there will be no hindrance to proposed six-lanning structures at the said location.		
	b) In case feasibility report is not available I do certify that sufficient ROW is available site for accommodating		
8	If NH section proposed to be taken up by NHAI on BOT basis a clause is to be inserted in the agreement." The permitted Highway on which licensee has been granted the right to pay cable/duct has also been granted as right of way to the concessionaire the concession agreement for up-gradation of... NH no 215 on buide, operate and transfer basis and therefore, the licensee shall honour the same	We will honour NHAI Guidelines.	
9	Who will supervise the work of laying of UG Electrical cable use.	Executive Engineer, TPNODL, Anandpur Electrical Division , ANANDAPUR/IE.	
10	Who will ensure that the defects in road portion after laying of Electrical cable line are corrected and if not corrected then what action will be taken.	Executive Engineer, TPNODL, Anandpur Electrical Division , ANANDAPUR/IE.	
11	Who will pay the claims for damages done/disruption permission in the concessionaire if asked by the concessionaire.	Executive Engineer, TPNODL, Anandpur Electrical Division , ANANDAPUR.	
12	A certificate from PD that he will enter the proposed permission in the register of records of the permissions in the register of the permissions in the prescribed proforma(copy enclosed)	Enclosed.	
13	If any previous approval is accorded for laying of underground water supply pipe line/Electrical Cable then Photocopy of register of records of permissions accorded as maintained by PD then copy be enclosed.	NA	

Thaking you.

Yours Faithfully,

Executive Engineer (Electrical)
AED, Anadapur.
EXECUTIVE ENGINEER
Anandapur Electrical Division
TPNODL, Anandapur

Manager (Tech.)
NHAI, PIU
Keonjhar

PROJECT DIRECTOR
Project Implementation Unit
National Highways Authority of India
KEONJHAR