

No. RO/Chennai/MoRTH/12017/NH-49/PER/049/2023-24

GOVERNMENT OF INDIA

MINISTRY OF ROAD TRANSPORT & HIGHWAYS

Regional Office, Chennai.

C-1-A, Rajaji Bhavan, Besant Nagar, Chennai- 600090.

Email: cerochennaimorth@gmail.com, Tele Off: 24919341.

Dated: 29th February 2024

Invitation of public comments

Subject:- Permission proposal for laying water pipe line along the road from Km 160/484 to Km 162/500 & Km 162/600 to Km 163/400(RHS) and across the road Km 120/400, Km 121/750, Km 123/600 (Pro. Km 123/336), Km 124/650 (Pro. Km 124/386), Km 127/930 (Pro. Km 127/670), Km 134/900 (Pro. Km 134/600) Km 142/100 (Pro. Km 141/650) Km 144/760 (Pro. Km 144/280) Km 152/200(Pro. Km 151/727) of NH-49(New NH-87) (Ramanathapuram-Rameshwaram section) in the state of Tamil Nadu-for a total length 3288m (along the road 2816m & across the road length 472m) - Reg.

The proposal is regarding requesting permission for laying water pipe line along the road from Km 160/484 to Km 162/500 & Km 162/600 to Km 163/400(RHS) and across the road Km 120/400, Km 121/750, Km 123/600 (Pro. Km 123/336), Km 124/650 (Pro. Km 124/386), Km 127/930 (Pro. Km 127/670), Km 134/900 (Pro. Km 134/600) Km 142/100 (Pro. Km 141/650) Km 144/760 (Pro. Km 144/280) Km 152/200(Pro. Km 151/727) of NH-49(New NH-87) (Ramanathapuram-Rameshwaram section) in the state of Tamil Nadu by the Executive Engineer, TWAD Board, Project Division(RCWSS), Ramanathapuram submitted to this office by the SE (NH), Tirunelveli vide letter No.37/2024/JDO-1 dated 11.01.2024(received on 17.01.2024). The proposal has been examined and the details are as under:

Stretch in Km	Length (Km)	ROW (m)	Dist. of Prop. Water pipe line from Centre of NH (m)
by open trench,			
Km 160/484 to Km 162/500 & Km 162/600 to Km 163/400(RHS)	2.816	Varies 16.00m to 61.00m	Varies 11.50m to 39.50m at the extreme edge of the Right of Way
Road Crossing (by HDD method)			
Km 120/400	0.040	40.00m	-
Km 121/750	0.0435	43.50m	-
Km 123/600 (Pro. Km 123/336)	0.060	60.00m	-
Km 124/650 (Pro. Km 124/386)	0.060	60.00m	-
Km 127/930 (Pro. Km 127/670)	0.060	60.00m	-
Km 134/900 (Pro. Km 134/600)	0.045	45.00m	-
Km 142/100 (Pro. Km 141/650)	0.060	60.00m	-
Km 144/760 (Pro. Km 144/280)	0.070	70.00m	-
Km 152/200 (Pro. Km 151/727)	0.045	45.00m	-

2. The proposal has been examined and it is observed in between Km 162/500 to Km 162/600(100m) the laying of pipeline is proposed at 8.50m from the center of road. As reported by PWD, there exists local tank and hence, SE(NH), Tirunelveli request to TWAD board authority to lay pipeline below the tank with the approval of the concerned authority. Since, there is no space from Km 163/400 to 163/700(300m), SE(NH), may also request the applicant to explore possibility of laying the pipeline through alternative road.

Shap
29/02/2024

3. The Right of Way in the stretch of NH proposed for laying Water pipe line is from 16.00m to 61.00m. The carriageway width of stretch from from Km 160/484 to Km 162/500 & Km 162/600 to Km 163/400 of NH 49(New NH 87) is 10.00m. The Executive Engineer, TWAD Board, Project Division(RCWSS), Ramanathapuram has proposed to lay the underground Public Utility at edge of the ROW for a length of 2816m by adopting open trench method along the National Highway and HDD method crosses at Km 120/400,Km 121/750,Km 123/600 (Pro. Km 123/336),Km 124/650 (Pro. Km 124/386),Km 127/930 (Pro. Km 127/670),Km 134/900 (Pro. Km 134/600) Km 142/100 (Pro. Km 141/650) Km 144/760 (Pro. Km 144/280) Km 152/200(Pro. Km 151/727) the National Highway.

4. The Executive Engineer, TWAD Board, Project Division(RCWSS), Ramanathapuram has furnished an undertaking to the effect that they will remove the laid Public Utility water pipe line in future if required by NH Authority/MoRTH, Government of India at any time for expansion of the NH at their own cost without claiming any compensation from NH Authority/MoRTH, Government of India and any right on the NH land. Further, mentioned that, the Executive Engineer, TWAD Board, Project Division(RCWSS), Ramanathapuram will also restore the ROW surfaces to its original condition soon after removal of the Public utility water pipe lines. Also, certified that the proposed Public Utility work will not affect the design, stability, traffic safety and future improvement of the proposed stretch.

5. As per the guidelines issued by the Ministry vide letter No.RW/NH-33044/29/2015/ S&R(R) dated 22.11.2016 the application will be made available for public comments and the comments will be invited within 30 days from the day of uploading the same in the web site of Ministry of Road Transport & Highways for public comments.

6. In view of above, comments of the public on the above proposal is invited for laying water pipeline from Km 160/484 to Km 162/500 and from Km 162/600 to 163/400(RHS) for a length of 2816m to the below mentioned address:

**The Regional Officer, Chennai,
Ministry of Road Transport & Highways,
C-1-A, Rajaji Bhavan, Besant Nagar, Chennai- 600 090
Email: cerochennaiamorth@gmail.com**

Yours Sincerely,


29/02/2024

(Dhanapalan.K)
Executive Engineer
For Regional Officer

To:

1. The NIC, Transport Bhavan, New Delhi - for uploading in the Ministry's website.
2. The Superintending Engineer(NH), Tirunelveli-for information please.
3. The Divisional Engineer (NH),Virudhunagar for information and necessary action.


(Dhanapalan.K)
Executive Engineer
For Regional Officer