



भारतीय राष्ट्रीय राजमार्ग प्राधिकरण
(सड़क परिवहन और राजमार्ग मंत्रालय, भारत सरकार)
National Highways Authority of India
(Ministry of Road Transport & Highways, Govt. of India)



क्षेत्रीय कार्यालय, केरल / Regional Office, Kerala
टी.सी.86/1036-1, अंबली आर्केड, एस एन एन आर ए-9, पेट्टा पी.ओ., तिरुवनंतपुरम - 695 024, केरल
T.C.86/1036-1, Ambly Arcade, S.N.N.R.A-9, Pettah - P.O., Thiruvananthapuram-695 024, Kerala
दूरभाष / Ph : 0471-2460060 ई-मेल / E-mail : rokerala@nhai.org, nhai.ro.tvc@gmail.com, वेब / Web : www.nhai.gov.in

11246/RO-Kerala/Utilitylaying/NH-66/KSEB/SP Medifort/Km.11+380-11+455(RHS)/0228

04.02.2025

MoRTH Application No.20240828/2/15/8819/9698

INVITATION OF PUBLIC COMMENTS

Sub:- NHAI-RO Kerala-Four Laning of Kazhakuttam to Mukkola section (Km.0+000 to Km.26+500) of NH-66 in the State of Kerala under NHDP Phase-III on EPC mode-Laying of 3 Nos. of 200mm dia HDPE pipe and 02 Nos. of 40mm Dia PLB pipe for laying LT Cable, 1.1 KV XLPE AL UG 3.5Cx70 sqmm (Armoured) Cable, 1.1 KV XLPE AL 1Cx35sqmm (Un Armoured) Cable & HT XLPE UG Cable (of sizes upto and incl.3x185sqmm) in Underground Manner by Horizontal Directional Drilling (HDD) from Km.11+380 to Km.11+455 on NH-66 (Thiruvananthapuram Bypass)- Reg

The proposal is regarding permission sought by M/s SP Medifort, Thiruvananthapuram for laying 3 Nos. of 200mm dia HDPE pipe and 02 Nos. of 40mm Dia PLB pipe for laying LT Cable, 1.1 KV XLPE AL UG 3.5Cx70 sqmm (Armoured) Cable, 1.1 KV XLPE AL 1Cx35sqmm (Un Armoured) Cable & HT XLPE UG Cable (of sizes upto and incl.3x185sqmm) in Underground Manner by Horizontal Directional Drilling (HDD) from Km.11+380 to Km.11+455 on NH-66 (Thiruvananthapuram Bypass) in the State of Kerala.

2. M/s SP Medifort, Thiruvananthapuram has furnished undertaking to bear all expenditure, if any, incurred by NHAI for repairing any damage caused to NH by laying, maintenance or shifting of UG cable. Further, the applicant has undertaken to confirm with all standards as mentioned in the Ministry's Circular No. RW/NH33044/29/2015-S&R dated 22.11.2016.

3. Further, M/s SP Medifort, Thiruvananthapuram has undertaken that they will not damage any other utility during the process on laying and in case, if damaged, then to pay the losses either to NHAI or to the agency concerned. M/s SP Medifort, Thiruvananthapuram has also undertaken to manage traffic movement during the execution of the work.

4. As per the guidelines issued by the Ministry vide letter No.RW/NH33044/29/2015/S&R(R) dated 22.11.2016, the proposal submitted by M/s SP Medifort, Thiruvananthapuram will be made available for 30 days seeking public Comments/objections and the comments shall be furnished within 30 days from the day of closure of public objections.

5. In view of the above, comments of public on the above proposal are invited and may be sent to the below mentioned address:-

The Regional Officer
National Highways Authority of India
(Ministry of Road, Transport & Highways)
Ambly Arcade, T.C. 86/1036-1,
S.N.N.R.A-9, Pettah (PO),
Thiruvananthapuram
Kerala-695 024

BABU LAL
MEENA

Digitally signed by BABU
LAL MEENA
Date: 2025.02.04
11:16:09 +05'30'

(B L Meena)

Regional Officer, Kerala

Copy to:

1. NHAI Website
2. The NIC, New Delhi: for uploading in the Ministry's Website
3. The Project Director, NHAI, PIU-Thiruvananthapuram: for information