



भारतीय राष्ट्रीय राजमार्ग प्राधिकरण

(सड़क परिवहन एवं राजमार्ग मंत्रालय, भारत सरकार)

National Highways Authority of India

(Ministry of Road Transport & Highways, Govt. of India)

क्षेत्रीय कार्यालय : "नारंग टावर", पहली मंजिल, उपआयुक्त यातायात पुलिस (नागपुर शहर) कार्यालय के सामने, पाम रोड, सिविल लाईन्स नागपुर-440 001 महाराष्ट्र
Regional Office : "Narang Towers", 1st Floor, Opp. to Office of Dy. Commissioner of Police Traffic (Nagpur City), Palm Road, Civil Lines, Nagpur- 440 001 Maharashtra
Tel/Fax : 0712-2520091, 0712-2980554 ई-मेल / Email : ronagpur@nhai.org



भारतमाला
प्रगति के पथ पर अग्रसर

NHAI/RO-NAG/OFC/NH-44/UG Cable/MSEDCL/Ut-48/2020/537 Date: 27.06.2020

Invitation of Public Comments

Sub: Proposal for grant of permission for laying of 33 KV, 3C x 300 Sq.mm. underground HT cable along NH-44 from Km.738.852 to Km.744.242 (Total 5.390 Km.) and crossing at Km.738.852 (near Pipla underpass Kettle crossing) and at Km.744.242 (near Panjari Underpass Kettle crossing) on NH-44 on MP/MH Border to Nagpur including Kamptee-Kanhan Bypass and Nagpur Bypass in the State of Maharashtra

Ref.: (i) PD, PIU, Nagpur NHAI/PIU1/NGP/NH-44/Bypass/UGC/RO/2019/4250, dated 23.03.2020

(ii) MSEDCL, Congress Nagar Division, Nagpur Lr.No.EE/CNDN/Tech./No.3006, dated 03.07.2019

It is to inform all concern that the Executive Engineer, Maharashtra State Electricity Distribution Company Limited, Congress Nagar Division, Nagpur vide letter under reference (ii) has submitted a proposal for the subjected work and PD, NHAI, PIU, Nagpur-1 has recommended the above proposal vide letter under reference (i) for approval of the Competent Authority / Highway Administrator.

2. The alignment proposed by Executive Engineer, Maharashtra State Electricity Distribution Company Limited, Congress Nagar Division, Nagpur for laying of 33 KV, 3C x 300 Sq.mm. electrical underground HT cable along NH-44 from Km.738.852 to Km.744.242 (Total 5.390 Km.) and crossing at Km.738.852 (near Pipla underpass Kettle crossing) and at Km.744.242 (near Panjari Underpass Kettle crossing) on NH-44 on MP/MH Border to Nagpur including Kamptee-Kanhan Bypass and Nagpur Bypass in the State of Maharashtra is as detailed below:

- (i) The laying of 33kV Electric Cable will be encased in HDPE Pipe 150mm dia 6 Kg press and crossing by HDD or pipe push through only 150mm 6kg thick pressure casing pipe
- (ii) **Along Road** - From Km.738.852 to Km.744.242 - Total Length - 5.390 Km.
- (iii) **Across Road** - at Km.738.852 near Pipla Underpass and at Km.744.242 near Panjari Underpass

3. As per Para-4 of Ministry's Circular No.RW/NH-33044/29/2015/S&R(R), dated 22.11.2016, the Highway Administration shall be put out in the public domain for 30 days for seeking claims and objections (on grounds of public inconvenience, safety and general public interest).

मुख्यालय : जी-5 एवं 6, सेक्टर-10, द्वारका, नई दिल्ली - 110 075
Head Office : G-5 & 6, Sector-10, Dwarka, New Delhi - 110 075

Contd...2

-:2:-

4. In view of the above, the comments / objections of affected public is hereby invited with reference to the Ministry's circular dated 22.11.2016 due to laying of 33 KV, 3C x 300 Sq.mm. electrical underground HT cable on the subjected stretch. The objections / comments may be addressed to the below mentioned address upto 29.07.2020, beyond due date, no comments/ objections will be accepted.

The Regional Officer,
Regional Office - Nagpur
National Highways Authority of India,
"Narang Towers", 3rd Floor,
Opp.to Office of Dy. Commissioner of Police Traffic (Nagpur City),
Palm Road, Civil Lines, Nagpur-440 001, Maharashtra
Tel : 0712-2520091
Email : ronagpur@nhai.org

This is issued with the approval of the Regional Officer, RO, Nagpur

(Signature)
27/6/2020

(Sunil V. Patil)
General Manager (Tech.)
NHAI, RO, Nagpur

To

(i) Web Admn., NHAI, HQ, New Delhi - for uploading in NHAI's website
[web-admin@nhai.org]

(ii) Director, NIC, New Delhi [mansoor@nic.in] - for uploading in Ministry's website