



# भारतीय राष्ट्रीय राजमार्ग प्राधिकरण

(सड़क परिवहन और राजमार्ग मंत्रालय, भारत सरकार)

## National Highways Authority of India

(Ministry of Road Transport and Highways, Government of India)



परियोजना कार्यान्वयन इकाई - कांचीपुरम  
प्लॉट नंबर 20, पहली मंजिल, पल्लवन नगर मेन रोड, मधुरावोयल, चेन्नई-600095  
Project Implementation Unit - Kancheepuram  
Plot No.20, 1st Floor, Pallavan Nagar Main Road, Maduravoyal, Chennai - 600095.  
फ़ोन / Tel. : 91-44- 22 26 22 36 ई-मेल / E-mail : piukanchipuram@nhai.org

NHAI/11040/60/2025/PIU.Kanchee/ 0307

10<sup>th</sup> February, 2025

### Invitation of Public Comments

Sub: NHAI, PIU, Kancheepuram - 6-laning of Karaipettai to Walajahpet section of NH-48 - M/s. Tamilnadu Water Supply and Drainage Board - Providing 2.70 MLD Water supply scheme to SIPCOT, Panapakkam in Ranipet District with river Palar as source at Thiruparkadal under Deposit Work period of completion-12 months Trial run period-6 months and paid Maintenance of the scheme-12 months - Crossing of 600 mm MS Pipeline through Underpass (VUP @ 87+544) at Km. 87+551 - **Invitation of Public Comments - Requested - Reg.**

The proposal is regarding permission for crossing of 600mm MS Pipeline through Underpass (VUP @ Km. 87+544) at Km. 87+551 of NHAI for providing 2.70 MLD Water Supply Scheme to SIPCOT, Panapakkam under Deposit Work by M/s. Tamilnadu Water Supply and Drainage Board.


S. No.	Description	Location	Method
1	Crossing of 600mm MS Pipeline through Underpass (VUP @ Km. 87+544) at Km. 87+551 of NHAI for providing 2.70 MLD Water Supply Scheme to SIPCOT, Panapakkam under Deposit Work by M/s. Tamilnadu Water Supply and Drainage Board	Karaipettai to Walajahpet Section of NH-48 - Crossing at Km. 87+551	The top of the casing / conduit pipe containing the utility services to cross the road shall be at least 1.2m below the top of the sub-grade or the existing ground level whichever is lower subject to being at least 0.3m below the drain inverts.  The crossing of the Pipeline shall be square i.e., it should be normal to the NH by Trenchless Method.

- The applicant M/s. Tamilnadu Water Supply and Drainage Board has furnished an undertaking to relocate UG Cable / Utilities at their cost notwithstanding the permission granted within such time as stipulated by NHAI for future widening or any other development.

*(Signature)*

3. As per the guidelines issued by the Ministry vide Letter No. RW-NH-33044/29/2015-S&R(R), dated 22.11.2016, the proposal submitted by M/s. Tamilnadu Water Supply and Drainage Board will be made available for 30 days seeking public comments / objection and the comments shall be furnished within 30 days from the day of closure of public objections.
4. In view of the above, comments of the public on the above proposal are invited and may be sent to the below mentioned address:

**The Project Director**  
**National Highways Authority of India**  
(Ministry of Road Transport & Highways)  
Project Implementation Unit - Kancheepuram  
No. 20, 1<sup>st</sup> Floor, Pallavan Nagar Main Road,  
Maduravoyal, Chennai - 600 095  
Email: [kancheepurampiu@gmail.com](mailto:kancheepurampiu@gmail.com) / [piukanchipuram@nhai.org](mailto:piukanchipuram@nhai.org)

  
(A. Savithri Devi)  
DGM (T) & Project Director  
PIU, Kancheepuram

**Copy to:**

1. NHAI Website.
2. The NIC, New Delhi for uploading in the Ministry Website.
3. Regional Office, NHAI, Chennai for information.