

भारत सरकार  
सडक परिवहन और राजमार्ग मंत्रालय  
क्षेत्रीय कार्यालय, भुवनेश्वर  
प्लॉट संख्या - 184 (फायर स्टेशन चौक के पास)  
बरमुन्डा, भुवनेश्वर-751003  
दूरभाष : (0674) 2960994 & 2952994  
ई-मेल : robbsr.morth@gmail.com



Government of India  
Ministry of Road Transport & Highways  
Regional Office, Bhubaneswar  
Plot No. - 184 (Near Fire Station Square)  
Baramunda, Bhubaneswar-751003  
Ph. No.: (0674) 2960994 & 2952994  
E-mail: robbsr.morth@gmail.com

No. RO/BBSR/Utility Services/NH-26/JYPR/96/2024 - 1303

Date: 18<sup>th</sup> Sep, 2025

**Invitation of Public Comments**

Sub: Proposal for laying of water pipeline along NH-326 from km 324/800 to 338/000 crossing for Mega PWS to 14 GPs of Boipariguda Block in the district of Koraput in the State of Odisha - reg.

1. Executive Engineer, National Highway Division, Jeypore vide letter dated 03.09.2025 has submitted a proposal on the mentioned subject as detailed below:

S. N.	Chainage		Side of laying	Available ROW (m)	Carriageway width + Shoulder (m)	Dia of proposed utility (in m)	Length (in Km)	Methodology
	From	To						
1	324.800	328.000	LHS	20.0	12.0	0.40	3.200	Open trench
2	333.600	334.300	LHS	20.0	12.0	0.35 & 0.11	0.700	Open trench
3	333.700	333.900	BHS	20.0	12.0	0.09	0.400	Open trench
4	333.700	334.200	RHS	20.0	12.0	0.09	0.500	Open trench
5	333.900	334.200	LHS	20.0	12.0	0.10	0.300	Open trench
6	334.200	334.400	RHS	20.0	12.0	0.11	0.200	Open trench
7	334.200	334.700	LHS	20.0	12.0	0.125	0.500	Open trench
8	334.400	334.700	RHS	20.0	12.0	0.125	0.300	Open trench
9	334.600	334.700	LHS	20.0	12.0	0.35	0.100	Open trench
10	334.700	335.600	LHS	20.0	12.0	0.20	0.900	Open trench
11	335.200	335.600	BHS	20.0	12.0	0.125	0.800	Open trench
12	335.600	337.600	BHS	20.0	12.0	0.11	4.000	Open trench
13	337.600	338.000	BHS	20.0	12.0	0.09	0.800	Open trench
14	334/930		Crossing	20.0	12.0	0.35	0.020	HDD
15	335/830		Crossing	20.0	12.0	0.09	0.020	HDD
16	341/530		Crossing	20.0	12.0	0.15	0.020	HDD
17	352/340		Crossing	20.0	12.0	0.09	0.020	HDD
Total							12.780	

2. As per Ministry's OM No. RW/NH-33044/29/2015/S&R(R) dated 22<sup>nd</sup> November, 2016 the Highway Administrator will put out the application in the public domain for 30 days for seeking claims and objections (on grounds of public inconvenience, safety and general public interest, if any).

3. In view of the above, comments of public for claims/objections, if any, on the above proposal are invited online as well as in hard copy. The strip plan/location details are enclosed herewith. The same should reach to the below mentioned address within 30 days from the date of uploading it in the website, beyond which no objection will be considered.

Address:

The Regional Officer,  
Ministry of Road Transport & Highways,  
Plot No -184, Near Fire Station Sq.,  
Baramunda, Bhubaneswar - 751003.

Yours faithfully,

  
(Sudhansu Sekhar Sahu)  
Senior Technical Assistant  
For Regional Officer

Copy to:

- 1) The Senior Technical Director, NIC, Transport Bhawan, New Delhi - 110001- along with strip chart for uploading on the Ministry's website.
- 2) General public with request to furnish comments, if any, to the above mentioned address or by e-mail to "robbsr.morth@gmail.com"





SPEED POST

हायरी संख्या... 1583  
तारीख... 08-09-2025  
सड़क परिवहन और राजमार्ग मंत्रालय  
क्षेत्रीय कार्यालय, भुवनेश्वर

Office of the Executive Engineer  
National Highway Division, Jeypore  
Email: -eenhdivision@gmail.com

Letter No. 1834/UE /Dated: 31/9/2025

To

The Regional Officer,  
Ministry of Road Transport & Highways,  
Plot No. 184, In front of C.R.P.F. Stadium,  
Baramunda,  
At/Po: Bhubaneswar,  
Dist: Khurda.


Sub: Proposal for laying of water pipe line along NH-326 from Km 324/800 to 338/000 Crossing for Mega PWSto 14 GPs of Boipariguda Block in the district of Koraput in the State of Odisha- reg.

Ref:- i) Your good office letter No 1032 dated 14.08.2025  
ii) SE RW, Koraput letter No 3400 date 02.09.2025

Sir,

In inviting a kind reference to the subject cited above, it is to submit herewith the compliance report received from SE, RWSS Division, Koraput for your kind information & necessary action.

Yours faithfully


  
Executive Engineer  
N.H. Division, Jeypore.


Memo No. \_\_\_\_\_ /Dated: \_\_\_\_\_.

Copy submitted to the Chief Engineer, National Highways (Odisha), Bhubaneswar/ Chief Construction Engineer, N.H. Circle (South), Berhampur for favour of kind information and necessary action.

Executive Engineer,  
N.H. Division, Jeypore

Please examine

  
10/9

  
Sr. TA





eerwss\_kpt@rediffmail.com

Ph. No. (Off) 06852-250281

**OFFICE OF THE SUPERINTENDING ENGINEER  
RURAL WATER SUPPLY & SANITATION DIVISION, KORAPUT**

Letter No. **3402**

Date. **21/9/2025**

To

The Executive Engineer,  
NH Division, Jeypore.

Sub- Submission of compliance to the Proposals for laying of water pipeline on NH-326 from Km 324/800 to Km 338/00 Crossing relating to works of Mega PWS to 14 GP of Boipariguda Block in Koraput District.

Ref: - 1. Your office letter no- 1730/WE date- 20.08.2025

2. This office Letter no- 1922 date-22.05.2025

3. This office Letter no- 697 date- 27.02.2025


Sir,

In inviting a reference to the subject cited above, it is to say that in accordance with clause 3.2 of Ministry's guideline dated 22.11.2016, where crossings through existing drainage structure are not permissible, HDD methods are proposed and the detailed list of such crossings is attached herewith accordingly after due modification of chainages as required.

In this connection you are requested to verify the same and take further necessary action in this regard.

Yours Faithfully,

Encl: As above


  
Additional Chief Engineer  
RWS&S Division, Koraput


Copy Communicated to: -

1. The Addl. Chief Engineer, RWSS Circle Koraput for favour of kind information & necessary action.
2. The SDO, RWS&S Sub-Division, Boipariguda for information & necessary action.
3. The Authorised Signatory KPIL-JWIL JV, project site at Boipariguda for information & necessary action.



SITE INSPECTION REPORT											
SL NO	NH NO	NH Chainage From km/ to km	Side of Laying (LHS/RHS/Crossing)	Available ROW (In m)	Carriage way width+shoulder width (In m)	Embankment height (In m)	Dia of proposed utility including casing (In m)	Methodology (Open Trench/HDD)	Depth of laying of utility from Ground level	Width of trench (In case of Open trench method)	Location of proposed utility beyond the toeline/ drain (yes/No)
1	326	334/930	CROSSING	20	19+5=24	0.5	0.35	HDD	2.2	1	YES
2	326	352/340	CROSSING	20	19+5=24	1.1	0.09	HDD	1.5	0.5	YES
3	326	341/530	CROSSING	20	19+5=24	1.1	0.15	HDD	1.2	0.5	YES
4	326	335/830	CROSSING	20	19+5=24	1.2	0.09	HDD	1.1	0.5	YES

  
 Executive Engineer  
 RWSS Sub Division  
 Baipanguda

  
 Executive Engineer  
 RWSS Sub Division  
 Baipanguda

  
 Superintending Engineer  
 R W S & S Division  
 Koraput




## ANNEXURE-I

total Distanc & Crossings alaong NH-326 under NH-Boipariguda division along for laying water pipe lines for "Execution of 3 Nos individual Rural Piped Water Supply project pertaining to 14Gp's Boipariguda Block in Koraput district,

Sl No	NH No	From Km	to Km	side of laying( LHS/RHS/ Crossing)	Available ROW	Carriage way width+sh oulder	Embankm ent height	Dia of proposed utility including	Methodology open	Depth of laying of utility from	Width of trench ( In case of open)	Location of proposed utility beyond the toe.
1	326	324/8	328/0	LHS	20	7+5=12	0.5	0.4	Open trench	1.4	0.7	Yes
2	326	333/6	334/3	LHS	20	7+5=12	0.5	0.35	Open trench	1.4	0.7	Yes
3	326	333/6	334/3	LHS	20	7+5=12	0.5	0.11	Open trench	1.1	0.35	Yes
4	326	333/7	333/9	BHS	20	7+5=12	1.5	0.09	Open trench	1.1	0.5	Yes
5	326	333/7	334/2	RHS	20	7+5=12	1.2	0.09	Open trench	1.1	0.5	Yes
6	326	333/9	334/2	LHS	20	7+5=12	1.5	0.1	Open trench	1.5	0.5	Yes
7	326	334/2	334/4	RHS	20	7+5=12	0.3	0.11	Open trench	1.2	0.5	Yes
8	326	334/2	334/7	LHS	20	7+5=12	0.3	0.125	Open trench	1.5	0.5	Yes
9	326	334/4	334/7	RHS	20	7+5=12	0.5	0.125	Open trench	1.5	0.5	Yes
10	326	334/6	334/7	LHS	20	7+5=12	0.5	0.35	Open trench	1.4	0.7	Yes
11	326	334/7	335/6	LHS	20	7+5=12	0.5	0.2	Open trench	1.2	0.5	Yes
12	326	335/2	335/6	BHS	20	7+5=12	1.2	0.125	Open trench	1.5	0.5	Yes
13	326	335/6	337/6	BHS	20	7+5=12	1.2	0.11	Open trench	1.2	0.5	Yes
14	326	337/6	338/0	BHS	20	7+5=12	1.2	0.09	Open trench	1.1	0.5	Yes
15	326	334/930		Crossing	20	19+5=24	0.5	0.35	HDD	2.2	1	Yes
16	326	335/830		Crossing	20	19+5=24	1.2	0.09	HDD	1.1	0.5	Yes
17	326	341/530		Crossing	20	19+5=24	1.1	0.15	HDD	1.2	0.5	Yes
18	326	352/340		Crossing	20	19+5=24	1.1	0.09	HDD	1.5	0.5	Yes

Chittaranjan Behara  
03/09/25  
Junior Engineer  
NH Section Boipariguda

  
Assistant Executive Engineer  
NH Sub-Division, Jeypore

  
Executive Engineer  
NH Division, Jeypore