



भारतीय राष्ट्रीय राजमार्ग प्राधिकरण

(सडक परिवहन और राजमार्ग मंत्रालय, भारत सरकार)

National Highways Authority of India

(Ministry of Road, Transport & Highway)

परियोजना कार्यान्वयन, इकाई, सोलापूर (महाराष्ट्र)

Project Implementation Unit, Solapur (Maharashtra)

कार्यालय/Office :

प्लॉट नं. ई-२, जय जलाराम नगर, शिवदारे कॉलेजच्या मागे,

जुळे सोलापूर, सोलापूर - ४१३००४ (महाराष्ट्र)

Plot No. E- 2, Jai Jalaram Nagar, Behind Shivdare College,
Jule Solapur, Solapur - 413 004. Tel/Fax - 0217 2303379

ई-मेल/Email : solapur@nhai.org; piusolapur@gmail.com

No.: NHAI/PIU/SLP/MAH-KNT/NH-9/Electric line/2022/ **6482** Date: **30/03/2022**

INVITATION OF PUBLIC COMMENTS


Sub.: Four Lanning of Solapur - Mah /Kar Border Section of NH-9 from Km 249+000 to 348+800 in the state of Maharashtra on Design, Build, Finance, Operate and Transfer (DBFOT) Basis under NHDP Phase - Laying of 11 KV Electric underground cable work on NH-65 at Ch. 314+664 near Dalimb, Tal. Omerga, Dist. Osmanabad - Reg.

Sir

1. Executive Engineer, MSEDCL, Tuljapur Division, Tuljapur has submitted the proposal for laying of 11 KV Electric underground cable work on NH-65 at Ch. 314+664 near Dalimb, Tal. Omerga, Dist. Osmanabad.
2. As per the guidelines, issued by the Ministry vide OM No. RW /NH-33044/29/2015/ S&R(R) dated 22.11.2016, the application shall be put out in the public domain for 30 days for seeking claims and objections (on grounds of public inconvenience, safety and general public interest).
3. In view of the above, comments of the public on the above application is invited to the below mentioned address, which should reach by this office within 30 days from the date of publication beyond which no comments shall be entertained.

GM (Tech.) & Project Director
 National Highways Authority of India
 Project Implementation Unit, Solapur
 Plot No. E-2, Jalaram Nagar,
 Solapur, Maharashtra,
 Pin - 413004

Thanking you,

भवदीय

महाप्रबंधक (ता) तथा परियोजना निदेशक
भा.रा.रा.प्रा. प.का.ई, सोलापूर

Copy to:-

- i. CGM (Tech) RO Mumbai for information please.
- ii. Executive Engineer, MSEDCL, Tuljapur Division (email id. eetuljapur@ho.mahadiscom.in & tuljapur@gmail.com) - for information.
- iii. Master file.

BHARATMALA

D:\Solapur MAH-KNT Border NH-9 NHDP\VB PKG 7 Group-~~Public to Project~~ Electric Line\Outward Letter\30.03.2022-Public domain notice-Laying of 11 KV Electric underground cable work on NH-65 at 314-664 Dalimb.docx

Head Office : No. G 5 & 6, Sector 10, Dwarka, New Delhi-110 075

Tel. No.: 011-2507 4100 / 2507 4200 Fax No. : 011-2509 3507 / 2509 3514. Web Site : <http://www.nhai.org>



Maharashtra State Electricity Distribution Company Limited.
(A Govt. of Maharashtra Undertaking)

CIN:U40109MH20055GC153645

Office of the Executive Engineer, Old Administrative Building Tuljapur.
E-Mail: eetuljapur@ho.mahadiscom.in E-Mail: eetuljapur@gmail.com

Ref. No.EE/TJR/TS/ **16E 663**

Date :

11 4 MAR 2022

To,
The Director Projects,
Indian National Highway,
Plot No. 8, Old Santosh Nagar
Near Devika Gas Agency, Solapur-413004.

Sub:- Laying of 11Kv Electric underground cable work on NH-65 CH NO. 314+664 Near Dalimb village Tq. Omerga Dist. Osamanabad.

With reference to the above cited subject & As per the MSEDCL sanction letter **EE/TJR/TS/1.3%DDF/COMM/2021-2022/148 Dated 09.12.2021**. We are going to provide 11 KV underground cable on NH-65 CH NO. 314+664 By pushing pipe method to give supply to **Saiprasad petroleum (IOCL) prop. Rajendra Premanath Gaikwad Dalimb**. New 11KV work under the supervision of MSEDCL authority for Express line work.

Detailed sketched of the proposed work with MSEDCL sanction copy is also attached with this . Hence it is kindly requested to accord your approval to carry out the above work because there is acute shortage of voltage which hampering business of existing consumer Saiprasad petroleum prop. Rajendra Premanath Gaikwad Dalimb.

Thanking You

- Enclosed- 1) Undertaking (Annexure 5.1 to 5.12)
2) Road & work sketch.
3) MSEDCL Sanction copy.
4) Check list.

Ranjana
Executive Engineer
EXECUTIVE ENGINEER
M.S.E.D. TULJAPUR
DIVISION

भार.रा.प्रा. पकाई, सोलापूर		
आवक क्र.	4868	
दिनांक	14/03	2022
एम. वाय.		
बी. बी.		
एन. एन.		
एल. ए.		
लेखापाल		
स्टेनोग्राफर		

To,

The Project Director-NHAI.
Project Implementation Unit,
Solapur Division
Solapur-413004

Sub:- Permission to carry out push pipe incasing work for laying of underground
11KV ELECTRIC CABLE for commercial use across **NH-65** four laning of
Solapur- Hyderabad Highway crossing at **CH.314+664**.

Ref.:- Project Director, NHAI, PIU, Solapur letter No. NHAI/PIU/SLPI NH-
52/2020-21/, dated - 03/11/2020

We are planning to lay underground 11KV electric cable of Saiprasad petroleum dalimb (IOCL) prop Rajendra premanath gaikwad across the NH-65 four laning of Solapur- Hyderabad adopting push pipe encasing method.

We are intending to lay our underground 11KV electric cable with minimum excavation or damage to the landscape across the road. We shall take care to minimize inconvenience to public and traffic during the work and reinstatement works.

We request you to grant permission to carry out above work. We shall do the restoration work as per NHAI guidelines and specification at our own cost.

We request you to accept and acknowledge our application letter and kindly issue the permission for the above work.

We are attaching here with the drawing for your reference and records.

Thanking you.

DA:- Proposal with Agreement
(IOCL)PROP RAJENDRA PREMANATH GAIKWAD



SAIPRASAD PETROLEUM DALIMB
DALIMB UNIT

Annexure I

Public Utility provider and Commercial infrastructure

A. Public Utility Provider

A Public Utility Provider in context of this Guideline shall mean any organization that provide and maintains the infrastructure for a public service like electricity, gas, water supply, telecom cables and sewage disposal subject to applicable regulation.

B. Eligible activities for Commercial Units or 'Commercial Infrastructure

Commercial Infrastructure in context of this Guideline shall mean any physical infrastructure that is required to facilitate commercial operations and is constructed, operated and maintained along/across Right of Way of National Highways. Such infrastructure shall include the following:

- a. Underground & above ground pipelines including provisions for booster pumping facilities, maintenance bays and other required support infrastructure for transport of legally permitted materials for commercial usage by a business entity having valid license for commercial operations.
- b. Conveyor Belts including provisions for maintenance bays and other required support infrastructure for transport of legally permitted materials, by a business entity having valid license for commercial operations. .
- c. Power cables/wires etc. meant for commercial usage by a business entity having valid license for commercial operations.
- d. Any other such associated commercial infrastructure facility



Panjan
Executive Engineer
M.S.E.D.C.L. O&M. Divn
TULJAPUR

Annexure II

(Enclosure to Ministry Circular No. RW/NH-33044/17/2000/S & R, dated 29.09.2000) dated 23/07/2003 and
F No. RW/NH-33044/29/2015/S & R(R) dated 22 nd Nov. 2016.

Format for Maintaining Records of Right of Way permission granted for laying Underground cable.
(To be maintained separately for every NH and State)

1. Name of State : Maharashtra
2. Name of Agency (NHAI) : NHAI
3. NH Number : NH-65

Sr. No	Left or right side of NH (towards increasing chainage Km. direction)	Location(Chainage in Km.)	Kind of service	Name of Licensee and contact address	Date signing Of Agree ment	Date validity Of Agree ment	Date of Last inspec tion Of site	Any deviatio n from most standar d norms	Remarl
1	Across the NH-65 at CH.314+664 M.	Push pipe encasing work for Laying Underground 11 KV electric cable across the NH on NH-65 four laning of Solapur -hydrabad Highway crossings at CH. 314+664.Total length 60.00+60.00 meter in the state of Maharashtra	Comm ercial power supply to IOCL petrole um	Saiprasad petroleum dalimb (IOCL)prop Rajendra premanat h gaikwad AP Dalimb tq omerga dist Tuljapur.				No	

SAIPRASAD PETROLEUM DALIMB (IOCL)
PROP RAJENDRA PREMANATH GAIKWAD
DALIMB UNIT



Bunja
EXECUTIVE ENGINEER
M. S. R. DIVISION
TULJAPUR

Check List


Guidelines for Project Directors for processing the proposal for laying of Underground 11 kv Electric Cable
in the land across National Highway vested with NHAI


Relevant Circulars

- 1) Ministry Circular No. NH-41 (58)68 dated 31.01.1969.
- 2) Ministry Circular No. NH-III/P/66/76 dated 1-/19.11.19776
- 3) Ministry Circular No. RWINH-111/P/66/76 dated 11.5.1982
- 4) Ministry Circular No. RWINH-11017/1/86-DOI (ii) dated 28.7.1993
- 5) Ministry Circular No. RW/NH-11037/1/86DOI dated 19.1.1995
- 6) Ministry Circular No. RW/NH-34066/2/95/ S&R dated 25.10.1999
- 7) Ministry Circular No. RW/NH-34066/7/2003 S&R (B) dated 17.9.2003

Check list for getting approval for laying of underground 11KV electric cable on NH land

Sr. No	Item	Information/Status	Remarks
1	General information	Laying of 11KV underground cable at chainage no 89/830	
1.1	Name and Address of the Applicant	Saiprasad petroleum dalimb (IOCL)prop Rajendra premanath gaikwad . AP Dalimb tq omerga dist Tuljapur..& Executive Engineer Tuljapur Division MSEDCL Maharashtra	
1.2	National Highway Number	NH-65	
1.3	State	Maharashtra	
1.4	Location	Solapur- Hyderabadhighway @ CH.NO. 314+664@ Dalimb	
1.5	(Chainage in Km)		
1.6	Length in Meters	60M+60M	
1.7	Width of available ROW		
	(a) Left side from center line towards increasing chainage /km direction	-	
	(b) Right side center from line towards increasing chainage/Km direction	-	
1.8	Proposal to lay underground 11KV electric cable		
	(a) Left side from center line towards increasing chainage /km direction	-	
	(b) Right side center from line towards increasing chainage/Km direction	-	
1.9	Proposal to acquire land		
	(a) Left side from center line	No	
	(b) Right side from center line	No	
1.10	Whether proposal is in the same side where land is not to be acquired. If not then where to lay the underground 11KV electric cable	Across the NH-65 at CH.314+664	
1.11	Details of already laid services, if any, along the proposed	No	
1.12	Number of lanes (2/4/6/8 lane) existing	4 Lane	
1.13	Proposed number of lanes (2 lanes with paved NA shoulders/4/6/8 lanes)	NA	
1.14	Service road existing or not	NA	
	If yes then which side	NA	
	(a) Left side from center line	NA	




Executive Engineer
 M.S.E.D.C.L.O&M. Divn
 TULJAPUR


	(b) Right side from center line	NA	
1.15	Proposed Service road	NA	
	(a) Left side from center line	NA	
	(b) Right side from center line	NA	
1.16	Whether proposal to lay underground 11KV electric cable is Across the road after service road or between the service road and main carriageway	Across the road	

Sr. No	Item	Information/Status	Remarks
1.17	The permission for laying of underground 11KV electric cable shall be considered for approval/rejection based on and method of laying	Yes	
2.0	(a) On approaches, the water mains/cables shall be NA carried along a line as close to the edge of the right of way as possible up-to a distance of 30 m from the bridge and subject to all other stipulations contained in this Ministry's guideline issued with letter No. NH-HI/P/66/76 dated 19.11.1976.	Yes	
3.0	Draft license Agreement signed by two witnesses.	Yes	
4.0	Performance Bank Guarantee in favour of NHAI will be given after to be obtained @ Rs.50/- per running meter (parallel receiving demand note to NH) and rs.1,00,000/- per crossing"of NH, for a period of one year initially (extendable if required till satisfactory completion of work) as a security for ensuring/making good the excavated trench for laying the cables/ducts by proper filling and compaction clearing debris loose earth produced due to execution of trenching at least 50 m away from the edge of the right of way. No payment shall be payable by the NHAI to the licensee for clearing debris loose earth	Will be given after receiving demand note	
4.1	Performance BG as per above is to be obtained.	Yes	
4.2	Conformation of BG has been obtained as per NHAI Guidelines	Yes	
5.0	Affidavit / Undertaking from the Applicant for		
5.1	Not to damage to other utility, if damaged then to pay losses either to NHAI or to the concerned agency	Yes, undertaking enclosed	
5.2	Renewal of Bank Guarantee	Will be done when necessary	
5.3	Conforming all standard condition of NHAI's guideline	Yes, undertaking enclosed	
5.4	Shifting of underground 11KV electric cables and when required by NHAI at their own cost.	Yes	
5.5	Shifting due to laning/widening of NH	Yes	
5.6	Indemnity against all damages and claims clause (xxiv)	Yes	
5.7	Traffic movement during laying of underground 11KV electric cable to be managed by the applicant	Yes	
5.8	If any claims is raised by the Concessionaire then the same has to be paid by the applicant	Yes	
5.9	Prior approval of the NHAI shall be obtained before Yes undertaking any work of installation, shifting or repairs, or alteration to the showing underground 11Kv electric cable located in the National highway right-of ways	Yes	
5.10	Expenditure, if any, incurred by NHAI for repairing Yes any damage caused to the National Highway by the laying, maintenance or shifting of the underground 11Kv electric cable will be borne by the agency owning the line.	Yes	



Banjan
Executive Engineer
M.S.E.D.C.L.O&M. Divn
T. II. IAPUR

5.11	If the NHAI considers it necessary in future to move the utility line for any work of improvement or repairs to the road, it will be carried out as desired by the NHAI at the cost of the agency owning the utility line within a reasonable time (not exceeding 60 days) of the intimation given.		
5.12	Certificate from the applicant in the following format (1) Laying of underground 11Kv electric cable will not have any, deleterious effect on any of the bridge components and roadway safety for traffic, (2) for 6-lanning "We do undertaking that, I will relocate service road/approach road/utilities at my own cost not withstanding the perinission granted within such time as will be stipulated by NHAI" for future six-lanning or any other development"		
6.0	Who will sign the agreement on behalf of underground electric cable agency.	Saiprasad petroleum dalimb (IOCL)prop Rajendra premanath gaikwad & Executive Engineer Tuljapur Division MSEDCL Maharashtra	
7	Certificate from the Project Director		
7.1	Certificate for conforming of all standard condition issued vide Ministry Circular No. Ministry Circular No. NH-41'(58) 68 dated 31.1.1969, Ministry Circular No. NHIII/ P/66/76 dated 18/19.11.1976, Ministry Circular No. RWINH-III/P/66/76 dated 11.5.1982, Ministry Circular No. RW/NH 11037/1/86-DOI (ii) dated 28.7.1993, Ministry Circular No. RW/NH-11037/1/861DOI dated 19.1.1995 Ministry Circular No. RW/NH 34066/2/95/ S&R dated 25.10.1999 and Ministry Circular No. RW/NH-34066/7/2003 S&R (B) dated 17.9.2003		
7.2	Certificate from PD in the following format (1) "It is certified that any other location of the Water Supply pipe line would be extremely difficult and unreasonable costly and the installation of Water Supply pipe line within ROW will not adversely affect the design, stability & traffic safety of the highway nor the likely future improvement such as widening of the carriageway, easing of curve etc". (ii) for 6-lanning (a) Where feasibility is available" I do certify that there' will be no hindrance to proposed six-laning based on the feasibility report considering proposed structure at the said location". (b) In case feasibility report is not available "I do certify that sufficient ROW is available at site for accommodating proposed six-laning".		
8	If NH Section proposed to be taken up by NHAI on Yes BOT basis a clause to be inserted in the agreement. "The permitted Highway on which Licensee has been granted the right to lay cable/duct has also been granted as a right of way to the concessionaire under the concession agreement for up-gradation of -----section from Km- to km----- of NH No. --- on Build. Operate and Transfer Basis) and there of, the licensee shall honour the same".		
9	Who will supervise the work of laying of underground electric cable .	Saiprasad petroleum dalimb (IOCL)prop Rajendra premanath gaikwad & Executive Engineer Tuljapur Division MSEDCL Maharashtra	



Rajendra
Executive Engineer
 M.S.E.D.C.L O&M. Divn
 TULJAPUR

10	Who will ensure that the defects in road portion after laying of underground 11 KV electric cable are corrected and if not corrected then what action will be taken.	Saiprasad petroleum dalimb (IOCL)prop Rajendra premanath gaikwad .& Executive Engineer Tuljapur Division MSEDCL Maharashtra	
11	Who will pay the claims for damages done / disruption in working of Concessionaire if asked by the Concessionaire	Saiprasad petroleum dalimb (IOCL)prop Rajendra premanath gaikwad .	
12	A certificate from PD that, he will enter the proposed permission in the register of records of Hon.		



Panjan
Executive Engineer
M.S.E.D.C.L.O&M. Divn
TULJAPUR

संख्या प्रकाश / अनुच्छेद क्रमांक
दस्त नोंदणी करणार आदेश नं.
नोंदणी होणार प्रमन्यास दुय्यम निबंधक कायान्याचे अर्थ
मिळकतीचे वर्णन
पाबदला रकम

मुद्रांक दिव्या पणान्याचे नाव
दुसऱ्या पणान्याचे नाव
हस्ते अमलदार याचे नाव व पत्ता
मुद्रांक दिव्या पणान्याचे नाव
मुद्रांक दिव्या नोंद वही अ.क्र.
मुद्रांक दिव्या नोंद वही अ.क्र.
प.म. दिव्या पणान्याचे नाव

20446 10 MAR 2022



This Agreement made this _____ day of _____ (month) _____ of _____ (year) between acting in his executive capacity through (hereinafter referred to as the "Authority" which expression shall unless excluded by or repugnant to the context, include his successors in office and assigns) on the one part, and **Salprasad petroleum (IOCL) Prop Rajendra premnath Gaikwad** having its Registered Office located at (hereinafter called the "Licensee") Gut.no.784 Near dalimb village Tq.omergera Dist.Osmanabad which expression shall unless excluded by repugnant to the context, include his successors/administrator assignees on the second part.

Whereas the Authority is responsible, inter-alia, for development and maintenance of lands in Km. _____ to _____ of NH No.65 RoW.

Whereas the Licensee proposes to lay Telecom cable / OFC cable / electrical cable / pipe line / ducts etc. referred to as utility services in subsequent paras.

Whereas the Licensee has applied to the Authority for permission to lay push pipe incasing works for laying of underground 11 KV electric cable of Salprasad petroleum (IOCL) Prop Rajendra premnath Gaikwad across NH on NH-65 four laning of Solapur- Hyderabad Highway crossing at Ch.314+664. Total length 60+60 meter. in the state of Maharashtra.

And whereas the Authority has agreed to grant such permission for way leave on the NH ROW as per terms and conditions hereinafter mentioned,

Now this agreement witnesseth that in consideration of the conditions hereinafter contained and on the part of the Licensee to be observed and performed, the Authority hereby grants to the Licensee permission to lay utility services as per the approved drawing attached hereto subject to the following conditions, namely.

1. ROW permissions are only enabling in nature. The purpose of extending the way leave facility on the National Highway RoW is not for enhancing the scope of activity of a utility service provider, either by content or by intent. Further, enforceability of the permission so granted shall be restricted only to the extent of provisions/scope of activities defined in the license agreement & for the purpose for which it is granted.
2. No Licensee shall claim exclusive right on the RoW and any subsequent user will be permitted to use the Row, either above or below, or by the side of the utilities laid by the first user, subject to technical requirements being fulfilled. Decision of the Authority in relation to fulfilment of technical requirements shall be final and binding on all concerned parties. In case any disruption damage is caused to any existing user by the subsequent user, the Authority shall not be held accountable or liable in any manner.
3. The Licensee shall be responsible for undertaking all activities including, but not limited to site identification, survey, design, engineering, arranging finance, project management, obtaining regulatory approvals & necessary clearances, supply of equipment, material, construction, erection, testing and commissioning, maintenance and operation and all other activities essential or required for efficient functioning of their own utility/ commercial infrastructure facilities.

4. The Licensee shall pay license fees @ Rs. /sq m/month to the Authority, The License fee shall become payable from the date of handing over of RoW land to the Licensee, for laying of utilities/cables/conduits/pipelines for infrastructural service provider. As regards Tariff and Terms and conditions for providing common utility ducts along National Highways, there shall be a separate agreement regime.

5. Fee shall have to be paid in advance for the period for which permission is granted into a license agreement. In case of renewal, rate prevailing at the time of renewal shall be charged in deposit of fee shall attract interest @ 15% per annum compounded annually.

6. Present policy of the MoRT&H is to provide a 2.00 m wide utility corridor on either side of the extreme edge of RoW. In cases where utility ducts with sufficient space are already available along NH, the utility services shall be laid in such ducts subject to technical requirements being fulfilled.

7. The utility services shall be laid at the edge of the Row. In case of restricted width of Row, which may be adequate only to accommodate the carriageway, central verge, shoulders, slopes of embankment, drains, other road side furniture etc; the utility services shall be laid beyond the toe line of the embankments and clear of the drain.

8. The Licensee shall make his own arrangement for crossing of cross drainage structure, rivers, etc. below the bed. In case, this is not feasible, the utility services may be carried outside the railings/parapets and the bridge superstructure. The fixing and supporting arrangement with all details shall be required to be approved in advance from the concerned Highway Administration. Additional cost on account of fixing and supporting arrangement as assessed by the Authority shall be payable by the Licensee.

9. In exceptional cases, where Row is restricted the utility services can be allowed beneath the carriageway of service road, if available, subject to the condition that the utility services be laid in concrete ducts, which will be designed to carry traffic on top. The width of the duct shall not be less than one lane. In such cases, it also needs to ensure that maintenance of the utility services shall not interfere with the safe and smooth flow of traffic. The cost of operation and maintenance will have to be borne by the Licensee.

10. It is to be ensured that at no time there is interference with the drainage of the road land and maintenance of the National Highways. Towards this, the top of the utility services shall be at least 0.6 metre below the ground level. However, any structure above ground shall be aesthetically provided for / landscaped with required safety measures as directed by the concerned Authority;

11. The utility services shall be permitted to cross the National Highway either through structure or conduits specially built for that purpose. The casing / conduit pipe should, as minimum, extend from drain to drain in cuts and toe of slope to toe of slope in the fills and shall be designed in accordance with the provision of IRE and executed following the Specifications of the Ministry,

12. Existing drainage structures shall not be allowed to carry the lines across.

13. The top of the casing conduit pipe containing the utility services to cross the road shall be at least 1.2m below the top of the sub grade or the existing ground level whichever is lower, subject to being at least 0.3m below the drain inverts. A typical sketch showing the clearances is given in Attachment-I.

14. The utility services shall cross the National Highway preferable on a line normal to it or as nearly so as practicable.

15. The casing/conduit pipe for crossing the road may be installed under the road embankment either by boring or digging a trench. Installation by boring method shall be preferred.

16. In case of trenching, the sides of the trench should be done as nearly vertical as possible. The trench width should be at least 30 cm. but not more than 60 cms wider than the outer diameter of the pipe. Filling of the trench shall conform to the specifications contained here-in-below or as supplied by the Highway Authority

- a. Bedding shall be to a depth not less than 30 cm. It shall consist of granular material, free of lumps, clods and cobbles, and graded to yield a firm surface without sudden change in the bearing value. Unsuitable soil and rock edges should be excavated and replaced by selected material.
- b. The backfill shall be completed in two stages (i) Side-fill to the level of the top of the pipe (ii) Overfill to the bottom of the road crust.
- c. The side fill shall consist of granular material laid in 15 cm. Layers each consolidated by mechanical tamping and controlled addition of moisture to 95% of the Proctor's Density. Overfill shall be compacted to the same density as the material that had been removed. Consolidation by saturation or ponding will not be permitted.
- d. The road crust shall be built to the same strength as the existing crust on either side of the trench or to thickness and specifications stipulated by the Highway Authority.

17. The Licensee shall ensure making good the excavated trench for laying utility services by proper filling and compaction, so as to restore the land in to the same condition as it was before digging the trench, clearing debris/loose earth produced due to execution of trenching at least 50 m away from the edge of the right of way;

18. All required restoration work subsequent to laying of the cable shall be required to be undertaken by the Licensee at its cost either by itself or through its authorized representative in consultation with the Authority as per predetermined time schedule and quality standards.

19. Prior to commencement of any work on the ground, a performance Bank Guarantee @ Rs. per route metre / Rs. per sq m with a validity of one year initially (extendable if required till satisfactory completion of work) shall have to be furnished by the Licensee to the Authority/its designated agency as a security against improper restoration of ground in terms of filling/unsatisfactory compaction damages caused to other underground installations/utility services & interference, interruption, disruption or failure caused thereof to any services etc. In case of the Licensee failing to discharge the obligation of making good of the excavated trench/other restoration work, the Authority shall have a right to make good the damages caused by excavation, at the cost of the Licensee and recover the amount by forfeiture of the Bank Guarantee.

20. In case, the Performance Bank Guarantee is invoked as mentioned above, the Licensee shall be required to replenish and reinstate the required Performance Bank Guarantee within one month of such invoking. In case the work contemplated herein is not completed to the satisfaction of the Authority, which has granted the permission, within a period of 11 months from the date of issue of the Bank Guarantee, the Licensee shall either furnish a fresh guarantee or extend the guarantee for a further period of one year. Notwithstanding this, the Licensee shall be liable to pay full compensation to the aggrieved Authority, its designated agency for any damage sustained by them by reason of the exercise of the Row facility;

21. The Licensee shall shift the utility services within 90 days (or as specified by the respective Authority) from the date of issue of the notice by the concerned Authority to shift/relocate the utility services, in case it is so required for the purpose of improvement/widening of the road/route/highway or construction of flyover/bridge and restore the road/land to its original condition at his own cost and risk,

22. The Licensee shall be responsible to ascertain from the respective agency in coordination with Authority, regarding the location of other utilities /underground installations/ facilities etc. The Licensee shall ensure the safety and security of already existing underground installations/utilities/facilities etc. before commencement of the excavation/using the existing cable ducts. The Licensee shall procure insurance from a reputed insurance company against damages to already existing under installations/utilities/facilities etc.

23. The Licensee shall be solely responsible/ liable for full compensation/indemnification or concerned agency / aggrieved Authority for any direct, indirect or consequential damage caused to them/claims or replacements sought for, at the cost and risk of the Licensee. The concerned agency in coordination with Authority shall also have a right make good such damages/ recover the claims by forfeiture of Bank Guarantee.

24. If the Licensee fails to comply with any condition to the satisfaction of the Authority, the same shall be executed by the Authority at the cost and risk of the Licensee.

25. Grant of License is subject to the Licensee satisfying (a) minimum disruption of traffic and (b) no damage to the highways. As far as possible, the Licensee should avoid cutting of the road for crossing highway, and other roads and try to carry out the work by trenchless technology. In case any damage is caused to the road pavement in this process, the Licensee will be required to restore the road to the original condition at its cost. If due to unavoidable reasons the road needs to be cut for crossing or laying utility services, the Licensee has to execute the restoration work in a time bound manner at its cost either by itself or through its authorized representative in consultation with the Authority as per predetermined time schedule and quality standards. In case of the Licensee failing to discharge the obligation of making good of the excavated trench/other restoration work, the Authority shall have a right to make good the damages caused by excavation, at the cost of the Licensee and recover the amount by forfeiture of the Bank Guarantee.

26. The Licensee shall inform/give a notice to the concerned agency designated by the Authority at least 15 day in advance with route details prior to digging trenches, ... for fresh or maintenance/repair works. A separate performance Bank Guarantee for maintenance/repair works shall have to be furnished by the Licensee.

27. Each day, the extent of digging the trenches should be strictly regulated so that utility services is laid and trenches filled up before the close of the work that day. Filling should be completed to the satisfaction of the concerned agency designated by the Authority.

28. The licensee shall indemnify the concerned agency in co-ordination with Authority, against all damages and claims, if any due to the digging of trenches for laying cables/ducts.

29. The permission for laying utility services is granted maximum for 5 years at a time, which can thereafter be considered for renewal. On payment of additional fee at the time of renewal, the permission shall automatically be renewed, unless defaults exist. In case of renewal, rate prevailing at the time of renewal shall be charged. Delay in deposition of fee shall attract interest @ 15% per annum compounded annually.

30. The permission shall be valid only for the period it is issued and fee deposited. However, the Authority also has a right to terminate the permission or to extend the period of Agreement.

31. That the Licensee shall not undertake any work of shifting, repairs or alterations to the utility services without prior written permission of the concerned agency in coordination with the Authority.

32. The permission granted shall not in any way be deemed to convey to the Licensee any ownership right or any interest in route/road/highway land /property, other than what is herein expressly granted. No use of NH ROW will be permitted for any purpose other than that specified in the Agreement,

33. During the subsistence of this Agreement, the utility services located in highway land / property shall be deemed to have been constructed and continued only by the consent and permission of the Authority so that the right of the Licensee to the use thereof shall not become absolute and indefeasible by lapse of time.

34. The Licensee shall bear the Stamp Duty charged on this Agreement.

35. Three copies of 'as laid drawings' of utilities (hard and soft copies) with geotagged photographs and geotagged video recordings of laying of cables in the trench (with respect to the NH) and after complete restoration shall be submitted to the Authority for verification and record within a month of completion of works.

3. 36. The Licensee shall allow free access to the Site at all times to the authorised representatives of Authority to inspect the Project Facilities and to investigate any matter within their Authority, and upon reasonable notice, shall provide reasonable assistance necessary to carry out their respective duties and functions.

37. The utility services shall not be made operational by the Licensee unless a completion certificate to the effect that the utility services has been laid in accordance with the approved specifications and drawings and the trenches have been filled up to the satisfaction of the concerned agency in co ordination with the Authority has been obtained. Notwithstanding anything contained herein, this Agreement may be cancelled at any time by Authority for breach of any condition of the same and the Licensee shall neither be entitled to any compensation for any loss caused to it by such cancellation nor shall it be absolved from any liability already incurred.

38. The Licensee shall ensure adherence to relevant Indian standards and follow best industry practices, methods and standards for the purpose of ensuring the safe, efficient and economic design, construction, commissioning, operation, repair and maintenance of any part of the utility lines/commercial infrastructure facilities and which practices, methods and standards shall be adjusted as necessary, to take account of a. operation, repair and maintenance guidelines given by the manufacturers, b. the requirements of Law, c. the physical conditions at the Site, and d. The safety of operating personnel and human beings.

39. The Licensee shall have to provide safety measures like barricading, danger lighting and other necessary caution boards while executing the work.

40. While laying utility services, at least one lane of road shall be kept open to traffic at all times. In case of single lane roads, a diversion shall be constructed. If any traffic diversion works are found necessary during the working period such diversion shall be provided at the cost of Licensee.

41. After the termination/expiry of the agreement, the Licensee shall remove the utility services within 90 days and the site shall be brought back to the original condition failing which the Licensee will lose the right to remove the utility services. However before taking up the work of removal of utility services the Licensee shall furnish a Bank Guarantee to the Authority for a period of one year for an amount assessed by the Authority as a security for making good the excavated trench by proper filling and compaction, clearing debris, loose earth produced due to excavation of trenching at least 50 m away from the edge of the Row.

42. Any disputes in interpretation of the terms and conditions of this Agreement or their implementation shall be referred to the redress mechanism prevailing in the Ministry and the decision of the redress mechanism shall be final and binding on all.

43. For PPP Projects, in case of any financial loss incurred by the respective project concessionaires due to such laying/shifting of utility services by the Licensee, compensation for the same

shall be required to be borne by the Licensee in mutual agreement with the respective proie concessionaires. MORT &H/ NHAI implementing authorities for the project shall not be liable to the concessionaire in any way in this regard.

This agreement has been made in duplicate, each on a Stamp Paper, Each party to this Agreement has retained one stamped copy each.

IN WITNESS WHEREOF THE PARTIES HERETO HAVE CAUSED THIS AGREEMENT TO BE EXECUTED THROUGH THEIR RESPECTIVE AUTHORISED REPRESENTATIVES THE DAY AND THE YEAR FIRST ABOVE WRITTEN.

SIGNED SEALED AND DELIVERED FOR AND ON BEHALF OF AUTHORITY,
BY SHRI _____

(Signature, name & address with stamp)



SIGNED ON BEHALF OF M/S _____

BY SHRI _____

(Signature, name & address with stamp)

HOLDER OF GENERAL POWER OF ATTORNEY Dated
ACCORDANCE WITH THE RESOLUTION NO. _____
BOARD OF DIRECTORS IN THE MEETING HELD ON

EXECUTED IN
DATED PASSED BY HTE

IN THE PRESENCE OF (WITNESSES):

1.

2.

Panjari
Executive Engineer
M.S.E.D.C.L.O&M. Divn
TULJAPUR



महाराष्ट्र MAHARASHTRA

2020

YE 856799

उमरगा अ क्र २५५३० दिनांक 9 MAR 2022

श्री स. साईप्रसाद पेट्रोलेम प्रा. लि. सोलापूर जिल्हा

वसाहतीच्या रू. २५५३०

हस्तक्षेप करून देणारे अधिकारी

यादी जमले मर्यादा

मागितले यत्न भरतंग

UNDERTAKING

पुढील दिले

We, Saiprasad petroleum (IOCL) Prop Rajendra premnath Gaikwad Gut.no.784 near dalimb village Tq.omeraga Dist. osmanabad, Pin - 43604 & Executive Engineer, Tuljapur Division, MSEDCL Maharashtra.

We have applied to lay push pipe method work for laying of underground 11 KV electric cable of Saiprasad petroleum (IOCL) Prop Rajendra premnath gaikwad across NH on NH-65 four laning of Solapur-hydrabad Highway crossings at CH.314+664. Total length 60.00+60.00 meter in the state of Maharashtra.

We hereby do undertake that - In reference to our application for the route on NH-65 four laning of Solapur-Hydrabad Highway crossings at Ch.314+664. Total length 60.00+60.00 meter in the state of Maharashtra.

1. The department shall not be responsible for any loss or damage to the pipe etc. that may on to any reason during/after laying the same.
2. In the event of any mis happening/accidents etc. while carrying, laying of underground electric cable Saiprasad petroleum (IOCL) Prop Rajendra premnath gaikwad shall be liable to pay the any type of compensasion so claimed.
3. Saiprasad petroleum (IOCL) Prop Rajendra premnath gaikwad shall not cause any damage to the carriage way of the highway and structure like bridges, culverts, drains, building etc. and in case of failure Saiprasad petroleum dalimb (IOCL)prop Rajendra premanath gaikwad .will be liable to make good the loss caused to the department.

साइप्रासद प्रॉपर्टी प्रमोटर प्रा. लि.

4. Saiprasad petroleum dalimb (IOCL) prop Rajendra premanath gaikwad shall lay the Underground electric cable under the guidance of the department.

5. The department shall not responsible in case the pipe line comes in the area under development in future at any time in such an eventuality shifting of the underground electric cable etc. shall be the liability of Saiprasad petroleum dalimb (IOCL) prop Rajendra premanath gaikwad.

6. Saiprasad petroleum dalimb (IOCL) prop Rajendra premanath gaikwad shall be responsible for any damage caused to the trees in the NHAI boundary. It will be responsibility of Saiprasad petroleum dalimb (IOCL) prop Rajendra premanath gaikwad to obtain permission for such likely foreseen/unforeseen damage from the competent authority.

7. In case of some unavailable circumstances if Saiprasad petroleum dalimb (IOCL) prop Rajendra premanath gaikwad desires to across the carriageway, the same shall be done under the guidance of the department and under no circumstances, the carriageway shall be allowed to get damaged. The crossing of carriageway shall be allowed with pressure angle only.

8. While crossing the bridge/culverts, no additional dead load shall be allowed to be added to the existing structure.

9. In case of difficulty anywhere in the stretch, Saiprasad petroleum dalimb (IOCL) prop Rajendra premanath gaikwad shall contact the concerned engineer of the department.

10. We hereby undertake to submit a performance bank guarantee of any amount as may be demanded by NHAI.

11. Saiprasad petroleum dalimb (IOCL) prop Rajendra premanath gaikwad shall be solely responsible/liable for full comensation/indemnification of concerned agency laggricved owners for at our cost and risk.:

12. Underground electric cable would be laid keeping in mind future expansion 4/6 laning of the NH. However, we also agree that we shall shift the Underground electric cable within 30 days for as specified by the respective agency/owner from the date of issue of notice by the concerned owner to shift/relocate the underground electric cable in case it is required for the purpose of improvement/widening of the road/route/highway or construction of flyover/bridge and restore the road/land to its original condition at our own cost and risk.

13. We will not violate the instruction of MORT & H (Ministry of Road Transport & Highways), New Delhi.

14. It is undertaken that the Underground electric cable will be laid out by push method.

15. The agency will notify the concerned PD/Concessionnaire at least 15 days in advance before digging trenches across the road.

16. Adequate arrangement for cautioning the traffic by way of caution board during daytime and danger light at night will be provided by the agency.

17. Each day the extant of digging trenches should be strictly regulated so that the Underground electric cable are laid and trenches filled up before the close of work that day, the filling should be completed to the satisfaction of engineer in charge.

18. The agency shall indemnify the road all the damages, if any, due to the digging of trenches for the laying of Underground electric cable.

SAIPRASAD PETROLEUM DALIMB (IOCL)
PROP RAJENDRA PREMANATH GAIKWAD .
DALIMB UNIT

Executive Engineer
M.S.E.D.C.L.O&M Divn
EXECUTIVE ENGINEER
TULJAPUR DIVISION



महोदय न्यायलय अविभा. उपमगा

Executive Engineer
M.S.E.D.C.L.O&M. Divn
EXECUTIVE ENGINEER
TULJAPUR DIVISION




महाराष्ट्र MAHARASHTRA

2020

YE 856803

उमरगा अ क्र २८५३४ दिनांक 9 MAR 2022

म. साईप्रासद पेट्रोलेम दालिंब हा रीमूव्ह हेमनाथ गैकवाद
दालिंब उमरगा
महाराष्ट्र सिद्धांत जलम
याचा मालक आहे
माहिती देऊन भरण्यात
मदत करील.



Annexure No. 5.2
मुद्रांक दिले.

UNDERTAKING

To,
गणेश सुशिराव इगळे
The Project Director, NHAI, Project Implementation Unit, Solapur, Plot No. E-2, Jai Jalaram
nagar, मद्रास जिल्हा त. को. उमरगा अ क्र ३८०४८
Solapur-413004.

From
Saiprasad petroleum dalimb (IOCL) prop Rajendra premanath gaikwad , Dist. Osmanabad,
Pin - 413604.

We, Saiprasad petroleum (IOCL) Prop Rajendra premnath Gaikwad Gut.no.784 near
dalimb village Tq.omeraga Dist.Osmanabad.. Pin - 413604.& Executive
Engineer,Tuljapur Division,MSEDCL Maharashtra, Do hereby Undertake that in connection
with laying push pipe method work for. Underground 11 KV Electric Cable across NH on NH-
65 four laning of Solapur-hydrabad Highway crossings at Ch.314+664. Total length
60.00+60.00 meter in the state of Maharashtra.

बाह्यपत्र - २

व्यवस्था प्रकार : प्रत्यक्ष कार्य

इस्त नोंदणी करणार आचार्य का

नोंदणी होणार आयत्यास दुय्यम निबंधक कार्यालयाचे वर

मिलकतीचे वर्ग :

पान-रस्ता :

मुद्रांक किंवा चिन्हावली नाव

दुसऱ्या पान

हस्ताक्षर : राजा गाव व पत्ता

मुद्रांक

मुद्रांक : राजा अ.क.

मुद्रांक : राजाजी सही

प.प. वि.क्र. का प्रत्येक प.क्र. २१०६०००६

बहामिस्त कार्यालय अचार्य, अमरा


२५.३.२०२२ १०.३०.२०२२ २५.३.२०२२

२५.३.२०२२ ९ MAR 2022 २५.३.२०२२

२५

We shall furnish a bank guarantee as per NHAI norms for the period of 1 year initially before execution of work will renew timely if required.

SAIPRASAD PETROLEUM DALIMB (IOCL)
PROP RAJENDRA PREMANATH GAIKWAD
DALIMB UNIT



Executive Engineer
M.S.E.D.C.L.O&M. Divn
EXECUTIVE ENGINEER
TULJAPUR DIVISION



महाराष्ट्र MAHARASHTRA

2020

YE 856804

उमरगा अ क्र

9 MAR 2022

श्री साईपुत्रा पदमिनी हा राई हेमचंद्र

ग.

राजेंद्र

यांनी जनरल

मागितले धरून भारतीय

पदांक दिले.

Annexure No. 5.3

गणेश सुरेश UNDER TAKING

To,

The Project Director, NHA, Project Implementation Unit, Solapur, Plot No. E-2, Jai Jalaram nagar, Solapur-413004.

From

Saiprasad petroleum dalimb (IOCL) prop Rajendra premanath gaikwad , Dist. Osmanabad, Pin- 413604.

We , Saiprasad petroleum (IOCL) Prop Rajendra premnath Gaikwad Gut.no.784 near dalimb village Tq.omeriga Dist.Osmanabad.. Pin - 413604.& Executive

Engineer,Tuljapur Division,MSEDCL Maharashtra, Do hereby Undertake that in connection with laying push pipe method work for. Underground 11 KV Electric Cable across NH on NH-65 four laning of Solapur-hydrabad Highway crossings at Ch.314+664. Total length 60.00+60.00 meter in the state of Maharashtra.

[illegible]

Executive Engineer
M.S.E.D.C.L.O.&M. Divn
EXECUTIVE ENGINEER
TULJAPUR DIVISION



महाराष्ट्र MAHARASHTRA

2020

YE 856806

उमरगा अ क्र २५५३८ दिनांक ९ MAR 2022

श्री साईप्रसाद दलित्

राजेंद्र प्रेमनाथ गाईकवाड व दलित्

यांनी जमिनीचे मालकी

मागितले वरून भारतीय

मदत दिले

Annexure No. 5.4

गणेश सुरेशराव इ. उ. UNDERTAKING

To

The Project Director, NHAI, Project Implementation Unit, Solapur, Plot No. E-2, Jai Jalaram nagar, Solapur-413004.

From

Saiprasad petroleum dalimb (IOCL) prop Rajendra premanath gaikwad , Dist. Osmanabad, Pin - 413604.

We , Saiprasad petroleum (IOCL) Prop Rajendra premnath Gaikwad Gut.no.784 near dalimb village Tq.omeriga Dist.Osmanabad.. Pin - 413604.& Executive

Engineer,Tuljapur Division,MSEDCL Maharashtra, Do hereby Undertake that in connection with laying push pipe method work for. Underground 11 KV Electric Cable across NH on NH-65 four laning of Solapur-hydrabad Highway crossings at Ch.314+664. Total length 60.00+60.00 meter in the state of Maharashtra.

वॉटरप्राइम
दस्तावेज प्रकार : वॉटरप्राइम कागज
इस वॉटरप्राइम कागज उपरान्त का
वॉटरप्राइम होना आवश्यक कार्यालयी बंध
मिलकरी दे जयें
पाठकता बंध
मु. क. विभाग के कार्यालयी नाव
दस्तावेज का बंधी बंध
हमने इस वॉटरप्राइम कागज व पत्र
मु. क. विभाग के कार्यालयी
मु. क. विभाग के कार्यालयी अ. क.
मु. क. विभाग के कार्यालयी सही
प. म. वि. वि. कागज प. म. वि. वि. कागज
वॉटरप्राइम कार्यालयी आवार, उपरान्त

के अतिरिक्त पत्र लिखें हो संपूर्ण हमारे सामने
24/3/22 9 MAR 2022
महेश महेश
रजिस्ट्रार

The expenditure if any, incurred by NHAI for repairing any damage caused to the national highway by the laying, maintenance or shifting of the Underground 11 KV Electric Cable will be done by Saiprasad petroleum dalimb (IOCL)prop Rajendra premanath gaikwad , Dist. Osmanabad, Pin - 413604.

SAIPRASAD PETROLEUM DALIMB (IOCL)
PROP RAJENDRA PREMANATH GAIKWAD
DALIMB UNIT



Executive Engineer
M.S.E.D.C.L. O&M. Divn
EXECUTIVE ENGINEER
TULJAPUR DIVISION



महाराष्ट्र MAHARASHTRA

2020

YE 856808

उपराग अ क्र २५३९ दिनांक ९ MAR 2022

श्री जे. राजेश्वर पटेल


ग. साई प्रकाश सायबान

हस्त

यांनी कनक मृदांक ()

मागितले वस्तु भरणा ()

मृदांक दिले



Annexure No. 5.5

गणेश सुरेशराव इगळे

UNDERTAKING

To, प्रधान निदेशक न.का.उपराग अ क्र ३१.०६.२०२१

The Project Director, NHAI, Project Implementation Unit, Solapur, Plot No. E-2, Jai Jalaram nagar, Solapur-413004.

From

Saiprasad petroleum dalimb (IOCL)prop Rajendra premanath gaikwad , Dist.Osmanabad , Pin - 413604.

We , Saiprasad petroleum (IOCL) Prop Rajendra premnath Gaikwad Gut.no.784 near dalimb village Tq.omerga Dist.Osmanabad.. Pin - 413604.& Executive Engineer,Tuljapur Division,MSEDCL Maharashtra, Do hereby Undertake that in connection with laying push pipe method work for. Underground 11 KV Electric Cable across NH on NH-65 four laning of Solapur-hydrabad Highway crossings at Ch.314+664. Total length 60.00+60.00 meter in the state of Maharashtra.

सविस्तर
सविस्तर प्रकल्प, प्रकल्पक

सविस्तर प्रकल्पक, प्रकल्पक

सविस्तर प्रकल्पक, प्रकल्पक

सविस्तर प्रकल्पक, प्रकल्पक

सविस्तर प्रकल्पक, प्रकल्पक

सविस्तर प्रकल्पक, प्रकल्पक

सविस्तर प्रकल्पक, प्रकल्पक

सविस्तर प्रकल्पक, प्रकल्पक

सविस्तर प्रकल्पक, प्रकल्पक

सविस्तर प्रकल्पक, प्रकल्पक

सविस्तर प्रकल्पक, प्रकल्पक

सविस्तर प्रकल्पक, प्रकल्पक

सविस्तर प्रकल्पक, प्रकल्पक

Saiprasad petroleum dalimb (IOCL)prop Rajendra premanath gaikwad ,
Dist. Osmanabad. have to shift Underground 11 KV Electric Cable in future due
to 4/6 laning / widening is in process of NH.

SAIPRASAD PETROLEUM DALIMB (IOCL)
PROP RAJENDRA PREMANATH GAIKWAD
DALIMB UNIT



Executive Engineer
M.S.E.D.C.L O&M. Divn
EXECUTIVE ENGINEER
TULJAPUR DIVISION



महाराष्ट्र MAHARASHTRA

2020

YE 856810

उपराज अ.क्र. 2000 दिनांक E-9 MAR 2022


श्री. साईप्रासद पुराजिना दलंब

श्री. राजेंद्र प्रेमनाथ गाईकवाड

यांनी जमिनी मालकी

मागितले बंधन भारतीय

मुद्रांक दिले.



Annexure No. 5.6

गणेश सुरेशराव इगळे

UNDERTAKING

To, प्रधान निदेशक न.का.उपराज अ.क्र. 31.06.003

The Project Director, NHAI, Project Implementation Unit, Solapur, Plot No. E-2, Jai Jalaram nagar, Solapur-413004.

From Saiprasad petroleum dalimb (IOCL)prop Rajendra premanath gaikwad , Dist. Osmanabad, Ph - 413604.

We , Saiprasad petroleum (IOCL) Prop Rajendra premnath Gaikwad Gut.no.784 near dalimb village Tq.omerga Dist.Osmanabad.. Pin - 413604.& Executive Engineer,Tuljapur Division,MSEDCL Maharashtra, Do hereby Undertake that in connection with laying push pipe method work for. Underground 11 KV Electric Cable across NH on NH-65 four laning of Solapur-hydrabad Highway crossings at Ch.314+664. Total length 60.00+60.00 meter in the state of Maharashtra.

विषय: २
इसका प्रकार / अनुच्छेद क्या है
इससे जेडपी का काम आरंभ का
तीव्रणी होगा प्रमाणित दस्तावेज कायम रखने के
मिलकतीसे वर्णन
पावदला रखने
मुद्रांक लिखने प्रमाणित नाम
दस्तावेज का नाम
हस्ताक्षर करने वाले का नाम व पता
मुद्रांक मुद्रांक
मुद्रांक लिखने वाले का नाम, पता
मुद्रांक लिखने वाले का पता
प.मु.वि. तालुका, जिल्हा प. अ. ३१, ०६, ०००
नगरपालिका कार्यालय आचार, इमरगा

9 MAR 2022

Indemnity against all damages and claims during work is of Saiprasad petroleum dalimb (IOCL) prop Rajendra premanath gaikwad , Dist. Osmanabad.

SAIPRASAD PETROLEUM DALIMB (IOCL)
PROP RAJENDRA PREMANATH GAIKWAD
DALIMB UNIT



Executive Engineer:
M.S.E.D.C.L.O&M. Divn
TULJAPUR
EXECUTIVE ENGINEER
TULJAPUR DIVISION



महाराष्ट्र MAHARASHTRA

उमरगा अ क्र २५४५

दिनांक ११.०३.२०२२


श्री साईपुत्र प्रेमनाथ गायक

श्री राजेंद्र प्रेमनाथ गायक

साईपुत्र प्रेमनाथ गायक

महाराष्ट्र राज्य सरकार

मुद्रांक दिले.



Annexure No. 5.7

गणेश सुरेशराव इगळे

मुद्रांक दिलेला त.क्र. उमरगा अ क्र २५४५

UNDERTAKING

To,

The Project Director, NHAI, Project Implementation Unit, Solapur, Plot No. E-2, Jai Jalaram nagar, Solapur-413004.

From

Saiprasad petroleum dalimb (IOCL) prop Rajendra premanath gaikwad , Dist. Osmanabad, Pin - 413604.

We , Saiprasad petroleum (IOCL) Prop Rajendra premnath Gaikwad Gut.no.784 near dalimb village Tq.omergera Dist.Osmanabad.. Pin - 413604.& Executive

Engineer,Tuljapur Division,MSEDCL Maharashtra, Do hereby Undertake that in connection with laying push pipe method work for. Underground 11 KV Electric Cable across NH on NH-65 four laning of Solapur-hydrabad Highway crossings at Ch.314+664. Total length 60.00+60.00 meter in the state of Maharashtra.

[illegible]

10
1000 1000 1000

Executive Engineer
M.S.E.D.C.L.O&M. Divn
EXECUTIVE ENGINEER
TULJAPUR DIVISION




महाराष्ट्र MAHARASHTRA

● 2020 ●

YE 856777

उपराग अ क्र २०५२२ दिनांक ११० MAR 2022
श्री स. सुप्रसाद पेट्रोलेम दालिंब
श्री स. सुप्रसाद पेट्रोलेम दालिंब
कारण
महाराष्ट्र सरकार
मुद्रांक दिले.



Annexure No. 5.8

गणेश सुरेशराव डंगरे
UNDERTAKING

To, महाराष्ट्र नॅशनल हायवे अथॉरिटी, अ. क्र. ३१, ०६००३

The Project Director, NHA, Project Implementation Unit, Solapur, Plot No. E-2, Jai Jalaram nagar, Solapur-413004.

From
Saiprasad petroleum dalimb (IOCL) prop Rajendra premanath gaikwad, Dist. Osmanabad, Pin - 413604.

We, Saiprasad petroleum (IOCL) Prop Rajendra premnath Gaikwad Gut.no.784 near dalimb village Tq.omergera Dist.Osmanabad.. Pin - 413604.& Executive Engineer,Tuljapur Division,MSEDCL Maharashtra, Do hereby Undertake that in connection with laying push pipe method work for. Underground 11 KV Electric Cable across NH on NH-65 four laning of Solapur-hydrabad Highway crossings at Ch.314+664. Total length 60.00+60.00 meter in the state of Maharashtra.

डा. ४५३-३

क्यासा प्रकाश / प्रमोव्ड कापक

इस्त नोदणी कापका आरत वर

नोदणी होणा प्रमोव्ड दुयम प्रमोव्ड कापकाचे वर

मिळवतीचे वर

प्रमोव्ड कापक

मुद्रांक विभाग, कापकाचे नाव

दुयम प्रमोव्ड कापक

हस्त आरत वर कापक नाव व पत्ता

मुद्रांक विभाग, कापक

मुद्रांक विभाग, कापकाचे नाव

मुद्रांक विभाग, कापकाचे नाव

प.म.वि.जी.का. इ.का. व.क. ३१०६००१

नहसिल कार्यालय आवा, उमगा

२०५४२ १० MAR २०२२

If any claim is raised by the concessionaire then the same will be paid by
Saiprasad petroleum dalimb (IOCL)prop Rajendra premanath gaikwad ,
Dist. Osmanabad.

SAIPRASAD PETROLEUM DALIMB (IOCL)
PROP RAJENDRA PREMANATH GAIKWAD
DALIMB UNIT



Executive Engineer
M.S.E.D.C. L.O&M. Divn
EXECUTIVE ENGINEER
TULJAPUR DIVISION




महाराष्ट्र MAHARASHTRA

10 MAR 2022

YE 856780

उपराग अ क्र 20402 दिनांक 10 MAR 2022
श्री अ साईपुल्लु महेस्वरन दिकर
या 20402 हेमन्त गायकवार
हस्त
यानी 20402 ॥ सिद्धांत गायकवार
मागितले वस्तु भारतीय



Annexure No. 5.9

गणेश सुंराव UNDERTAKING

To,

The Project Director, NHAI, Project Implementation Unit, Solapur, Plot No. E-2, Jai Jalaram nagar, Solapur-413004.

From

Saiprasad petroleum dalimb (IOCL) prop Rajendra premanath gaikwad , Dist. osmanabad, Pin - 413604.

We , Saiprasad petroleum (IOCL) Prop Rajendra premnath Gaikwad Gut.no.784 near dalimb village Tq.omerga Dist.Osmanabad.. Pin - 413604.& Executive

Engineer,Tuljapur Division,MSEDCL Maharashtra, Do hereby Undertake that in connection with laying push pipe method work for. Underground 11 KV Electric Cable across NH on NH-65 four laning of Solapur-hydrabad Highway crossings at Ch.314+664. Total length 60.00+60.00 meter in the state of Maharashtra.

हॉटपत्र - २

कम्प्लाय प्रकल्प पत्रावरून केवळ

इसत नोंदणी करणाऱ्या आचार्य

रोटरी

मिटर

पावट

मुद्र

दुसऱ्या

हस्त

मुद्र

मुद्र

मुद्र

प.मु.वि.ओ

नमसिल कार्यालय आवार, उमरगा

नमो न पत्र

10 MAR 2022

(2.5)

We will obtain prior approval of the NH before undertaking any work of installation, shifting or repairs or alternations to the under ground 11 KV Electric Cable located in the National Highway right of ways.

SAIPRASAD PETROLEUM DALIMB (IOCL)
PROP RAJENDRA PREMANATH GAIKWAD
DALIMB UNIT



ENGINEER
M. S. CHIDAMBARAM
TULIAPUR



महाराष्ट्र MAHARASHTRA

2020

YE 856781

11 0 MAR 2022

अमरा अ क्र २८५५० दिनांक

श्री के. सुप्रकाश पटेल निवासी

श्री. राजेंद्र प्रेमनाथ गाईकवाड

यांनी केलेले काम

Annexure No. 5.10

UNDERTAKING

To,

The Project Director, NHAI, Project Implementation Unit, Solapur, Plot No. E-2, Jai Jalaram nagar,


Solapur-413004.

From

Saiprasad petroleum dalimb (IOCL) prop Rajendra premanath gaikwad , Dist. osmanabad, Pin - 413604.

We , Saiprasad petroleum (IOCL) Prop Rajendra premnath Gaikwad Gut.no.784 near dalimb village Tq.omerga Dist.Osmanabad.. Pin - 413604.& Executive

Engineer,Tuljapur Division,MSEDCL Maharashtra, Do hereby Undertake that in connection with laying push pipe method work for. Underground 11 KV Electric Cable across NH on NH-65 four laning of Solapur-hydrabad Highway crossings at Ch.314+664. Total length 60.00+60.00 meter in the state of Maharashtra.



[illegible]

Expenditure if any incurred by NHAI for repairing any damage caused to the national highway by the laying, maintenance or shifting of the Underground 11 KV Electric Cable will be borne by **Saiprasad petroleum dalimb (IOCL)prop Rajendra premanath gaikwad , Dist. Osmanabad.** Owning the line.

Executive Engineer
M.S.E.D.C. & M. Divn
EXECUTIVE ENGINEER
TULJAPUR
TULJAPUR DIVISION




महाराष्ट्र MAHARASHTRA

2020

YE 856784

उपराग अ क्र. २५५३ दिनांक १० MAR 2022
श्री. अ. सुप्रसाद दलम्ब
ग. राजेंद्र प्रेमनाथ गैकवाद
ह. साईप्रसाद दलम्ब
यांना जनरल मॅट्रिक (६)
मागितले करून भारतीय (७५)



Annexure No. 5.11

UNDERTAKING

To,
The Project Director, NHAI, Project Implementation Unit, Solapur, Plot No. E-2, Jai Jalaram
nagar,
Solapur-413004.

From
Saiprasad petroleum dalimb (IOCL) prop Rajendra premanath gaikwad , Dist. osmanabad, Pin
- 413604.

We , Saiprasad petroleum (IOCL) Prop Rajendra premnath Gaikwad Gut.no.784 near
dalimb village Tq.omerga Dist.Osmanabad.. Pin - 413604.& Executive
Engineer,Tuljapur Division,MSEDCL Maharashtra, Do hereby Undertake that in connection
with laying push pipe method work for. Underground 11 KV Electric Cable across NH on NH-
65 four laning of Solapur-hydrabad Highway crossings at Ch.314+664. Total length
60.00+60.00 meter in the state of Maharashtra.

साधुपडा २
 जलवायु प्रकृति / अ. जलवायु प्रकृति
 इस्त नौदणी कायदा अ. जलवायु प्रकृति
 नौदणी होयना अ. जलवायु प्रकृति
 पिलकलीन अ. जलवायु प्रकृति
 पावना अ. जलवायु प्रकृति
 मुद्रा अ. जलवायु प्रकृति
 दुसरा अ. जलवायु प्रकृति
 हस्त अ. जलवायु प्रकृति
 मुद्रा अ. जलवायु प्रकृति
 मुद्रा अ. जलवायु प्रकृति
 मुद्रा अ. जलवायु प्रकृति
 प. म. अ. जलवायु प्रकृति
 नमोसल वायुप्रकृति आवाय, उमगा

2013 10 MAR 2022

If NHAI considers it necessary in future to move the utility line for any work of improvement or repair to the road, it will be carried out as desired by NHAI at the cost of the agency owning the utility line within a reasonable time (not exceeding 60 days) of the intimation given.

SAIPRASAD PETROLEUM DALIMB (IOCL)
 PROP RAJENDRA PREMANATH GAIKWAD
 DALIMB UNIT



Panija
 Executive Engineer
 SECTION ENGINEER
 TULJAPUR DIVISION



महाराष्ट्र MAHARASHTRA

2020

0. MAR 2022

YE 856785

उपरा अ क्र २५५४ दिनांक

श्री के. सी. प्रसाद प्रेमनाथ गैकवाद

विवरण राजेंद्र प्रेमनाथ गैकवाद

कारण

यानी उपरा अ क्र २५५४

माहिती देणारे अधिकारी

पुढीलप्रमाणे

Annexure No. 5.12

गणेश सुरेशराव इ. UNDERTAKING

To, पुढीलप्रमाणे माहिती देणारे अधिकारी अ क्र २५५४

The Project Director, NHAI, Project Implementation Unit, Solapur, Plot No. E-2, Jai Jalaram nagar, Solapur-413004.


From

Saiprasad petroleum dalimb (IOCL) prop Rajendra premanath gaikwad, Dist. osmanabad, Pin 413604.

We, Saiprasad petroleum (IOCL) Prop Rajendra premnath Gaikwad Gut.no.784 near dalimb village Tq.omerga Dist.Osmanabad.. Pin - 413604.& Executive

Engineer,Tuljapur Division,MSEDCL Maharashtra, Do hereby Undertake that in connection with laying push pipe method work for. Underground 11 KV Electric Cable across NH on NH-65 four laning of Solapur-hydrabad Highway crossings at Ch.314+664. Total length 60.00+60.00 meter in the state of Maharashtra.


10 MAR 2022





Executive Engineer
TULJAPUR DIVISION

DRAWING FOR HDD METHOD CH/NO314+614

TOP VIEW



SIDE VIEW



Prathibha
Executive Engineer
M.S.E.D. C.L.O&M. Divn
TULJAPUR

इंडियन ऑयल कॉर्पोरेशन लिमिटेड

पुणे मंडल कार्यालय :

2 रा माला, बी.एस.एन.एल. टेलिफोन एक्सेज बिल्डींग,

पुणे गोल्फ कोर्स के सामने, एअरपोर्ट रोड, येरवडा, पुणे - 411006.

Indian Oil Corporation Limited

Pune Divisional Office

2nd Floor, BSNL Telephone Exchange Building,

Opp. Pune Golf Course, Airport Road, Yerwada, Pune - 411006.

Tel. : 020 - 26681421 / 22



IndianOil

विपणन प्रभाग

Marketing Division

Ref: M/2020/IN000332/MAH/000040/3203/00012

Page: 1 of 4

Date: 29.05.2020

To,
RAJENDRA GAIKWAD
J10, JAI BHARAT HOU SOC., SUNDER BAUG LANE,
KAMANI KURLA WEST,
MUMBAI- 400070



Dear Sir/Madam,

Sub : Proposed MS/HSD A Site Retail Outlet Dealership at Location: FROM YELI TOWARDS MURUM PHATA ON LHS OF NH 65, District: OSMANABAD State: Maharashtra Category: SC

I refer to our advertisement dated 25.12.2018 and your application form No. 15450565849251 for the award of MS/HSD Retail Outlet dealership at the above location and the subsequent Draw of Lots held at PUNE on 19.06.2019.

Please be informed that by this Letter of Intent, we propose to offer you a Retail Outlet dealership of Indian Oil Corporation Ltd. at the above location on the following terms & conditions:-

1. You have offered a suitable piece of land admeasuring 1575 Sq. Meter approx.: 35 Meter (frontage) X 45 Meter (depth) at GUT NO- 784, Village DALIMB, Taluka: OMERGA, District: OSMANABAD, you as indicated by you in the application for the development of the subject Retail Outlet. You have to make available this land within 2 months from the date of this letter failing which this offer is liable to be withdrawn.
2. As and when advised by the Corporation, the site offered by you should be duly developed up to the road level by cutting/filling (as applicable), with good earth/murum, layer-wise compacted as per standard engineering practices. You shall also construct necessary retaining wall and compound wall of 1.5 meters height, designed as per site conditions as per approval of Corporation as committed under Clause 12 (e) of affidavit submitted by you along with application. Subsequently, the land would be required to be transferred on lease for a minimum period of 19 Yrs & 11 months with renewable option at rentals mutually agreed upon / sold to Indian Oil Corporation Ltd. Kindly note that in case the site as offered by you for leasing/sale to Indian Oil Corporation Ltd. for putting up the Retail Outlet is not made available for lease/purchase as per the advice of the Corporation, this Letter Of Intent will be withdrawn without any further notice. However, there is no commitment from Indian Oil Corporation Ltd. for taking the said land from you.
3. Indian Oil Corporation Ltd. will develop the retail outlet at the above location FROM YELI TOWARDS MURUM PHATA ON LHS OF NH-65 on the said site to be taken on lease by Indian Oil Corporation Ltd. with appropriate structures, storage tanks and pumps. Additional facilities (site specific) may also be developed by Indian Oil Corporation Ltd. on its sole discretion such as Canopy, Service Station or any other facility as may be decided by Indian Oil Corporation Ltd. from time to time.
4. You will provide at the retail outlet other mandatory facilities at your cost at the Retail Outlet premises as under
 - a. Clean drinking water.
 - b. Telephone.
 - c. First aid kit with valid medicines
 - d. PUC facilities, wherever it is mandatory.
 - e. Other facilities as may be specified by the Corporation from time to time.

CIN - L23201 MH 1959 GOI 011388

पंजीकृत कार्यालय : इंडियन ऑयल भवन, जी - 9, अली यावर जंग मार्ग, बांद्रा (पूर्व), मुंबई - 400 051 (भारत)

Regd. Office : Indian Oil Bhavan, G - 9, Ali Yavar Jung Marg, Bandra (E), Mumbai - 400 051 (India)

the facilities that may be provided by the Corporation as aforesaid, we will recover from you license fee as may be decided by the Corporation and applicable to you from time to time. At present, the license fee recoverable is Rs 472.77/- KL For MS and Rs 393.97/- KL for HSD including applicable taxes.

The corporation will not be held liable for any loss or damage on account of delay that may be caused in providing you the facilities mentioned above, whatever may be the cause of the failure or delay.

7. For enabling you to operate the dealership, Working capital, as may be determined by the Corporation at its sole discretion to be utilized only for the purpose of taking delivery of MS/HSD/Lubes from the Corporation to maintain supply.

The above working capital will carry interest, which at present is @ 11% per annum payable monthly from the date of disbursement of the working capital by the Corporation.

The aforesaid working capital along with the interest mentioned above, will be repayable by you in 100 equal monthly installments commencing from the 13th month of commissioning of the dealership.

8. You shall not induct any partner(s) in case of individual (s) nor make any changes in the constitution of the partners as existing at the time of application without approval of the company, except your spouse as per terms and conditions of Indian Oil Corporation Ltd., and shall give an undertaking to this effect.

9. It will always be a basic condition for the award of MS / HSD retail outlet dealership that you shall be paying attention towards day to day working of the dealership by personally managing the affairs of the dealership you will give us a written undertaking to this effect and shall not assign or part with the same to any other person (s).

You will not be eligible for taking up any employment. If you are already employed you will have to resign from the employment and produce the letter of acceptance of resignation by the employer before the issuance of Letter of Appointment by Indian Oil Corporation Ltd..

10. As agreed, you will be initiating necessary action towards enabling registration of site where the Retail Outlet is planned. You will also assist us in getting the requisite NOC from appropriate Authorities.


11. You will deposit with us a Demand Draft for 270000.00 drawn on any scheduled bank in favour of Indian Oil Corporation Ltd. payable at Pune towards Security Deposit (after setting off Initial Security Deposit amount) at the time of issuance of appointment letter after compliance of all the requirements of LOI.

Kindly note that the Security deposit will not carry any interest and is refundable at the time of expiry of agreement between you and the Corporation. However, if such expiry of agreement is consequent to proven adulteration/malpractice at the dealership, this amount will be forfeited. Moreover, this Corporation reserves its right to adjust this amount towards any dues to it.

12. You will be notified by the corporation, in writing, after the facilities mentioned above are made available and are ready for commissioning the dealership. Immediately on receipt of the above notice from the Corporation, you shall obtain each and every license necessary for operating your dealership as may be required under any Central / State Govt. / Municipal or local authorities for the time being in force.

13. If we find that the progress made by you towards the above is not to our satisfaction, this offer is liable to be withdrawn.

14. Please note that you are required to fulfill the conditions with regard to inducting Spouse as Co-owner in the dealership before issuance of Letter of Appointment.



Letter of intent will stand automatically withdrawn and cancelled on the happening of any of the following events:-

In case you or your close relatives like spouse, unmarried son(s) and unmarried daughter(s) receive anytime or have received a letter of intent for any other dealership or distributorship from our company or any other oil company either in your individual capacity or in partnership with any other individual(s).

- b. If it is found that you have suppressed and / or misrepresented any material facts in your application.
- c. In case you are found to be convicted for any criminal / economic offence involving moral turpitude.
- d. In the event of death if you are an individual/partner.

16. In case you are not able to provide the developed land within the specified time or fail to fulfill of terms & conditions of LOI or withdraw for any reason, then LOI can be withdrawn and selection cancelled.
17. In case you are not able to provide the developed land within the specified time or fail to fulfill of terms & conditions of LOI or withdraw for any reason, then LOI can be withdrawn and selection cancelled. In such situations Initial Security Deposit (ISD) would be forfeited.
18. This letter is merely a letter of intent and is not to be construed as a 'firm offer' of dealership to you. The dealership will be allotted to you on your complying with the terms and conditions spelt out herein above by issuance of appointment letter along with signing of our standard dealership agreement between you and us.
- 19 Note : You have one time option to offer alternate land meeting all specifications in the advertised location/stretch within 90 days of this LOI provided you have not availed such opportunity of providing alternate land after FVC (Field Verification of Credentials).

Should you require any further details / guidelines, please get in touch with our office at the address mentioned below:

Pune Divisional Office
885/1, Millenium Tower, II & IIIrd
Bhandarkar Institute Rd., Pune.

Remarks :


इंडियन ऑयल कॉर्पोरेशन लि.
पुणे मंडल कार्यालय
कुसुम तल, वि.एस.एम.एल. टेलिफोन एक्सचेंज बिल्डींग,
वेरुडा, पुणे - 411006

Please acknowledge receipt of this letter.

Thanking you.

Yours faithfully

For Indian Oil Corporation Ltd,



Dy. General Manager (Retail Sales)

ACKNOWLEDGEMENT

I/we hereby accept this Letter of Intent with all the terms and conditions stipulated therein.

I/We do hereby confirm that I/we am/are eligible for allotment of Retail Outlet dealership as per applicability of Multiple Dealership Norm defined under Clause "Disqualification" in the " Brochure for Selection of Dealers for Regular & Rural Retail Outlets" and I am / We are not disqualified for allotment of Retail Outlet dealership under other conditions mentioned therein.

Place: Pune
Date: 16/06/2020

Signature: 
Name: Keyur R. Gaikwad

OO:

CC : State Retail Head ; Vide ref. 3203/2020-21/109702 dated 15.04.2020 approval was obtained for issue of LOI. Accordingly the above LOI has been issued. This is for your kind information & records.

4:17 PM

पावती

Original/Duplicate

नोंदणी क्रं. : 39म

Regn.:39M

पावती क्र.: 6303 दिनांक: 11/12/2018

गावाचे नाव: दाळींब

दस्तऐवजाचा अनुक्रमांक: उमग-3869-2018

दस्तऐवजाचा प्रकार : भाडेपट्टा

सादर करणाऱ्याचे नाव: प्रकाश गौरोबा कांबळे

नोंदणी फी

रु. 12000.00

दस्त हाताळणी फी

रु. 200.00

डाटा एन्ट्री

रु. 20.00

पृष्ठांकी संख्या: 10

एकः

₹. 12220.00

આપણાસ મૂલ્ય દસ્ત ,પંચનેલ પ્રિંટ,સૂચી-૨ અંદાજે

1.10 FM ह्या वेळेस मिळेल.

बाजार मुल्य: रु.28000000/-

मोबदला रु.0/-

भरलेले मुद्रांक शुल्क : रु. 112000/-

~~Sub Registrar's Office~~
~~3rd Floor, 1st Floor~~

उमरगा

1) देयकाचा प्रकार: eChallan रकम: रु.12000/-

डीडी/घनादेश/पे ऑर्डर क्रमांक: MH009238393201819E दिनांक: 11/12/2018

द्वैकेचे नाव व पत्ता:

2) देयकाचा प्रकार: By Cash रक्कम: रु 220/-


नौदण्डी की माफी असल्यास तपशिल :-

1) Fee Adjustment : Fee Adjustment (yashada training) code added for keeping tack of adjusted fees



CHALLAN
MTR Form Number-6

टोकन नं.	3
अनुष्ठान क	92




GRN	MH009238393201819E	BARCODE	Date		11/12/2018-11:31:59	Form ID	36A
Department	Inspector General Of Registration		Payer Details				
Type of Payment	Stamp Duty Registration Fee		TAX ID (If Any)				
			PAN No.(If Applicable)				
Office Name	OMG_UMERGA SUB REGISTRAR		Full Name	Prakash Goroba Kamble			
Location	OSMANABAD		Flat/Block No.	784			
Year	2018-2019 One Time		Premises/Building	4000			
Account Head Details	Amount In Rs.	Road/Street	Dalimb				
0030046401 Stamp Duty	112000.00	Area/Locality	Town/City/District				
0030063301 Registration Fee	12000.00	PIN	4 1 3 6 0 6				
		Remarks (If Any)	SecondPartyName=Rajendra Premnath				
			Gaikwad-CA=2800000-Marketval=2800000				
		Amount In	One Lakh Twenty Four Thousand Rupees Only				
		Words					
		1,24,000.00					
Payment Details		FOR USE IN RECEIVING BANK					
STATE BANK OF INDIA		Bank CIN	Ref. No.	00040572018121126180	IK00VQLEO2		
Cheque/DD Details		Bank Date	RBI Date	11/12/2018-11:32:55	Not Verified with RBI		
Cheque/DD No.		Bank-Branch		STATE BANK OF INDIA			
Name of Bank		Scroll No. , Date		Not Verified with Scroll			
Name of Branch							



Department ID : Mobile No. : 9890842346
NOTE: This challan is valid for document to be registered in Sub Registrar office only. Not valid for unregistered document.
सदर चलन केवल दुर्यम निबंधक कार्यालयात नोंदणी करावयाच्या दस्तासाठी लागू आहे. नोंदणी न करावयाच्या दस्तासाठी सदर चलन लागू नाही.

Challan Defaced Details

उ म ग / 2018	
दस्त क्र.	13268
पाने	9/70



Sr. No.	Remarks	Defacement No.	Defacement Date	User Id	Defacement Amount
1	(IS)-206-3869	0005054666201819	11/12/2018-13:06:19	IGR284	12000.00
2	(IS)-206-3869	0005054666201819	11/12/2018-13:06:19	IGR284	112000.00
Total Defacement Amount					1,24,000.00

--:- श्री--:-

--:- भाडेपट्टा--:-

भाडेपट्टा खुल्या जागेचे शासकिय किंमत २८,००,०००/- (अक्षरी आठठाविस लाख रुपये फक्त.)मौजे दाळीब तालुका उमरगा जिल्हा उस्मानाबाद येथील मुदत २८ वर्ष ११ महीने वार्षिक भाडे रुपये-१२,०००/-विभाग क्रमांक ६ मधील खुली जागा.

दिनांक ११ डिसेंबर २०१८

लिहून घेणार :- प्रकाश गोरोबा कांबळे वय ६५वर्ष धंदा शेती

रा.तळवडे पुणे ता.जि. पुणे ४१२११४

पॅन नं. AVJPK4682N(मुळ जमीन मालक)

यांसी.....

लिहून देणार :- राजेंद्र प्रेमनाथ गायकवाड वय ४३ वर्ष धंदा व्यापार

रा.सुंदरबाग कमानी कुर्ला पश्चिम मुंबई ४०००७०

पॅन नं. ALGPG7148A----- (भाडेकरू)


कारणे भाडेपट्टा लिहून देतो की,

१ मिळकतीचे वर्णन - तुकडी उस्मानाबाद पोटा तुकडी उमरगा मे दुय्यम निबंधक साहेब उमरगा जिल्हा उस्मानाबाद व ग्रामपंचायत मौजे दाळीब तालुका पंचायत समिती उमरगा व जिल्हा परिषद उस्मानाबादचे हद्दिदतील खुली जागा

गाव:- दाळीब गट नंबर ७८४ क्षेत्र ८ हेक्टर ५२ आर आकार १८ रुपये ६५ पैसे त्यापैकी लिहून घेणार यांची जमीन २ हे ६९ आर आकार ५ रु ८९ पैसे आहे या पैकी पुर्व-उत्तर कोप-यातील जागा क्षेत्र पुर्व-पश्चिम ५०.०० मीटर दक्षिणोत्तर ८०.०० मीटर सदरील जागेचे एकुण क्षेत्रफळ ४००० चौरस मीटर.

उ म रा / 2012	
दस्त क्र.	९८४९
पाने	२१७०

Prakash Goroba Kamble



-::यांसी चतुःसिमा-::-

पुर्वेस:-अनिल श्रीपती भालेराव यांची जमीन.

पश्चिमेस:-माझी शिल्लक जमीन.


दक्षिणेस :- माझी शिल्लक जमीन

उत्तरेस :- नॅशनल हायवे नं. ६५.

येणे प्रमाणे चतुःसिमेतील खुली जागा लिहुन देणार यांनी लिहुन घेणार यांच्या कडुन खालील अटीवर भाडेवर घेतली आहे.

- २ सदरील जागा लिहुन देणार यांनी लिहुन घेणार यांच्या कडुन पेट्रोलपंप चालवण्यासाठी भाड्याने घेतले आहे. सदरील भाडे कराराची मुदत २८ वर्ष ११ महिने राहिल सदरील जागेचे भाडे रक्कम रुपये १२,०००/- (अक्षरी बारा हजार रुपये फक्त) प्रति वर्ष नगदी देण्याचे ठरले आहे.
- ३ सदरील भाडे कराराची मुदत दिनांक ११/१२/२०१८ पासुन दिनांक ११/११/२०४७ पर्यंत एकुण २८ वर्ष ११ महिने राहिल.
- ४ सदरील खुली जागा लिहुन देणार यांनी शेजा-यास त्रास होईल असे वर्तन करण्याचे नाही व सदरील खुल्या जागेची लिहुन देणार यांनी निगराणी व देखभाल करण्याचे आहे.
- ५ सदरील खुली जागेचे २८ वर्ष ११ महिनेचे लाईट बिल भरणा लिहुन देणार यांनी स्वतः भरण्याचे आहे लिहुन घेणार यांना त्यांची तोषिस लागु देण्याचे नाही.
- ६ सदरील खुल्या जागेचा फक्त आणि फक्त पेट्रोलपंप चालवण्यासाठीच वापर करावयाचा आहे.
- ७ सदरील खुल्या जागेत दारू व इतर शासकिय प्रतिबंध असलेला कोणताही पदार्थाचा साठा लिहुन देणार यांनी ठेवायचा नाही किंवा कायदयाने ज्या गोष्टीची परवानगी नाही किंवा सरकारी बंदी आहे असा कोणताही धंदा करणार नाही

उ म ग / २०१६	
दस्त क्र.	३६६९
पाने	३१७०



[Handwritten signature]

८ सदरील भाडेपट्याचे शासकिय मुद्रांकशुल्क रुपये १,१२,०००/- व नोंदणीफीस १२०००/-रुपये चा भरणा लिहुन देणार यांनी केलेला आहे.

९ सदरील भाडे पट्याची मुदत संपताच सदरील खुली जागा लिहुन देणार यांनी लिहुन घेणार यांना ज्या परिस्थितीत खुली जागा घेतली होती त्याच परिस्थितीत विना तक्रार परत लिहुन घेणार यांच्या ताब्यात देण्याचे आहे

१० सदरील जागा लिहुन देणार (भाडेकरू)यांनी कोणत्याही पेट्रोलपंप कंपनीस चालवण्यासाठी भाडे करारावर देवु शकतात त्यास लिहुन घेणार यांची संपुर्ण संमती आहे.

११ सदर जागेवर पेट्रोल पंप चालवण्यासाठी लागणारे गोडाऊन व ऑफिस वगैरेचे बांधकाम भाडेपट्टा भाडेकरू यांनी करावयाचे आहे ज्यावेळी कोणत्याही नाहरकत किंवा बांधकाम परवाना लागेल त्यावेळी मी स्वतः सही करून देऊन कोणतीही अडचण लिहुन देणार यांना होऊ द्यावयाची नाही वरील कामास माझी संपुर्ण संमती राहिल.

हे लिहुन दिलो भाडेपट्टा मी राजीखुषीने सहि दिनांक ११ डिसेंबर २०१८ दस्तुर प्रविण फुलचंद गायकवाड उमरगा
लिहुन घेणार

लिहुन देणार

Prakash Goroba

Rajendra Premnath

(प्रकाश गोरोबा कांबळे)

(राजेंद्र प्रेमनाथ गायकवाड)

Kamblam

साक्ष

१-मारुती शिवराम कांबळे

२-गुंडू माणिक कांबळे

रा.दाळीब ता.उमरगा

रा.पुणे ता.पुणे

उ म ग / 2018	
दस्त क्र:	3635
पाने	8770



03 8785 5076
— सामान्य माणसाचा अधिकार

राजेंद्र प्रेमनाथ गावकुवार
Rajendra Premnath Gaikwad

जन्म वर्ष / Year of Birth : 1975
पुरुष / Male

5603 8785 5076

आधार — सामान्य माणसाचा अधिकार



प्रकाश गोरोबा कांबळे
Prakash Goroba Kamble
जन्म तारीख / DOB: 01/11/1953
पुरुष / MALE

4038 9981 1154

माझे आधार, माझी ओळख



गुंडु माणिक कांबळे
Gundu Manik Kamble
जन्म तारीख / DOB: 15/08/1948
पुरुष / MALE

2483 7022 9642

माझे आधार, माझी ओळख



मारुती कांबळे
Maruti Kamble

जन्म वर्ष / Year of Birth : 1951
पुरुष / Male

7655 1045 0179

आधार — सामान्य माणसाचा अधिकार



पता : S/O प्रेमनाथ अंबाजी
गावकुवार, साई बाबा मंदिर जवळ,
जे/१, बक नारत होसिंग, सोसायटी, मुंबई,
बाग, कमाणी, कुर्ला (पश्चिम), मुंबई,
महाराष्ट्र, 400070

Address: S/O Premnath Ambhaji
Gaikwad, Near Sai Baba
Mandir, J/10, Jai Bharat HSG
Soc. Sunder Baug, Kaman,
Kurla (West), Mumbai (Sub
Urban), Maharashtra, 400070

1047
1800 100 1047

help@uidai.gov.in

www.uidai.gov.in

P.O. Box No. 1047,
Bangalore-560 001



पता:
सर्वे नं-464, छत्रपती
शिवाजी विद्यालय जवळ,
तुकाराम नगर, तळवडे, पुणे
शहर, पुणे,
महाराष्ट्र - 412114

Address
servey no-464, near
chattrapati shivaji
vidyalaya, tukaram
nagar, talwade, Pune
City, Pune,
Maharashtra - 412114

1047
1800 100 1047

help@uidai.gov.in

www.uidai.gov.in

P.O. Box No. 1047,
Bangalore-560 001



पता:
S/O: माणिक कांबळे, सर्वे नं
68 हिंसा 1 ए, रेल्वे मार्ग
जवळ, तुकाराम नगर, पुणे
शहर, पुणे,
महाराष्ट्र - 411012

Address:
S/O: Manik Kamble, Sr. No. 68 Hissa 1A,
Near Railway Line, Guleb Nagar, Pune City,
Pune,
Maharashtra - 411012

1047
1800 100 1047

help@uidai.gov.in

www.uidai.gov.in

P.O. Box No. 1047,
Bangalore-560 001



पता : S/O शिवराम, उमर्गा, दांडिव,
दांडिव, डलम्ब, डामनेबाद, महाराष्ट्र,
413604

Address: S/O Shikram, umarga,
Dallimb, Dalimb, Damanebad,
Maharashtra, 413604


Kamble's

1047
1800 100 1047

help@uidai.gov.in

www.uidai.gov.in

P.O. Box No. 1047,
Bangalore-560 001



उमर्गा / 2018	
दस्त क्र.	3445
पाने	6170

869

ळवार, 11 डिसेंबर 2018 1:18 म.नं.

दस्त गोपवारा भाग-1

उमरा

8/90

दस्त क्रमांक: 3869/2018

दस्त क्रमांक: उमरा /3869/2018

बाजार मूल्य: रु. 28,00,000/-

मोबदला: रु. 00/-

भरलेले मुद्रांक शुल्क: रु. 1,12,000/-

नोंदणी फी माफी असल्यास तपशिल :-

1) Fee Adjustment : Fee Adjustment (yashada training) code added for keeping tack of adjusted fees

दु. नि. सह. दु. नि. उमरा यांचे कार्यालयात

पावती: 6303

पावती दिनांक: 11/12/2018

अ. क्र. 3869 वर दि. 11-12-2018

मादरकरणाराचे नाव: प्रकाश गोरोबा कांबळे

रोजी 12:48 म.नं. वा. हजर केला.

नोंदणी फी

रु. 12000.00

दस्त हाताळणी फी

रु. 200.00

डाटा एन्ट्री

रु. 20.00

पृष्ठांची संख्या: 10

दस्त हजर करणाऱ्याची सही:

एकुण: 12220.00

[Signature]
 दुय्यम निबंधक उमरा

उमरागा

दस्ताचा प्रकार: भाडेपट्टा


[Signature]
 Sub Registrar Umarga
 दुय्यम निबंधक उमरागा

उमरागा

मुद्रांक शुल्क: (तीन) कोणत्याही ग्रामपंचायतीच्या हद्दीतील क्षेत्रात किंवा उप-खंड (दोन) मध्ये नमूद न करण्यात आलेल्या अशा कोणत्याही क्षेत्रात.

शिक्षा क्र. 1 11 / 12 / 2018 12 : 48 : 59 PM ची वेळ: (सादरीकरण)

शिक्षा क्र. 2 11 / 12 / 2018 12 : 50 : 31 PM ची वेळ: (फी)





11/12/2018 12:22:47 PM

दस्त गोपबारा भाग-2

उमरा

7070

दस्त क्रमांक:3869/2018

दस्त क्रमांक :उमरा/3869/2018

दस्ताचा प्रकार :-भाडेपट्टा

अनु क्र.	पक्षकाराचे नाव व पत्ता	पक्षकाराचा प्रकार	छायाचित्र	अंगठ्याचा ठसा
1	नाव:प्रकाश गोरोबा कांबळे पत्ता:प्लॉट नं: 0, माळा नं: 0, इमारतीचे नाव: 0, ब्लॉक नं: 0, रोड नं: रा तळवडे पुणे, महाराष्ट्र, पुणे. पॅन नंबर:AVJPK4682N	मालक वय :-65 स्वाक्षरी:-		
2	नाव:राजेंद्र प्रेमनाथ गायकवाड पत्ता:प्लॉट नं: 0, माळा नं: 0, इमारतीचे नाव: 0, ब्लॉक नं: 0, रोड नं: रा मुंदरबाग कमानी कुर्ता प.मुंबई, महाराष्ट्र, मुम्बई. पॅन नंबर:ALGPG7148A	भाडेकरू वय :-43 स्वाक्षरी:-		

वरील दस्तऐवज करून देणार तथाकथित भाडेपट्टा चा दस्त ऐवज करून दिल्याचे कबुल करतात.
शिक्का क्र.3 ची वेळ:11 / 12 / 2018 12 : 54 : 25 PM

ओळख:-

खालील इसम असे निवेदीत करतात की ते दस्तऐवज करून देणा-यानां व्यक्तीशः ओळखतात, व त्यांची ओळख पटवितात

अनु क्र.	पक्षकाराचे नाव व पत्ता	छायाचित्र	अंगठ्याचा ठसा
1	नाव:महारी शिवराम कांबळे वय:67 पत्ता:रा दाळीब ता उमरगा पिन कोड:413606		
2	नाव:गुंडू माणिक कांबळे वय:70 पत्ता:रा पुणे पिन कोड:411012		

शिक्का क्र.4 ची वेळ:11 / 12 / 2018 12 : 56 : 37 PM

शिक्का क्र.5 ची वेळ:11 / 12 / 2018 12 : 56 : 45 PM नोंदणी पुस्तक 1 मध्ये

दुय्यम निबंधक श्रेणी-9

उमरगा EPayment Details.

Sr. Epayment Number
1 MH009238393201819E

Defacement Number
0005054666201819

प्रमाणीत करण्यात येते की, या दस्तामध्ये
एकूण 90 पाने आहेत

दुय्यम निबंधक श्रेणी-9 उमरगा

पुस्तक क्रमांक 9

क्रमांक 3444 - वर नोंदला

११ माहे १२ सन २०१८
3869/2018

दुय्यम निबंधक श्रेणी-9 उमरगा

Know Your Rights as Registrants

1. Verify Scanned Document for correctness through thumbnail (4 pages on a side) printout after scanning.
2. Get print immediately after registration.

For feedback, please write to us at feedback.isaria@gmail.com





Maharashtra State Electricity Distribution Co. Ltd.
Office of the Executive Engineer, Old Administrative Building, Tuljapur
E-mail: - eetuljapur@ho.mahadiscom.in / eetuljapur@gmail.com

Ref. No. EE/TJR/TS/

Date: -

To,
Dy. Executive Engineer,
MSEDCL, O & M Sub-Division,
Lohara

NO = 3639

9 DEC 2021

Pre Audit No.	
------------------	--

Sub: - Administrative Approval & Technical Sanction to

The Estimate Under 1.3 % DDF Scheme (Non Refundable) Technical sanction for Giving power supply to 1 nos. of commercial connection in R/o. Rajendra Premnath Gaikwad at gat no. 784, Dalimb, Tq. Omarga, Dist. Osmanabad

Ref: - Letter from DyEE, No. DyEE/Lohara/TS/1123, dt. 25.11.2021

EE, Tuljapur in consultation with Dy. Manager (F & A), has accorded the Administrative Approval & Technical Sanction to the Estimate as per powers Re delegated vide Letter No. ed distribution Lt -conn sanction/26331 date 18.09.2019

EE/TJR/TS/1.3% DDF/COMM/2021-2022/ 148 Date- 09.12.2021

Amount ₹ 789,957

A) Proposed :-

HT Line: - Highway crossing UG line
DTC : - 25 KVA
LT Line : - NIL

B) Existing DTC : - NA
Existing Load : - NA
Proposed Load : - 0.3kw
Total Load : - 0.3km
DTC No. : - New proposed

C) Connection Type: - AG

Name of Contractor: - Jadhav Electricals and contractors Osmanabad MC No. 36892

The particulars of connection etc are as below:


Sr. No.	Name of Applicant	Village	Load	DTC	HT Line	LT Line
1	Rajendra Premnath Gaikwad at gat no. 784, Dalimb, Tq. Omarga, Dist. Osmanabad	Dalimb	0.3kw	25 KVA	Highway crossing UG line	NIL

Item Code No. 1201					
POLE MOUNTED DISTRIBUTION TRANSFORMER SUB-STATION, 16 KVA, 11/0.433 KV ON RSJ POLE with MCCB Dist.Box					
S.N.	Description of Material	Unit	QTY	RT/U.Rs.	Amt Rs.
1	11 / .433 KV 16 KVA Transformer	No.	1	47150.00	47150.00
2	RSJ POLE 125*100 9 Mtr	No	0	9254.00	0.00
3	Psc pole 9 meter 200kg	No	2	2260.00	4520.00
4	MS Channel 100x50x6 mm	Kg.	100	51.80	5180.00
5	M.S.Channel 75x40x6 mm	kg.	44	51.80	2279.20
6	MS angle 50x50x6 mm	kg.	22	51.80	1139.60
7	M.S.Flat 50 x 6 mm	kg.	24	48.50	1164.00
8	11 kV Pin Insulators with G.I. Pins	NO.	3	135.00	405.00
9	Strain Hardware for Dog0.1 or Equ.AAAC.	No	3	322.00	966.00
10	L.T.Dist.Boxes 25/63 KVA with MCCB	No.	1	10800.00	10800.00
11	L.As. 11 KV (Gapless type) with disconnector	Set.	1	1268.00	1268.00
12	H.T.Stay Set	No	2	598.00	1196.00
13	G.I.Stay Wire 7/4mm(8 SWG)	kg.	25	57.45	1436.25
14	Earthing Sets H.T	No.	3	342.00	1026.00
15	11KV H.G.Fuses	Set	1	1964.00	1964.00
16	11KV A.B Switch, 400 A	No	1	9240.00	9240.00
17	Danger Board in yard.	No.	2	50.00	100.00
18	G.I.Wire 8 SWG/ 6 SWG	Kg.	25	57.40	1435.00
19	G.I.Barbed Wire 'A' type.	kg.	15	64.27	964.05
20	Concreting ration 1:3:6	CMT	2	3027.00	6054.00
21	Painting/Hardware & support with numbering of pole	L.S.	1	225.00	225.00
22	DTC Metring with Box, single core L.T. XLPE cable (16 sq.mm., 120 mtr length) and other allied material.	No.	1	7514.00	7514.00
23	Sundries	L.S.	1	810.00	810.00
	Cost of material				106836.10


Assistant Engineer
Turori

Note :-

1. All the material required for the above work may be procured by the applicant. No materials will be provided By MSEDCL
 2. All the material should be as per the company, specification & standard & should be inspected by the Executive Engineer or his authorized representative before commencement of the work.
 3. The work should be executed through a licensed electrical contractor & execute the agreement at Division level before commencement of the work.
 4. The applicant has to bear the damage/compensations due to accident occurred in the course of erection of the above work. All other Levies/duties if any will be paid by applicant.
 5. The fees towards the inspection of above assets by the electrical inspector, should be paid by the applicant.
 6. The guarantee period for above asset is about five years & any damages during the guarantee period will be on a applicant's account.
 7. A separate register should be maintained at Subdivision level of such assets observing guarantee period.
 8. The separate register should be maintained for furnishing actual itemwise material with as per Sanctioned estimate, utilized by the applicant.
 9. The infrastructure/Assets completed by the agency should be inspected by SDO and Commissioned as per rule.
 10. The work completion report should be done as soon as a release of connection from concerned SDO.
 11. The firm quotation of above Estimate may please be issued as per schedule of charges at Sub-Divisional Level.
 12. The Supervision Charges at a rate of 1.3 % of the normative charges for Rs. 8,703 under a DDf scheme may please be recovered before starting work.
- Note :- GST @ 18% to be recovered on 1.3% Supervision Charges. 1,567


Executive Engineer
MSEDCL, O & M Division
Tuljapur

Copy s.w.r. to: - The Superintending Engineer, MSEDCL, O & M Circle, Osmanabad.

Copy to: -1) The Assistant Engineer, MSEDCL Lohara

2) The Dy. Manager (F&A), MSEDCL, O & M Division, Tuljapur.

3) Rajendra Premnath Gaikwad at gat no. 784, Dalimb, Tq. Omarga, Dist. Osmanabad

Assistant engineer
7875762246

Turori Section Office, Tuljapur
Osmanabad.

AE/TUR/20-21/

Date:-

To,
The Dy. Executive Engineer,
Maharashtra State Electricity Distribution Company Ltd,
O & M sub/Division Office, Omerga.

Sub.:-Administrative approval for the estimate under 1.3% DDF scheme New 1 nos of PWV connection in R/o Sarpanch Gram panchayat Malgi at Malgi tal omerga under Turori section office.

With reference to the above mentioned subject please find enclosed here with the for the estimate under 1.3% DDF scheme New 1 nos of PWV connection in R/o Sarpanch Gram panchayat Malgi at Malgi tal omerga under Turori section office.


The following works are involved in the proposal.

Sr. No.	Description	Amount
A	LT LINE	32597.20
B	11 kv line	0.00
C	1.3% Supervision charges	424
	TOTAL	33021


Assistant Engineer
Turori

The Estimate Under 1.3 % DDF Scheme (Non Refundable) Technical sanction for Giving power supply to 1 nos. of commercial connection in R/o. Rajendra Premnath Gaikwad at gat no. 784, Dalimb, Tq. Omarga, Dist. Osmanabad

Sr. No.	Particulars	Unit	Qty	Amount (Rs.)	
1	Pole Mounted Distribution Transformer- 25 KVA 11/0.433 KV on 9 mtr PSC Pole (As Per Sheet -1)	No.	1.00	127584.39	
2	11Kv Highway crossing 11Kv 3 C 300 Sqmm XLPE underground cable and LT cable for service connection (As Per Sheet -2)	Km	1.00	454550.13	
3	Total Material Cost			582134.52	
4	Labour charges on Material Cost @ 15% on "Sr. No. 3"			87320.18	
5	Total Estimate Cost including Overheads (Sr. No. 4 + 3)			669455	
6	GST @18%			120501.85	
7	Total Estimate Cost (sr no 6 + sr no 5)			789956.54	
8	1.3% Supervision Charges [(SR NO 5)			8702.91	
9	GST @ 18 % on 1.3% Supervision charges on sr no 8			1566.52	
10	TOTAL CHARGES TO BE RECOVERED FROM CONSUMER			10269.44	
Sr.No.	Particulars	HT Line	DTC	LT Line	Load
1	The Estimate Under 1.3 % DDF Scheme (Non Refundable)Teachnical sanction for Giving power supply to 1 nos. of coomercial connection in R/o.Rajendra Premnath Gaikwad at gat no. 784, Dalimb, Tq. Omarga, Dist. Osmanabad	Highway crossing UG line	25 KVA	NIL	0.3kw


Executive Engineer
MSEDCL, O & M Division
Tulapur

Name of Agency: -

Jadhav Electricals and contractors Osmanabad MC No. 36892

.

.

The Estimate Under 1.3 % DDF Scheme (Non Refundable) Technical sanction for Giving power supply to 1 nos. of commercial connection in R/o. Rajendra Premnath Gaikwad at gat no. 784, Dalimb, Tq. Omarga, Dist. Osmanabad

Estimate for Pole Mounted Distribution Transformer- 25 KVA, 11/0.433 KV on 9 Mtr PSC (200Kg) with MCCB Dist. Box

Sr. No.	Description of Material	Unit	Qty.	Rate/Unit Rs.	Amount (Rs.)
1	11 / .433 KV 25 KVA Transformer	No.	1	48800.00	48800.00
2	RSJ 116x100, 9 m long	No	2	9073.00	18146.00
3	MS Channel 100x50x6 mm	Kg.	100	50.78	5078.00
4	M.S Channel 75x40x6 mm	kg.	44	50.78	2234.32
5	MS angle 50x50x6 mm	kg.	22	50.78	1117.16
6	M.S.Flat 50 x 6 mm	kg.	24	48.20	1156.80
7	11 kV Pin Insulators with G.I. Pins	NO.	3	135.11	405.32
8	Strain Hardware for Dog0.1 or Equ.AAAC.	No.	3	321.66	964.98
9	L.T Dist Boxes 25/63 KVA with MCCB	No.	1	15000.00	15000.00
10	L.As 11 KV (Gapless type) with disconnector	Set.	1	1100.00	1100.00
11	H.T Stay Set	No	4	586.66	2346.64
12	G.I.Stay Wire 7/4mm(8 SWG)	kg.	25	56.32	1408.00
13	Earthing Sets H.T	No.	3	335.51	1006.53
14	11KV H.G.Fuses	Set.	1	1780.00	1780.00
	11KV A.B. Switch	No.	1	8400.00	8400.00
15	Danger Board In yard.	No.	2	50.00	100.00
16	G.I.Wire 8 SWG/ 6 SWG	Kg.	25	56.27	1406.75
17	G.I.Barbed Wire 'A' type.	kg.	15	63.01	945.15
18	Concreting ration 1:4:8	CMT.	2	2596.08	5192.16
19	Painting/Hardware & support with numbering of pole	L.S.	1	219.57	219.57
20	DTC Metring with Box, single core L.T. XLPE cable (16 sq.mm, 120 mtr length) and other allied material.	No.	1	10007.01	10007.01
21	Sundries	L.S.	1	770.00	770.00
	Cost of material				127584.39

Rajendra
Executive Engineer
MSEDCL, O & M Division
Tuljapur

महाराष्ट्र राज्य विद्युत वितरण कंपनी मर्या

दूरध्वनी क्र-0२४७१-२२४५८५



email: eetuljapur@ho.mahadiscom.in
website: www.mahadiscom.in

कार्यालय
कार्यकारी अभियंता
विभागीय कार्यालय, शासकीय
विश्रामगृहा समोर] तुळजापूर
तुळजापूर- ४१३५०६

जा.क्र./काय/तू'पूर/मासं/ ०८/२०

प्रती,

कार्यकारी अभियंता,
महावितरण विभागीय,
कार्यालय शहर सांगली.

No 089

दि. 25 SEP 2020

विषय:- दोषारोप पत्रासंबंधीची कागदपत्रे मिळणेबाबत.

संदर्भ:- अमोल अभंग जाधव, तंत्रज्ञ भ.नि.नि.क्र. २७०६६०१ यांचा दि. १४/०९/२०२० रोजीचा अर्ज.

उपरोक्त विषयास अनुसरून या विभागांतर्गत उपविभाग लोहारा शाखा जेवळी येथे कार्यरत असलेले श्री.अमोल अभंग जाधव, तंत्रज्ञ भ.नि.नि.क्र. २७०६६०१ यांनी सादर केलेला दोषारोप पत्रासंबंधीची कागदपत्रे मिळणेबाबतचा अर्ज या सोबत जोडून पाठवीत आहोत.

आपल्या माहिती व पुढील योग्य त्या कार्यवाहीस्तव सादर.

सोबत:- संदर्भीय अर्जाची प्रत

प्रत स्वाना:-

उपकार्यकारी अभियंता, महावितरण उपविभाग उमरगा.

कार्यकारी अभियंता,
महावितरण, विभागीय कार्यालय,
तुळजापूर.

The Estimate Under 1.3 % DDF Scheme (Non Refundable) Technical sanction for Giving power supply to 1 nos. of commercial connection in R/o. Rajendra Premnath Galkwad at gat no. 784, Dalimb, Tq. Omarga, Dist. Osmanabad

11Kv Highway crossing 11Kv 3 C 300 Sqmm XLPE underground cable and LT cable for service connection

Sr. No.	Description of Material	Unit	Qty.	Rate/Unit Rs.	Amount (Rs.)
1	RSJ 116x100, 11 m long	No.	4	11311	45244
2	RSJ 116x100, 10 m long	No.	4	10283	41132
3	M.S. Flats (50 X 10mm)	Kg.	60	48.5	2910
4	MS Channel 100x50x6 mm	Kg.	150.6	51.8	7801.08
5	M.S. Channel 75x40x6 mm	Kg.	72	51.8	3729.6
6	MS angle 50x50x6 mm	Kg.	22	51.8	1139.6
7	Strain Hardware for Dog0.1 or Equ.AAAC.	No.	6	322	1932
8	Disc Insulator 11 KV 7000 KG.	No.	6	344	2064
9	XLPE Cable 11 KV, 3 C / 300 mm sq.	Rmt	214	1194	255516
10	R.C.C. Pipe 150 mm 2 M	No	10	572	5720
11	Black Bituminous Paint	Ltr.	4	85	340
12	Red Oxide Paint for 2 coats	Ltr.	10	85	850
13	Aluminium Paint for 1 coat	Ltr.	16	113	1808
14	11 kV heat shrinkable Outdoor termination joint kit for 3 C X 300 sqmm	No.	4	2030	8120
15	Sand	Cmt	50	222	11100
16	H.T. Stay Set	No.	4	598	2392
17	G.I. Stay Wire 7/4mm (8 SWG)	Kg.	50	57.45	2872.5
18	Earthing Sets H. T	No	4	342	1368
19	G.I. Wire 8 SWG/ 6 SWG	kg.	30	57.4	1722
20	G.I. Barbed Wire 'A' type.	kg.	15	64.27	964.05
21	Danger Board in yard.	No.	4	50	200
22	Concreting ration 1:3:6	Cmt.	4	3027	12108
23	Mics. For XLPE U/G Cable	LS.	2	1050	2100
24	11KV A.B. Switch, 400 A	Set	1	9240	9240
25	11 kV Pin Insulators with G.I. Pins	No.	6	135	810
26	L.A.s. 11 KV (Gapless type) with disconnector	Set.	2	1268.00	2536
27	11KV H.G.Fuses	Set.	2	1964.00	3928
28	Providing HDPE	Mtr	12	1050	12600
29	AAAC 55SQMM	Mtr	10	28.56	285.6
	LT XLPE Armoured Cable 3 1/2C X 95 Sq mm	Rmt	30.00	239.08	7172.40
	Misc. (Bricks, sand, termination kit and etc.)	LS	0.10	24153.00	2415.30
30	Sundries	LS	3	810	2430
	Cost of Material				454550.13

P. B. J.
Executive Engineer
MS&DCL O & M Division
Tuljapur

Certificates:-

1. The Work is carried out as per Rules & Regulations of MSEDCL & in time.
2. The works are erected at proper location and as per joint survey & work order.
3. No T & P provided to agency for above said work.
4. The work started on dt. & completed on dt.