



# भारतीय राष्ट्रीय राजमार्ग प्राधिकरण

(सड़क परिवहन और राजमार्ग मंत्रालय, भारत सरकार)

## National Highways Authority of India

(Ministry of Road Transport and Highways, Government of India)



परियोजना कार्यान्वयन इकाई: कृष्णागिरी  
Project Implementation Unit : Krishnagiri

#२५९/१ सेलम मार्ग, के ए केसी पेट्रोल बंक के पास, कृष्णागिरी, तमिलनाडु - ६३५००१

# 259/1, Salem Main Road, Near KAKC Petrol Bunk, Krishnagiri ( Tamil Nadu ) - 635 001.

दूरभाष / Tel: 04343 234250, ईमेल / Email : nhaikrishnagiri@gmail.com, kri@nhai.org वेबसाइट : www.nhai.gov.in

No. NHAI/11013/ TWAD/2024/PIU-K'giri/ 610

01<sup>st</sup> March 2024

### Invitation of Public Comments

Sub: NHAI, PIU, Krishnagiri- laying of Drinking water pipeline from km.91/670 to km.91/910 (LHS) and road crossing at km.91/670 on Krishnagiri Walajahpet section of NH-48 by Executive Engineer, Pallikonda Town Panchayat, Vellore District – Invitation of Public Comments - Reg.

The proposal is regarding permission for laying of Drinking water pipeline from km.91/670 to km.91/910 (LHS) and road crossing at km.91/670 on Krishnagiri Walajahpet section of NH-48 by Executive Engineer, Pallikonda Town Panchayat, Vellore District submitted to this office on 20.02.2024.

2. The details of the proposal is as under:

- The above proposal pertains to the laying of Drinking water pipeline from km.91/670 to km.91/910 (LHS) and road crossing at km.91/670 on Krishnagiri Walajahpet section of NH-48.
- The details of ROW available along with the distance at which Water Pipeline is proposed to lay from the centerline is as follows:

SI no.	Description			Length in mtrs	ROW in Meters		Distance of Water Pipeline from centreline of the Main Carriageway	
	From	To	side		LHS	RHS	LHS	RHS
1	91.670	91.910	LHS	240	23.50	23.50	22.50	-
Total length				240				
Road Crossing km.91.670								

- Executive Engineer, Pallikonda Town Panchayat, Vellore District has proposed to laying of drinking water pipeline as under:

4.11.2024

Sl.no.	Pipe Dia	Chainage		Length	said		Depth
		From	To		LHS	RHS	
A. Along the Road							
1	200MM.dia DI pipe	91.670	91.910	240	LHS	-	Along the road by open trench method duly keeping the top of the casing at 1.20 m below the top of sub grade level
Total Length				240			
B. Road Crossing							
1	200MM dia DI pipe (Encase 350mm dia DI Pipe)	91.670					Road crossing by HDD Method duly keeping the top of the pipe at 1.65 m from bottom of crust.

3. Executive Engineer, Pallikonda Town Panchayat, Vellore District has furnished an undertaking to indemnify the concerned agency in coordination with NHAI, against all damages and claims if any, due to the digging of trenches for laying of water pipeline. Further, the applicant has furnished undertaking that they will adopt HDD method wherever, the available width of ROW is less than 15m and undertaking not to damage other utility, if damaged then to pay the losses either to NHAI or to the concerned agency. Further, the applicant has furnished undertaking that the HDD method will be adopted for crossing of road at grade separators at grade junction and wherever required and in the built up areas as per the instruction of NHAI officials.

4. As per the guidelines issued by the Ministry vide letter No.RW/NH33044/29/2015/ S&R(R) dated 22.11.2016, the proposal submitted by Commissioner, Ranipet Municipality will be made available for 30 days seeking public

*Urthum*

comments/objections and the comments shall be furnished within 30 days from the day of closure of public objections.

In view of the above, comments of the public on the above proposal are invited any may be sent to the below mentioned address:

The Project Director,  
National Highways Authority of India,  
Project Implementation Unit,  
No.259/1, Salem Main Road,  
Near KAKC Petrol Bunk,  
Krishnagiri (T.N) - 635 001.

Yours faithfully,

*G. Ramesh*  
01/03/2017  
(G. Ramesh)

Project Director

Copy to:

1. Regional Officer, NHAI, Chennai Region, Chennai – for kind information.
2. NHAI website.
3. The NIC, New Delhi- for uploading in the Ministry's website.