

By Email/Post



सत्यमेव जयते

Government of India

Ministry of Road Transport & Highways

Regional Office Gujarat, UT of Dadra & Nagar Haveli and Daman & Diu

4th floor, Block No 14, New Sachivalaya, Regional Office, Gandhinagar, Gujarat 382010

Phone No. 079-23240091, Phone/Fax No.079-23220705 Email-rogandhinagar@yahoo.in

F.No. RW/GNR/NH/US/OC/NOC/35/2019/ 339

Dated: 3rd June 2019

Invitation of Public Comments

Subject: Proposal for permission for overhead crossing of 220 KvD/c Asoj-IOCL line near Sankarda Village between km 83/650 to 83/600 (between km 16/0 and 17/0) on NE-1.

The proposal is regarding permission for erection of 220KV overhead electric line crossing from km 83/650 to km 83/600 of NE-1 was submitted to this office by the Project Director NHAI, PIU Ahmedabad vide No NHAI/PIU.Ahmedabad/NE-1/Per.2018/2019/1383 dated 27.05.2019 for approval of Highway Administration.

2. The recommended proposal of PD Ahmedabad has been examined by this office and detailed features of the proposals are as under:

Crossing type and purpose	Electric overhead crossing
NH NO	NE-1
Chainage of NH	Km 83/650 to km 83/600
ROW of NH at crossing location	90 mtr
Distance of the tower/ pole of overhead crossing from extreme edge of road land (ROW)	44.5 mtr (LHS) and 66.5 mtr.(RHS)
Methodology for laying power supply line	Overhead line
Span of overhead line crossing NH	205 mt
Angle of crossing with NH	78° 9"
Tower/pole height	51.21 mt
Vertical clearance from FRL to lowest cable of overhead crossing	16 mt
Whether height clearance criterial is satisfied as per Ministry's guidelines NO. NHIII/P/20/77 dated 08.04.1982	Yes. For 220 KV line the minimum vertical clearance is 7015 mm and for instant case it is 16000 mm

3. As per the guidelines issued by the Ministry vide letter No.RW/NH-33044/29/2015/ S&R(R) dated 22.11.2016 the application submitted by the applicant i.e. the Executive Engineer (Const), GETCO, Jambuva will be made available public comments for seeking claims and objections (on grounds of inconvenience, safety and general public interest) and the may be submitted to below mentioned address within 30 days from the day of uploading.

4. This issues with approval of Highway Administration Gujarat.

Address:

The Superintending Engineer cum Regional Officer,
Gandhinagar
Ministry of Road Transport & Highways,
New Sachivalaya, Block No. 14 , 4th Floor, Gandhinagar,
Gujarat 382010

Yours Sincerely,

Encl: As Above.


(Ganesh Shelar)
Asstt. Executive Engineer
For Regional Officer, Gandhinagar

Copy to:

1. The NIC, New Delhi - for uploading in the Ministry's website.
2. The Project Director, NHAI, PIU-Ahmedabad- for information.
- ✓ 3. The Executive Engineer (Const). GETCO, Jambuva.