



Government of India

Ministry of Road Transport & Highways

Office of the Chief Engineer-Regional Officer

No. 32, 2nd Floor, KSCFL Building,

D. Devaraj Urs Road, (Race Course Road), BENGALURU-560 001

Email: robengaluru@gmail.com; Telephone: 080-22267457, 080-22265765

No. RW/BNG/PER.CASES/BNG. DVN/2020

Dated: 12.02.2021

Notice Inviting Public Comments on proposal seeking permission for laying of XLPE HT UG cable on RHS of NH 234 from Km 381.500 to Km 387.160 for a total length of 5.66 Kms. by M/s. Klene Paks Ltd., Bangalore through open trench method.

Reference: The Executive Engineer, NH Division, Bengaluru letter Nos. EE/NHD/BNG/AE-1/Klene/2020-21/2210-12 dated 02.02.2021.

The Executive Engineer, NH Div, Bengaluru vide letter cited under reference above (Annexure I), has submitted the proposal seeking Permission for laying of XLPE HT UG cable on RHS of NH 234 from Km 381.500 to Km 387.160 for a total length of 5.66 Kms. by M/s. Klene Paks Ltd., Bangalore through open trench method.

2. The proposal has been examined as per Ministry's Guidelines vide letter no. RW/NH-33044/29/2015/S&R(R) dated 22.11.2016 and is generally found in order.

3. In view of above, as per Ministry's said guidelines Para 4, public comments are invited on the above proposal making claims and raising objections (on grounds of public inconvenience, safety and general public interest) if any within 30 days on public portal i.e., website of Ministry of Road Transport and Highways (morth.nic.in) in Form-A (copy enclosed) for "Accommodation of Public and Industrial Utility Services along and across National Highways".

Comment Inviting Authority

The Chief Engineer-Regional Officer

Ministry of Road Transport & Highways

No.32, 2nd Floor, Race Course Road, Bangalore-560 001


Email: robengaluru@gmail.com; Telephone: 080-22217457, 080-22105765

Enclosed: As above.

- Copy to : (i) The Senior Technical Director, NIC, Transport Bhawan, New Delhi- 110001 for uploading on Ministry's website.
- (ii) The Director, M/s. Klene Paks Ltd., 7th Mile, Arekere Gate, L&T South City Road, Bennerghatta Road Bangalore - 560076 for information.


(S. Sadananda Babu)
Superintending Engineer

For Chief Engineer - Regional Officer


(S. Sadananda Babu)
Superintending Engineer
For Chief Engineer - Regional Officer

ಕಾಯ್ದೆ ನಿಯಂತ್ರಣ ಅಭಿಯಂತರರವರ
ಕಛೇರಿ ರಾಷ್ಟ್ರೀಯ ಹೆದ್ದಾರಿ ವಿಭಾಗ,
ಬೆಂಗಳೂರು.

Annexure 1



Office of the Executive Engineer
National Highways Division, ,
No.13/4 , 4th Floor CFC
Building Nrupathunga Road
Bangalore -560001
Ph No -080-22211207

e-mail-
executive_engi@yahoo.com

ಕರ್ನಾಟಕ ಸರ್ಕಾರ

No.EE / NHD/BNG/AE-1/klene/2020-21

/2210-12

Date- 02-02-2021

To,

The Chief Engineer (RO),
MoRT&H, No.32, 2nd Floor,
KSCFL Building,
D.Devaraj Urs Road (Race course Road)
Bengaluru-560001.

Sir,

O/o. THE CE-RO
MORT&H, BENGALURU
Diary No.....2409.....
Date.....04/02/21.....

- Sub:** Request to issue permission for laying of HT UG cable from 66/11 Kv Manchenahalli substation to Newly constructed industry M/s Klene Paks Ltd. Bandammana Halli (v), Nandi(H), Poshettihalli(P), Chikkaballapura on NH-234 Reg
- Ref:** 1.This office letter no.1948-50 dated:06.01.2021
2.Cheif Engineer-Regional Officer, MoRTH, Bengaluru letter no.1207 dated:22.01.2021
3.Assistant Executive Engineer, National Highway sub division, C.B.Pura letter no.208 dated:29.01.2021

Adverting to the above, please find herewith the compliance for the objections received from the Chief Engineer-Regional Officer, MoRTH, Bengaluru vide letter under ref(2). The proposal is re-examined by Assistant Executive Engineer, National Highway Sub-Division C.B.Pura in view of the objections and complied vide letter under ref(3). Point wise details for the objections are as follows:

Sl No	Objections	Compliance
a	Keeping in view of the future development of National Highway at the above-mentioned stretch and available ROW, the applicant may be suggested to explore alternate route for laying of HT UG cable	AEE, NHSD, C.B.Pura has inspected the above site and found that there is no alternate route for laying of HT UG cable other than the above said stretch.
b	Linear drawing showing existing ROW, carriageway along with width, HT UG cable and cross-sectional drawing showing all relevant details of every 1 Km needs to be submitted	The drawing showing existing ROW, carriageway along with width, HT UG cable and cross-sectional drawing are enclosed for kind reference.
c	Keeping in view of the safety of the NH traffic and public, measures such as markers, signages etc. to be provided by the applicant need to be submitted along with undertaking for the same.	Undertaking from the applicant is enclosed.

Yours faithfully,

Executive Engineer,
NH Division, Bengaluru

FORM A

Form for seeking claims and objections (on grounds of public inconvenience, safety and general public interest) on the application for Accommodation of Public and Industrial Utility Services along and across National Highways.

Subject: Permission for laying of XLPE HT UG cable on RHS of NH 234 from Km 381.500 to Km 387.160 for a total length of 5.66 Kms. by M/s. Klene Paks Ltd., Bangalore through open trench method - Reg.

The claims and objections (on grounds of public inconvenience, safety and general public interest) by the general public needs to be given within 30 days of uploading the online application for comments.

Sl. No	Item	Details
1	Name of the person who is desiring to give claims and objections (on grounds of public inconvenience, safety and general public interest)	
2	Address of the person	
3	Details of the application for Accommodation of Public and Industrial Utility Services along and across National Highways against which claims and objections are being given (name of applicant and other details like site address etc.)	
	g) Application No.	
	h) Name of applicant (who applied to Accommodation of Public and Industrial Utility Services along and across National Highways)	
	i) Details of Application	
4	The claims and objections (on grounds of public inconvenience, safety and general public interest)	

NH-23411KV HT UG CABLE LINE LAYING AND CROSS SECTION

5.66 MTRS

CH 387.160

COWRIBIDANUR

CH 381.500

RHS

LHS

UTILITY CORRIDOR- 0.5MTR

DRAIN- 1MTR

PAVED SHOULDER-2.5MTRS

CARRIAGE WAY- 3.5 MTRS

CARRIAGE WAY- 3.5MTRS

PAVED SHOULDER- 2.5MTRS


DRAIN- 1 MTR

UTILITY CORRIDOR-0.5MTR

15MTRS ROW

UTILITY CORRIDOR	PAVED SHOULDER	MAIN CARRIAGE WAY	MAIN CARRIAGE WAY	PAVED SHOULDER	UTILITY CORRIDOR
0.5M	2.5 MTRS	3.5 MTRS	3.5 MTRS	2.5 MTRS	0.5M

ANNEXURE-B		
SL. NO.	STARTING CHAINAGE	ENDING CHAINAGE
1.	CH381.500	CH387.160



For KLENE PAKS LTD.

Managing Director

FILLING
CSB
SUB GRADE

Executive Engineer
N.H. Division, Bangalore

FILLING
CSB
SUB GRADE

Assistant Executive Engineer
National Highway Sub-Division
Chikkaballapur-582101