



# भारतीय राष्ट्रीय राजमार्ग प्राधिकरण

(सड़क परिवहन एवं राजमार्ग मंत्रालय, भारत सरकार)

National Highways Authority of India

(Ministry of Road Transport & Highways, Govt. of India)

क्षेत्रीय कार्यालय-पश्चिम उ०प्र०, लखनऊ

Regional Office - West UP, Lucknow.

3/248, विशाल खण्ड, गोमती नगर, लखनऊ-226010 (उ.प्र.)

3/248, Vishal Khand, Gomti Nagar, Lucknow-226010 (UP)

दूरभाष / Phone : 0522-4960291

टेलीफैक्स / Fax : 0522-4950680

ई-मेल / E-mail : rowestup@nhai.org

rowestup@gmail.com

वेबसाइट / Website : www.nhai.gov.in

19001/1/RO-W-UP/NH-232A/Km.54.184/OH/1007/1015

Dated: 11.11.2021

## Invitation of Public Comments

**Sub: Permission for overhead crossing NH-232A (Unnao - Lalganj) 132 KV Sareni - Raghuraj Singh TSS Line at Ch.54.184 - reg.**

The Authorized Signatory M/s EE, UPPTCL, Raibareilly has submitted the proposal for permission for overhead crossing NH-232A (Unnao - Lalganj) 132 KV Sareni - Raghuraj Singh TSS Line at Ch.54.184 in the State of Uttar Pradesh.

2. From the submitted proposal, it is seen that the position of Tower is outside of NH ROW. Length of crossing Span is 198m & Towers are at a distance of 83.67m & 86.63m from either side of NH boundry while height of towers is 42.22m in both side. Vertical Clearance between road level & the lowest conductor is 31.03m. Width of available ROW is 49.50m.

3. As per the guidelines, issued by the Ministry vide OM No.RW/NH-33044/29/ 2015/ S&R(R) dated 22.11.2016, the application shall be put out in the public domain for 30 days for seeking claims and objections (on grounds of public inconvenience, safety and general public interest).

4. In view of the above, comments of the public on the above application is invited to the below mentioned address, which should reach by this office within 30 days from the date of publication beyond which no comments shall be entertained.

**The Chief General Manager cum Regional Officer,  
National Highways Authority of India  
Regional Office, UP-West, Lucknow  
3/248, Vishal Khand, Gomti Nagar  
Lucknow-226 010**

This issues with the approval of RO-West (UP).

Encl: As above.

(Roopak Jain)  
Dy. Manager(T)  
For RO-West, UP

### Copy to:

1. Web Admin, NHA-HQ- with request for uploading on the NHA website.
2. The Technical Director, NIC, Transport Bhawan, New Delhi- with request for uploading on the Ministry's website.
3. The Authorized Signatory M/s EE, UPPTCL, Raibareilly, U.P. for information.
4. The PD, PIU-Kanpur for information.

*"Building a nation, not just Roads."*

मुख्यालय : प्लॉट सं० जी-5 एवं 6, सेक्टर-10, द्वारका, नई दिल्ली - 110 075, दूरभाष : 91-11-25074100/200

Head Office : Plot No. G-5 & 6, Sector - 10, Dwarka, New Delhi - 110 075 Phone : 91-11-25074100/200



### CHEK LIST

1. National Highway Number : NH – 232A
2. Name of Crossing : UNNAO - LALGANJ
3. Crossing at Chainage : 54.184 KM UNNAO – LALGANJ NH near village – Keshuli
4. Position of towers : Outside the ROW of NH
5. Crossing Span : 198M
6. Clearance over the road level : 31.03 M
7. Angle of road crossing :  $85^{\circ} 42'01''$
8. Appox. Distance from NH : AP No.13, DC+10 = 83.67 M.  
Boundary to center of tower : AP No.14 , DC+10 = 86.63 M
9. Perpendicular distance from center : AP No.13, DC+10 = 100.97 M.  
of tower to center of road : AP No.14 , DC+10 = 97.03 M
10. Protection of assembly to the line : Yes, the transmission line is protected  
instantaneously by high speed protection relays  
with carrier equipment.
11. No. of stay required : No Required
12. Minimum Factor of Safety : 2.0 (Normal condition)
13. Size of power conductor mm. : ACSR Panther (Conductor dia.30/3.00 Al. +  
7/3.00 mm Steel for 2 Phases.
14. Size of OPGW : 12 mm. OPGW

*Salgankel*  
RS/PL

*SDO*

*SDO*  
अधिशायी अभियन्ता  
विद्युत पारेषण खण्ड  
उ०प्र०पावर ट्रान्समिशन कारपोरेशन लि०  
रायबरेली

*U*  
Project Director  
National Highways Authority of India  
P.I.U., Kanpur