



भारतीय राष्ट्रीय राजमार्ग प्राधिकरण

(सड़क परिवहन एवं राजमार्ग मंत्रालय, भारत सरकार)

National Highways Authority of India

(Ministry of Road Transport & Highways, Govt. of India)

क्षेत्रीय कार्यालय-पश्चिम उ०प्र०, लखनऊ

Regional Office - West UP, Lucknow.

3/248, विशाल खण्ड, गोमती नगर, लखनऊ-226010 (उ.प्र.)

3/248, Vishal Khand, Gomti Nagar, Lucknow-226010 (UP)

19001/1/RO-W-UP/NH-709A/22.864/765KV/771

दूरभाष / Phone : 0522-4960291

टेलीफैक्स / Fax : 0522-4950680

ई-मेल / E-mail : rowestup@nhai.org

rowestup@gmail.com

वेबसाइट / Website : www.nhai.gov.in

Dated: 21.06.2021

Invitation of Public Comments

Sub: Proposal for permission of overhead crossing of NH-709A (Garhmukteshwar-Meerut Road) at Chainage 22.864 km Near Village- Hasanpur Kalan, Tehsil-Mawana, District-Meerut for construction of LILO of 765KV SC Gr. Oida-Hapur Transmission Line-reg.

The Chief Executive Officer, Power Grid Meerut-Simbhawali Transmission Limited, Meerut has submitted the proposal for the permission of overhead crossing of NH-709A (Garhmukteshwar-Meerut Road) at Chainage 22.864 km Near Village-Hasanpur Kalan, Tehsil- Mawana, District-Meerut for construction of LILO of 765KV SC Gr. Oida-Hapur Transmission Line.

2. From the submitted proposal, it is seen that structures (Transmission Towers) on either side are being erected at distance of 116.13m & 81.71m respectively from either side of NH boundary. Crossing span of the structure is 242.83m. Further, the minimum vertical clearance of 23.97m between the lowest conductor of the proposed line and NH carriageway shall be maintained. However, the proposed transmission line shall be crossing the National Highway at 72° angle.


3. As per the guidelines, issued by the Ministry vide OM No.RW/NH-33044/29/2015/ S&R(R) dated 22.11.2016, the application shall be put out in the public domain for 30 days for seeking claims and objections (on grounds of public inconvenience, safety and general public interest).

In view of the above, comments of the public on the above application is invited to the below mentioned address, which should reach by this office within 30 days from the date of publication beyond which no comments shall be entertained.

The General Manager cum Regional Officer,
National Highways Authority of India
Regional Office, UP-West, Lucknow
3/248, Vishal Khand, Gomti Nagar
Lucknow-226 010

This issues with the approval of RO-West (UP).

Encl: As above.


(Anuj Kumar Singh)
Manager (T)
For RO-UP (West)

Copy to:

1. Web Admin, NHAI-HQ- with request for uploading on the NHAI website.
2. The Technical Director, NIC, Transport Bhawan, New Delhi - with request for uploading on the Ministry's website.
3. The Chief Executive Officer, Power Grid Meerut-Simbhawali Transmission Limited, Meerut for information.
4. The Project Director, NHAI, PIU-Moradabad for information.

"Building a nation, not just Roads."

मुख्यालय : प्लॉट सं० जी-5 एवं 6, सेक्टर-10, द्वारका, नई दिल्ली - 110 075, दूरभाष : 91-11-25074100/200

Head Office : Plot No. G-5 & 6, Sector - 10, Dwarka, New Delhi - 110 075 Phone : 91-11-25074100/200

**LILO OF 765 KV GR. NOIDA – HAPUR TRANSMISSION LINE AT 765/400 KV
GIS, MEERUT**

POWERGRID MEERUT SIMBHAVALI TRANSMISSION LIMITED

**QUESTIONNAIRE FOR ROAD CROSSING FOR CONSTRUCTING OF LILO OF 765 KV GR. NOIDA –
HAPUR TRANSMISSION LINE AT 765/400 KV GIS, MEERUT**

S. No.	QUESTIONNAIRE	(AP21A – AP22)
1-	Name of the Road	NH-709A GARH MUKHTESHWAR - MEERUT ROAD
2-	Name of the Line (Proposed Line)	LILO OF 765 KV GR. NOIDA – HAPUR TRANSMISSION LINE AT 765/400 KV GIS, MEERUT
3-	Crossing Span	242.83 mtrs
4-	Crossing Angle	72° 00' 00"
5-	Type of supporting structure (Tower Type)	D+0 & D+0
6-	Distance of the Tower from the nearest road edge	100.41 & 134.83 mtrs
7-	Crossing In between Kilometer Stone	22-23
a)	From: Meerut	23.00 Km
b)	To: Garh Mukhteshwar	22.00 Km
8-	Electrical Clearance above Top Surface of the Road	
a)	Actual:	23.97 mtr.
b)	Required:	15.00 mtr.

Bhagat
13/12/21
Chief Manager


ए. अहमद /A. Ahmad
मुख्य कार्यकारी अधिकारी/Chief Executive Officer
पावर ग्रिड मेरठ सिम्भावली ट्रांसमिशन लिमिटेड
Power Grid Meerut-Simbhawali Transmission Limited