

Government of India

Ministry of Road Transport & Highways

(Chief Engineer - Regional Office, Lucknow)

N.H. Bhawan, Biotech Chowk, Lucknow Ring Road, Vikas Nagar, Lucknow - 226 022

Ph.: (0522) - 2967112, 2738226 (Tele-Fax)

Dated: 13.12.2022

Invitation of public comments

Sub.: Proposal for NOC permission of water supply pipeline for laying & crossing by HDD method in Km.39.800 to km.44.734 (Barokharkhurd - Rehuna) of NH-35(76) at Tehsil & District - Banda in the state of Uttar Pradesh - Reg.

The Executive Engineer, UP Jal Nigam (Gramin), Chitrakoot submitted the proposal for laying underground water supply pipeline through trenchless HDD method in Km.39.800 to km.44.734 (Total length of 4934 meters) of NH-35 (old NH-76) (Barokharkhurd - Rehuna section) in the State of Uttar Pradesh to Chief Engineer (NH), PWD, Lucknow for consideration.

2. As per the guidelines, issued by the Ministry vide OM No. RW/NH-33044/29/2015/S&R(R) dated 22.11.2016, the application shall be put out in the public domain for 30 days for seeking claims and objections (on grounds of public inconvenience, safety and general public interest).

3. In view of the above, comments of the public on the above application is invited to the below mentioned address:

The Chief Engineer-Regional Officer,
Ministry of Road Transport & Highways,
N.H. Bhawan, Biotech Chowk, Lucknow Ring Road,
Vikas Nagar, Lucknow - 226 022.

Encl.: As above.

Yours faithfully,



(Mohd. Zaid)

Assistant Executive Engineer
for Chief Engineer - Regional Officer

Copy to:

- (i) NIC, New Delhi - for uploading on the Ministry's website.
- (ii) The Chief Engineer (NH), Public Works Department, Government of Uttar Pradesh, Nirman Bhavan, 96, M. G. Marg, Lucknow - 226 001.
- (iii) The Executive Engineer, NH Division, PWD, Banda.

(Mohd. Zaid)

Assistant Executive Engineer
for Chief Engineer - Regional Officer

CHECK LIST

Guidelines for Project Directors for processing the proposal of crossing/ laying optical fiber/ HT cables/ Water supply pipe line etc. by private parties in the land along National Highway with NH PWD Division.

Relevant circular

Ministry Circular No. RW/NH-33044/29/2015/S&R Dated 22.11.2016.

Ministry Circular No. RW/NH-33044/27/2005/S&R (Pt) Dated 06.08.2013.

Check-list for getting approval for crossing/ laying of optical fiber/ HT cables /Water Supply Pipe line etc. on NH PWD Division land

S. No.	Item	Information/Status	Remarks
1.	General information		
1.1	Name and Address of the applicant / Agency	Office of The Executive Engineer Divisional Office UP Jal Nigam, (Gramin) Chitrakoot (Banda)	
1.2	National Highway Number	NH-35	
1.3	State	Uttar Pradesh	
1.4	Location	Tehsil- BANDA & District- BANDA	
1.5	Changes in KM	300 mm and 250mm Dia at Ch at Km. 39.800 to 44.734 and (NH-35)	
1.6	Length in meters	5994.00 mtr.	
1.7	Width of available ROW		
	(a) Left side from centre line towards increasing change/km direction	34 mtr. and 24 mtr.(vary every KM)	
	(b) Right side from centre line towards increasing chainage /km direction	34 mtr. and 24 mtr.(vary every Km)	
1.8	Proposal to lay the pipe line	39.80 km to 44.734 km	
	(a) Left side from centre line towards increasing change/km direction	km – 39.80 TO km -41.515	

Executive Engineer
N.H., P.W.D.-Banda

Assistant Engineer
National Highway Div. P.W.D.
P.A NDA

Junior Engineer
N.H. Div. P.W.D., Banda

अधिशोषी अभियन्ता
खण्ड कार्यालय उत्तर प्रदेश
जल निगम (ग्रामीण)
चित्रकूट

	(b) Right side from centre line towards increasing chainage /km direction.	km – 41.515 TO km -44.734	
1.9	Proposal to acquire land	4,863.8 Sqm.	
	(a) Left side from centre line.	2135.56 Sqm.	
	(b) Right side from centre line.	2728.2 Sqm.	
1.10	Whether proposal is in the same side where land is not to be acquired.	Not required	
	If not then where to lay the cable	Within available ROW	
1.11	Details of already laid the services, if any, along the proposed route.	NO	
1.12	Number of lanes (2/4/6/8 lanes) Existing	2-lanes with Paved Shoulder	
1.13	Proposed Number of lanes (2 lanes with pave shoulder/4/6/8 lanes)	Not Proposed	
1.14	Service road existing or not		
	If yes then which side		
	(a)left side from centre line	Does not exist.	
	(b)Right side from centre line.	Does not exist.	
1.15	Proposed road existing or not		
	(a) left side from centre line	Not Proposed	
	b)Right side from centre line.	Not Proposed	
1.16	Whether proposal to lay cable is after the service road or between the service road and main carriageway.	Extreme edge of Row	
1.17	The permission for pipe lines laying and crossing shall be considered for approval rejection	For approval	
	(i) Where the Row is more than 45m then the duct cable shall be laid at the edge of right of way within the utility corridor of 2m width, duly keeping in view the future widening.	Extreme edge of Row	
	(ii)Where land is yet to be acquired for 4-laning and the position of new carriageway has been decided then the cable shall be laid at the edge of right of way within the utility corridor of 2m width, in that side of existing carriageway where extra land is not proposal to be acquired for 4-laning.	Not required	
	(iii) Where the widening plan for 2-lanes with Paved Shoulder is not yet decided and available Row is around 30m or less, a judicious decision would need to be taken for permitting the laying of pipe lines laying and crossing. This could be within 1.5m to 2m of utility corridor at the edge of existing Row, duly keeping in view the possible widening plan.	2-laning has been completed.	
	(iv) Where Row is restricted and adequate only to accommodate the carriageway, central verge,	Plain terrain (Edge of Row)	

[Signature]
Junior Engineer
N.H. Div. P.W.D., Banda

[Signature]
Assistant Engineer
National Highway Div. P.W.D.
BANDA

सहायक अभियन्ता
खण्ड कार्यालय उत्तर प्रदेश
जल निगम (ग्रामीण)
बाँदा

[Signature]
Executive Engineer
N.H., P.W.D.-Banda

	shoulders and drains (e.g. Highways in currying through hilly, rolling terrain) the cable shall be laid clear of the drain.		
	(v) Where land strip for utility corridor cannot be conveniently earmarked (available row restricted to the toe of the embankment) for laying of cable/ducts, the permission may be refused.	Available	
1.18	Number of applicants of the same stretch.	Single applicant	
1.19	Whether the case of multiple licenses.	Single	
1.20	If so furnish a joint implement programmer to lay their respective ducts within stipulated time frame.	No	
1.21	If crossing of the road involved If yes, it shall only be through trench less technology.	Yes, it shall only be through HDD method	
2	Document/drawing enclosed with the proposal.		
2.1	Cross section showing the size of trench for open trenching method (Is it normal size of 1.65m deep x0.5m wide)	Shown in drawing	
2.2	Cross section showing the size of pit location of cable for HDD method.	NA	
2.3	Strip plan/ Route plan showing the pipe lines laying and crossing, chainage, width of ROW, important mile stone, intersections, cross drainage works etc.	Shown in drawing	
2.4	Mythology of laying of PFC	Enclosed	
2.4.1	Open trenching method. If yes, methodology of refilling of trench	Trench less	
2.4.2	Horizontal Directional drilling HDD method	Yes, through HDD	
2.4.3	Laying OFC/cable through CD works and method of laying (Whether to be hung outside parapet)	NA	
3.	Draft license agreement signed by two witnesses	Yes	
4.	Performance Bank Guarantee		
5.	Affidavit/ undertaking/ from the applicant for		
5.1	Not to damage to other utility, if damaged then to pay the losses either to NH PWD Division or to the concerned agency.	Yes, enclosed	
5.2	Renewal of Bank Guarantee.	NA	
5.3	Confirmation all standard condition of MORTHS guidelines.	Yes, enclosed	
5.4	Shifting of water pipe line laying as and when required by NH Division PWD.	Yes, enclosed	
5.5	Shifting due to 2-laning With Paved Shoulder / widening of NH Division PWD.	Yes, enclosed	
5.6	Indemnity against all damages and claims clause (xxiv)	Yes, enclosed	
5.7	Traffic movement during laying of OFC/cable to be managed by the applicant	Yes, enclosed	

[Signature]
Junior Engineer
N.H. Div. P.W.D., Banda

[Signature]
Assistant Engineer
National Highway Div. P.W.D.
BANDA

सहायक अभियन्ता
खण्ड कार्यालय उत्तर प्रदेश
जल निगम (ग्रामीण)
बाँदा

[Signature]
Executive Engineer
N.H., P.W.D.-Banda

5.8	If any claim is raised by the concessionaries then the same has to be paid by the applicant.	Yes, enclosed	
5.9	Certificate for 6-laning from the applicant in following format. "We do undertake that I will relocate service road/approach. Road/utilities at my own cost notwithstanding the permission granted within such time as will be stipulated by NH PWD Division for future two lane with Paved shoulder or any other development."	Yes, enclosed	
6.	Affidavit /Power of attorney in favor of authorized signatory.	Affidavit enclosed	
7.	Copy of DOT license	No, XLPE cable	State Govt. project.
8.	Certificate from the Project Director	Yes, enclosed	
8.1	Certificate from confirming of all standard condition issued vide Ministry Circular no. RW/NH-33044/27/2005/S&R(R)(Pt.) dated 7/8/2013 & dated 22.11.2016	Yes	
8.2	Certificate for 4-laning from PD in the following format (a) Where feasibility is available "I do certify that there will be no hindrance to proposed 6-laning base on the feasibility report considering proposed structure at the said location. (b) in case feasibility report is not available "I do certify that sufficient ROW is available at site for accommodate proposed 6-laning".	Already 2-lane NA NA	
9.	As per guidelines licensee fee shall be charged.	Department will pay fee after issuing demand note	
10.	If NH Division PWD section proposed to be taken up MORTH'S on BOT basis-a clause in Para 17 to be inserted in the agreement. "The permitted Highway on which licensee has been granted the right of way to the concessionaire under the concession agreement for uo-gradation of [... section from km.....to km..... of NH Division PWD no..... on Build, Operate and Transfer Basis]	NA	
11	Who will supervise the work of laying of pipe lines laying and crossing.	Office of The Executive Engineer Divisional Office UP Jal Nigam, (Gramin) Chitrakoot (Banda)	
12.	Who will ensure that the defects in road portion after laying of pipe lines laying and crossing are corrected and if not corrected then what action will be taken.	Office of The Executive Engineer Divisional Office UP Jal Nigam, (Gramin) Chitrakoot (Banda) UP-	

Bah
Junior Engineer
N.H. Div. P.W.D., Banda

Pawha
Assistant Engineer
National Highway Div. P.W.D.
BANDA

सहायक अभियन्ता
खण्ड कार्यालय उत्तर प्रदेश
जल निगम (ग्रामीण)
बाँदा

ALB
Executive Engineer
N.H., P.W.D.-Banda
Bah

13.	Who will pay the claims for damages' done/disruption in working of concessionaire.	Office of The Executive Engineer Divisional Office UP Jal Nigam, (Gramin) Chitrakoot (Banda) UP-210001	
14.	A Certificate from EE that he will enter the proposed permission in the register of records of the permissions in the prescribed perform (copy enclosed) issued vide Ministry Circular no. RW/NH- 33044/29/2015/S&R(R) dated 22/11/2016	Yes	
15.	If any previous approval is accorded for laying of cable then photocopy if register of records of permissions accorded as maintained by PD (as per ministry circular no. RW/NH- 33044/29/2015/S&R(R) dated 22/11/2016	NA	

Yankar
10/12

सहायक अभियन्ता
खण्ड कार्यालय उत्तर प्रदेश
जल निगम (ग्रामीण)
बॉन्डा

Jah
Junior Engineer
N.H. Div. P.W.D., Banda

dk
Assistant Engineer
National Highway Div. P.W.D.
BANDA

AKS
Executive Engineer
N.H., P.W.D.-Banda
Jah