



भारतीय राष्ट्रीय राजमार्ग प्राधिकरण

(सड़क परिवहन एवं राजमार्ग मंत्रालय, भारत सरकार)

National Highways Authority of India

(Ministry of Road Transport & Highways, Govt. of India)

क्षेत्रीय कार्यालय-पश्चिम उ०प्र०, लखनऊ

Regional Office - West UP, Lucknow.

3/248, विशाल खण्ड, गोमती नगर, लखनऊ-226010 (उ.प्र.)

3/248, Vishal Khand, Gomti Nagar, Lucknow-226010 (UP)

दूरभाष / Phone : 0522-4960291

टेलीफैक्स / Fax : 0522-4950680

ई-मेल / E-mail : rowestup@nhai.org

rowestup@gmail.com

वेबसाइट / Website : www.nhai.gov.in

19001/1/RO-W-UP/NH-30/Ch.307.230/33KV/384.

Date: 18.09.2020

Invitation of Public Comments

Sub: proposal for permission for underground crossing by HDD method of 2nos, 33KV, 3x300 Sq.mm. XLPE insulated cable on NH-30 (Old NH-24), Bareilly Sitapur at Km.307.230, Tilhar & District-Shahjahanpur in the State of Uttar Pradesh.

The Authorized Signatory M/s AMP Solar Evolution Pvt. Ltd. has submitted the proposal for granting permission for underground crossing by HDD method of 2nos, 33KV, 3x300 Sq.mm. XLPE insulated cable on NH-30 (Old NH-24), Bareilly Sitapur at Km.307.230, Tilhar & District-Shahjahanpur in the State of Uttar Pradesh.

2. As per the guidelines, issued by the Ministry vide OM No.RW/NH-33044/29/2015/ S&R(R) dated 22.11.2016, the application shall be put out in the public domain for 30 days for seeking claims and objections (on grounds of public inconvenience, safety and general public interest).

3. In view of the above, comments of the public on the above application is invited to the below mentioned address, which should reach by this office within 30 days from the date of publication beyond which no comments shall be entertained.

**The General Manager cum Regional Officer,
National Highways Authority of India
Regional Office, UP-West, Lucknow
3/248, Vishal Khand, Gomti Nagar
Lucknow-226 010**

This is issues with the approval of RO-West (UP).

Encl: As above.

(N P Singh)
DGM (T)
For RO-West, UP

Copy to:

1. Web Admin, NHAI-HQ- with request for uploading on the NHAI website.
2. The Technical Director, NIC, Transport Bhawan, New Delhi- with request for uploading on the Ministry's website.
3. The Authorized Signatory, M/s AMP Solar Evolution Pvt. Ltd., New Delhi for information.
4. The PD, PIU-Bareilly for information.

"Building a nation, not just Roads."

मुख्यालय : प्लॉट सं० जी-5 एवं 6, सेक्टर-10, द्वारका, नई दिल्ली - 110 075, दूरभाष : 91-11-25074100 / 200

Head Office : Plot No. G-5 & 6, Sector - 10, Dwarka, New Delhi - 110 075 Phone : 91-11-25074100/200

CHECK LIST

Guidelines for Project Directors for processing the proposal of crossing /laying optical fiber/ HT cables/ Water supply pipe line etc. by private parties in the land along National Highway with NHAI.

Relevant circulars

Ministry Circular No. RW/NH-33044/29/2015/S&R (R) Dated 22.11.2016.

Ministry Circular No. RW/NH-33044/27/2005/S&R(R)(Pt.) Dated 06.08.2013


Check-list for getting approval for crossing/ laying of optical fiber/ HT cables/ Water supply pipe line etc. on NH land


S. No.	Item	Information/Status	Remarks
1.	General Information		
1.1	Name and Address of the applicant/Agency	M/s AMPSolar Evolution Private Limited, Address: 309, 3rd Floor, Rectangle One, Behind Sheraton Hotel, Saket, New Delhi - 110 017.	
1.2	National Highway Number	NH-30 (Old NH-24)	
1.3	State	Uttar Pradesh	
1.4	Location	Tilhar & District-Shahajahanpur.	
1.5	(Chainages in KM)	Km.307.230	
1.6	Length in Meters	60.00m	
1.7.	Width of available ROW		
	(a) Left side from centre line towards increasing chainage/km direction	30m	
	(b) Right side from centre line towards increasing chainage/km direction	30m	
1.8	Proposal to lay the HT (cable)		
	(a) Left side from centre line towards increasing chainage/km direction	NA	Crossing
	(b) Right side from centre line towards increasing chainage/km direction	NA	Crossing

Amprasad
परियोजना निदेशक
भारतीय राष्ट्रीय राजमार्ग प्राधिकरण
परियोजना कार्यान्वयन इकाई, बरेली (उ०प्र०)

Deepak
AMPSOLAR EVOLUTION PRIVATE LIMITED

1.9	Proposal to acquire land		
	(a) Left side from centre line.	Not required	
	(b) Right side from centre line.	Not required	
1.10	Whether proposal is in the same side where land is not to be acquired	Not required	
	If not then where to lay the cable	Within available ROW	
1.11	Details of already laid services, if any, along the proposed route	No	
1.12	Number of lanes (2/4/6/8 lanes) existing	4-lanes	
1.13	Proposed Number of lanes (2 lanes with paved shoulder/4/6/8 lanes)	Not proposed	
1.14	Service road existing or not		
	If yes then which side		
	(a) Left side from centre line.	Does not exist.	
	(b) Right side from centre line.	Does not exist.	
1.15	Proposed Service Road		
	(a) Left side from centre line.	Not proposed	
	(b) Right side from centre line.	Not proposed	
1.16	Whether proposal to lay cable is after the service road or between the service road and main carriageway	Extreme edge of RoW	
1.17	The permission for laying OFC / HT cables shall be considered for approval/rejection	Approval	
	(i) Where the ROW is more than 45m then the duct cable shall be laid at the edge of right of way within the utility corridor of 2m width, duly keeping in view the future widening.	Extreme edge of RoW	
	(ii) Where land is yet to be acquired for 4-laning and the position of new carriageway has been decided then the cable shall be laid at the edge of right of way within the utility corridor of 2m width, on that side of existing carriageway where extra land is not proposed to be acquired for 4-laning.	Not required	


 AMPSOLAR EVOLUTION PRIVATE LIMITED


 परियोजना निदेशक
 भारतीय राष्ट्रीय राजमार्ग प्राधिकरण
 परियोजना कार्यान्वयन इकाई, बरेली (उ०प्र०)

	(iii) Where the widening plan for 4-laning is not yet decided and available ROW is around 30m or less, a judicious decision would need to be taken for permitting the laying of cable/duct. This could be within 1.5m to 2 m of utility corridor at the edge of existing ROW, duly keeping in view the possible widening plans.	4-laning has been completed.	
	(iv) Where ROW is restricted and adequate only to accommodate the carriageway, central verge, shoulders and drains (e.g. Highways in currying through hilly, rolling terrain) the cable shall be laid clear of the drain.	Plain terrain (Edge of ROW)	
	(v) Where land strip for utility corridor cannot be conveniently earmarked (available ROW restricted to the toe of the embankment) for laying of cable/ducts, the permission may be refused.	available	
1.18	Number of applicants of the same stretch.	Single applicant	
1.19	Whether the case of multiple licenses.	Single	
1.20	If so furnish a joint implement programmer to lay their respective ducts within stipulated time frame.	No	
1.21	If crossing of the road involved If yes, it shall only be through trench less technology	Yes, it shall only be through HDD method	
2.	Document/drawing enclosed with the proposal.		
2.1	Cross section showing the size of trench for open trenching method (Is it normal size of 1.65m deep x0.5m wide)	Shown in drawing	
2.2	Cross section showing the size of pit location of cable for HDD method	NA	
2.3	Strip plan / Route Plan showing the OFC/Cable, chainage, width of ROW, important mile stone,	Shown in drawing	

Deepal
AMPSOLAR EVOLUTION PRIVATE LIMITED

परियोजना निदेशक
भारतीय राष्ट्रीय राजमार्ग प्राधिकरण
परियोजना कार्यान्वयन इकाई, बरेली (उ०प्र०)

	intersections, cross drainage works etc.		
2.4	Mythology of lay/crossing of HT	enclosed	
2.4.1	Open trenching method. If, yes, methodology of refilling of trench.	Trench less	
2.4.2	Horizontal Directional Drilling (HDD) method	Yes, through HDD	
2.4.3	Laying OFC/cable through CD works and method of laying (Whether to be hung outside parapet)	NA	
3.	Draft license agreement signed by two witnesses	Yes	
4.	Performance Bank Guarantee		
5.	Affidavit/ Undertaking/ from the Applicant for		
5.1	Not to Damage to other utility, if damaged then to pay the losses either to NHAI or to the concerned agency.	Yes, enclosed	
5.2	Renewal of Bank Guarantee.	NA	
5.3	Confirmation all standard condition of NHAI,s guidelines.	Yes, enclosed	
5.4	Shifting of OFC/cable as and when required by NHAI.	Yes, enclosed	
5.5	Shifting due to 6-laning / widening of NH.	Yes, enclosed	
5.6	Indemnity against all damages and claims clause (xxiv)	Yes, enclosed	
5.7	Traffic movement during laying of OFC/cable to be managed by the applicant	Yes, enclosed	
5.8	If any claim is raised by the Concessionaries then the same has to be paid by the applicant.	Yes, enclosed	
5.9	Certificate for 6-laning from the applicant in following format. "We do undertake that I will relocate service road/approach road/utilities at my own cost notwithstanding the permission granted within such time as will be stipulated by NHAI for future six-laning or any other development."	Yes, enclosed	


Amish Kumar


परियोजना निदेशक
भारतीय राष्ट्रीय राजमार्ग प्राधिकरण
परियोजना कार्यान्वयन इकाई, बरेली (उ.प्र.)

Deepal


AMPSOLAR EVOLUTION PRIVATE LIMITED


6.	Affidavit /Power of Attorney in favor of authorized signatory.	Affidavit enclosed	
7.	Copy of DOT license	No, XLPE cable	
8.	Certificate from the Project Director	Yes, enclosed	
8.1	Certificate from confirming of all standard condition. issued vide Ministry Circular No. RW/NH-33044/27/2005/S&R(R)(Pt.) dated 7/8/2013 & dated 22.11.2016	Yes	
8.2	Certificate for 4-laning from PD in the following format	Already 4-lane	
	(a) Where feasibility is available "I do certify that there will be no hindrance to proposed 6-laning base on the feasibility report considering proposed structure at the said location.	NA	
	(b) In case feasibility report is not available "I do certify that sufficient ROW is available at site for accommodate proposed 6-laning".	NA	
9	As per guidelines license fee shall be charged.		
10	If NH section proposed to be taken up NHAI on BOT basis –a clause in para 17 to be inserted in the agreement. " The permitted Highway on which Licensee has been granted the right of way to the concessionaire under the concession agreement for up-gradation of [.... Section From Km.....to kmof NHAI No..... on Build, Operate and Transfer Basis]		
11	Who will supervise the work of lay/crossing of OFC/Cable	M/s AMPSolar Evolution Private Limited, Address: 309, 3rd Floor, Rectangle One, Behind Sheraton Hotel, Saket, New Delhi – 110 017.	
12	Who will ensure that the defects in road portion after lay/crossing of OFC/Cable are corrected and if not	M/s AMPSolar Evolution Private Limited, Address: 309, 3rd Floor, Rectangle	


 परियोजना निदेशक
 भारतीय राष्ट्रीय राजमार्ग प्राधिकरण
 परियोजना कार्यान्वयन इकाई, बरेली (उ.प्र.)


 AMPSOLAR EVOLUTION PRIVATE LIMITED

	corrected then what action will be taken.	One, Behind Sheraton Hotel, Saket, New Delhi – 110 017.	
13	Who will pay the claims for damages' done/disruption in working of concessionaire if asked by the Concessionaire.	M/s AMPSolar Evolution Private Limited, Address: 309, 3rd Floor, Rectangle One, Behind Sheraton Hotel, Saket, New Delhi – 110 017.	
14	A Certificate from PD that he will enter the proposed permission in the register of records of the permissions in the prescribed performa (copy enclosed) issued vide Ministry Circular RW/NH-33044/27/2005/S&R(R)(Pt.) Dated 7/8/2013	Yes	
15	If any previous approval is accorded for lay/crossing of cable then photocopy of register of records of permissions accorded as maintained by PD (as per Ministry Circular No. RW/NH-33044/27/2005/S&R(R)(Pt.) Dated 7/8/2013 as referred in para 13 above is enclosed or not.	NA	


 परियोजना निदेशक
 भारतीय राष्ट्रीय राजमार्ग प्राधिकरण
 परियोजना कार्यान्वयन इकाई, बरेली (UP)


 AMPSOLAR EVOLUTION PRIVATE LIMITED