



दूरभाष/Tele : +91-452-258 8999  
वेब/Website : www.nhai.gov.in  
ई-मेल/E-mail : romadurai@nhai.org  
nhairomadurai@gmail.com

भारतीय राष्ट्रीय राजमार्ग प्राधिकरण  
(सड़क परिवहन और राजमार्ग मंत्रालय)  
**National Highways Authority of India**  
(Ministry of Road Transport & Highways)  
क्षेत्रीय कार्यालय, मदुरै / Regional Office, Madurai  
दूसरा व तीसरी तल, विजय कृष्ण प्लाजा, संख्या-1, लेक एरिया, मेलूर मेन रोड, माट्टुतावनी, मदुरै-625 007  
2<sup>nd</sup> & 3<sup>rd</sup> Floor, Vijay Krishna Plaza, No.1, Lake Area, Melur Main Road, Mattuthavani, Madurai-625 107



**BHARATMALA**  
ROAD TO PROSPERITY

NHAI/15018/4.1/2/2021/RO Madurai/198

1<sup>st</sup> February, 2021

**INVITATION OF PUBLIC COMMENTS**

Sub: NHAI, Madurai Region - PIU, Madurai - Operation and Maintenance of Madurai - Kanyakumari section from Km.0/000 to Km.243/170 of NH-7 in the State of Tamil Nadu - NOC for erection of 230 KV Overhead Electrical power supply Line crossing at Km.3+450 in Thuvariman Village - Proposal submitted - Reg.

\*\*\*\*\*

The proposal is regarding permission for Erection of 230 KV overhead electrical line crossing NH at Km.3+450 in Madurai - Kanyakumari section of NH-7 in the state of Tamil Nadu submitted to this office by PD-Madurai vide Lr.No. NHAI/PIU/MDU/NH-7/Utility/2020/3222, dt.18.12.2020 in accordance with Ministry's latest guideline dated 22.11.2016.

2. The alignment proposed by the Superintending Engineer, GCC, TANTRANSCO, Madurai for Erection of 230 KV overhead electrical line crossing NH at Km.3+450 in Thuvariman village in the section of Madurai - Kanyakumari of NH-7 in the State of Tamil Nadu as detailed under:

Sl. No	Description	Length in Meters	Width in meters	Name of Village	Remarks
Across the road					
1	Km.3+450	60	0.116	Thuvariman	Manual Erection of 230 KV DC Tower Line

3. The Right of Way is 60 m in the aforesaid stretch. The proposed Erection of 230 KV overhead electrical line crossing the NH at Km.3+450 in Madurai - Kanyakumari section of NH-7. Further, the Superintending Engineer, GCC, TANTRANSCO, Madurai has given undertaking that the vertical clearance is 18.0 m from the FRL (Finished road level) which is in conformity with Ministry's latest guidelines dated 22.11.2016.

4. The applicant has furnished an undertaking that they will shift the erected electrical line in future when required by NH Authority at any time for expansion of the NH at their own cost without claiming any compensation from NHAI. Also, certified that, the proposed erection of 230KV overhead electrical line work will not affect the design, stability, traffic safety and future improvement of the proposed stretch.

*K. n. s.*



## National Highways Authority of India

5. As per the guidelines issued by the Ministry vide letter No. RW/NH-33044/29/2015/S&R(R) dated 22.11.2016, the application submitted by the applicant will be made available for public comments and the comments may be given within 30 days from the day of uploading.

In view of the above, comments of the public on the above proposal are invited to the below mentioned address:

The Regional Officer  
National Highways Authority of India  
No.2<sup>nd</sup> & 3<sup>rd</sup> Floor, Vijay Krishna Plaza,  
No.1, Lake Area, Melur Main Road, Mattuthavani,  
Madurai - 625 107.

*K. Mathivanan*  
01/02/2021  
(KPSK. Mathivanan),  
Manager (Tech.),  
For Regional Officer

Copy to: 1. NHAI website.

2. The NIC, New Delhi - For uploading in the Ministry's website.

3. PD, NHAI, Madurai - for information.