



दूरभाष / Tele : +91-452-258 8999  
वेब / Website : www.nhai.gov.in  
ई-मेल / E-mail : romadurai@nhai.org  
nhairomadurai@gmail.com

**भारतीय राष्ट्रीय राजमार्ग प्राधिकरण**  
**(सड़क परिवहन और राजमार्ग मंत्रालय)**  
**National Highways Authority of India**  
**(Ministry of Road Transport & Highways)**  
**क्षेत्रीय कार्यालय, मदुरै / Regional Office, Madurai**  
दूसरा व तीसरी तल, विजय कृष्ण प्लाजा, संख्या-1, लेक एरिया, मेलूर मेन रोड, माट्टुतावनी, मदुरै-625 007  
2<sup>nd</sup> & 3<sup>rd</sup> Floor, Vijay Krishna Plaza, No.1, Lake Area, Melur Main Road, Mattuthavani, Madurai-625 107



**BHARATMALA**  
ROAD TO PROSPERITY

NHAI/15018/4.1/5/2021/RO Madurai/ 1168

23<sup>rd</sup> July, 2021

### INVITATION OF PUBLIC COMMENTS

Sub: NHAI, Madurai Region - PIU, Madurai - Operation and Maintenance of Madurai - Kanyakumari section from Km.0/000 to Km.243/170 of NH-7 in the State of Tamil Nadu - Proposal submitted to Erection of 765 KV Overhead Electrical line crossing at Km.60/830 in Maruluthu village - Proposal submitted - Reg.

The proposal is regarding permission for Erection of 765 KV overhead electrical line crossing NH at Km.60/830 in Maruluthu village in Madurai - Kanyakumari section of NH-7 in the state of Tamil Nadu submitted to this office by PD, PIU, Madurai Lr.No. NHAI/PIU/MDU/NH-7/Utility/2021/663, dt.02.03.2021 in accordance with Ministry's latest guideline dated 22.11.2016.

2. The alignment proposed by the Executive Engineer, Transmission/TANTRANSCO, Virudhunagar for Erection of 765 KV overhead electrical line crossing NH at Km.60/830 in Maruluthu village in the section of Madurai - Kanyakumari of NH-7 in the State of Tamil Nadu as detailed under:

Sl. No	Description	Length in Meters	Width in meters	Name of Village	Remarks
Across the road					
1	Km.60/830	60	5.616	Maruluthu	Manual Erection of 765 KV DC Tower Line

3. The Right of Way is 60 m in the aforesaid stretch. The proposed Erection of 765 KV overhead electrical line crossing the NH at Km.60/830 in Madurai - Kanyakumari section of NH-7. Further, the Executive Engineer, Transmission / TANTRANSCO, Virudhunagar has given undertaking that the vertical clearance is 25.0 m from the FRL (Finished road level) which is in conformity with Ministry's latest guidelines dated 22.11.2016.

*(Signature)*

## National Highways Authority of India

4. The applicant has furnished an undertaking that they will shift the erected electrical line in future when required by NH Authority at any time for expansion of the NH at their own cost without claiming any compensation from NHAI. Also, certified that, the proposed erection of 765 KV overhead electrical line work will not affect the design, stability, traffic safety and future improvement of the proposed stretch.

5. As per the guidelines issued by the Ministry vide letter No. RW/NH-33044/29 /2015/S&R(R) dated 22.11.2016, the application submitted by the applicant will be made available for public comments and the comments will be invited within 30 days from the day of uploading.

In view of the above, comments of the public on the above proposal is invited to the below mentioned address:

The Regional Officer  
National Highways Authority of India  
No.2<sup>nd</sup>& 3<sup>rd</sup> Floor, Vijay Krishna Plaza,  
No.1, Lake Area, Melur Main Road, Mattuthavani,  
Madurai - 625 107

  
(V.Sasikumar),

Manager (Tech.),  
For Regional Officer

To

1. NHAI Website.
2. The NIC, New Delhi - For uploading in the Ministry's Website.
3. PD, PIU, Madurai.