



दूरभाष / Tele : +91-452-258 8999
वेब / Website : www.nhai.gov.in
ई-मेल / E-mail : romadurai@nhai.org
nhairomadurai@gmail.com

भारतीय राष्ट्रीय राजमार्ग प्राधिकरण
(सड़क परिवहन और राजमार्ग मंत्रालय)
National Highways Authority of India
(Ministry of Road Transport & Highways)
क्षेत्रीय कार्यालय, मदुरै / Regional Office, Madurai
दूसरा व तीसरी तल, विजय कृष्ण प्लाजा, संख्या-1, लेक एरिया, मेलूर मेन रोड, माट्टुतावनी, मदुरै-625 007
2nd & 3rd Floor, Vijay Krishna Plaza, No.1, Lake Area, Melur Main Road, Mattuthavani, Madurai-625 107



BHARATMALA
ROAD TO PROSPERITY

NHAI/15018/4.1/12/2021/RO Madurai/E-121939/2561

20th December, 2021

INVITATION OF PUBLIC COMMENTS

Sub: NHAI, Madurai Region - PIU, Madurai - Operation and Maintenance of Madurai - Kanyakumari section from Km.0/000 to Km.243/170 of NH-7 in the State of Tamil Nadu - Permission for Erection of 230 KV Over Head Electrical line crossing at Km.195/300 in Vagaikulam village in Madurai - Kanyakumari section of NH-44 - Proposal submitted - Reg.

The proposal is regarding permission for Erection of 230 KV overhead electrical line crossing NH at Km.195/300 in Vagaikulam village in Madurai - Kanyakumari section of NH-44 in the state of Tamil Nadu submitted to this office by PD, PIU, Madurai Lr.No. NHAI/PIU/MDU/NH-7/Utility/2021/3146, dt.01.11.2021 in accordance with Ministry's latest guideline dated 22.11.2016.

2. The alignment proposed by the Superintending Engineer, GCC, TANTRANSCO, Madurai for Erection of 230 KV overhead electrical line crossing NH at Km.195/300 in Vagaikulam village in the section of Madurai - Kanyakumari of NH-44 in the State of Tamil Nadu as detailed under;

S. No	Stretch	Available ROW (in m)		Proposal
		LHS	RHS	
1	Crossing at Km 195/300 in NH-44	31.2	35.6	<p>The 230 KV EHT towers (1 No. of Pole on each side) are proposed to be erected at a distance of 66.1 m from Center line on RHS and at a distance of 95.7m from Center line on LHS. Instant proposal is only for the crossing of 230 KV Over Head Electrical power transmission line at Km 195/300.</p> <p>The proposed clear height from the FRL and the bottom of the conductor is 19.14 m and span between two towers is 161.8 m.</p>

3. The Right of Way is 66.8 m in the aforesaid stretch. The proposed Erection of 230 KV overhead electrical line crossing the NH at Km.195/300 in Madurai - Kanyakumari section of NH-44. Further, the Superintending Engineer, GCC, TANTRANSCO, Madurai has given undertaking that the vertical clearance is 19.14 m

(Signature)


from the FRL (Finished road level) which is in conformity with Ministry's latest guidelines dated 22.11.2016.

4. The applicant has furnished an undertaking that they will shift the erected electrical line in future when required by NH Authority at any time for expansion of the NH at their own cost without claiming any compensation from NHAI. Also, certified that, the proposed erection of 230 KV overhead electrical line work will not affect the design, stability, traffic safety and future improvement of the proposed stretch.

5. As per the guidelines issued by the Ministry vide letter No. RW/NH-33044/29 /2015/S&R(R) dated 22.11.2016, the application submitted by the applicant will be made available for public comments and the comments will be invited within 30 days from the day of uploading.

In view of the above, comments of the public on the above proposal is invited to the below mentioned address:

The Regional Officer
National Highways Authority of India
No.2nd & 3rd Floor, Vijay Krishna Plaza,
No.1, Lake Area, Melur Main Road, Mattuthavani,
Madurai - 625 107


(V. Sasikumar),
Manager (Tech.),
For Regional Officer

To

1. NHAI Website.
2. The NIC, New Delhi - For uploading in the Ministry's Website.
3. PD, PIU, Madurai.