



भारतीय राष्ट्रीय राजमार्ग प्राधिकरण
(सड़क परिवहन और राजमार्ग मंत्रालय)
National Highways Authority of India
(Ministry of Road Transport & Highways)
क्षेत्रीय कार्यालय, चेन्नई / Regional Office, Chennai
'श्री टावर' 3rd मंजिल, DP-34 (SP), इंडस्ट्रीयल एस्टेट, गिण्डि, चेन्नई - 600 032
'SRI TOWER', 3rd Floor, DP-34 (SP), Industrial Estate, Guindy, Chennai - 600 032.

दूरभाष/Tele : 91-44-2225 2635
फैक्स/Fax : 91-44-2225 2636
ई-मेल/ E-mail: rochennai@nhai.org

NHA/11019/16/2009/RO Chennai/535

10th February, 2021

Invitation of Public Comments

Sub: NHA, RO, Chennai - PIU, Chennai – Proposal for laying of 33 KV 1 x 630 sqmm XLPE UG Cable from SRMC 110 KV SS to Kovoor 33/11 KV SS along the road from km 12/060 to km 12/260 by Trenchless Method and from km 12/260 to km 13/060 on LHS by Open Trench method in Chennai Bypass by Executive Engineer, Civil, CDC, TANGEDCO, Chennai – Regarding.

The proposal is regarding permission for laying of 33 KV 1 x 630 sqmm XLPE UG Cable from SRMC 110 KV SS to Kovoor 33/11 KV SS along the road from km 12/060 to km 12/260 by Trenchless Method and from km 12/260 to km 13/060 on LHS by Open Trench method in Chennai Bypass by Executive Engineer, Civil, CDC, TANGEDCO, Chennai submitted to this office by the PD, NHA, Chennai vide letter No. (2100) dated 27.10.2020.

2. The available width of ROW is 60m and it is proposed to lay the UG Cable at a distance of 24.5m from the centreline of the main carriageway.
3. Executive Engineer, Civil, CDC, TANGEDCO, Chennai has proposed to lay proposed laying of 33 KV 3x360 sq.mm XLPE UG Cable from km 12/060 to km 12/260 by Trenchless Method along the road by open trench method beneath RCC Cover Slab with fine sand filling and backfilled with excavated earth at a depth of 1.60 m below the ground level. From Km 12/260 to km 13/060 on LHS, it is proposed to lay the Cable at a depth of 1.50 m below the ground level by Open Trench method.
4. Executive Engineer, Civil, CDC, TANGEDCO, Chennai has furnished undertaking to indemnify against all damages and claims and furnished undertaking that they will relocate utilities at their own cost notwithstanding the permission granted within such time as will be stipulated by NHA for future six laning or any other development.. Executive Engineer, Civil, CDC, TANGEDCO, Chennai has given undertaking to relocate cable lines/utilities at their own cost, notwithstanding the permission granted within such time as will be stipulated by NHA for future six laning or any other development.

National Highways Authority of India

5. As per the guidelines issued by the Ministry vide letter No.RW/NH-33044/29/2015/ S&R(R) dated 22.11.2016, the proposal submitted by Executive Engineer, Civil, CDC, TANGEDCO, Chennai will be made available for 30 days seeking public comments/objections and the comments shall be furnished within 30 days from the day of closure of public objections.

In view of the above, comments of the public on the above proposal are invited and may be sent to the below mentioned address:

The Regional Officer
National Highways Authority of India
(Ministry of Road, Transport & Highways)
SRI Tower, 3rd Floor
DP - 34 (SP), Industrial Estate,
Guindy - Chennai-600 032

Yours faithfully,


(G.Athipathi)

Manager (Tech)

For Regional Officer, NHAI, Chennai

Copy to:

1. NHAI website
2. The NIC, New Delhi - for uploading in the Ministry's website.
3. PD, NHAI, Chennai – for information