

No. RO/Chennai/MoRTH/12017/NH-81/PER/26/2021-22

GOVERNMENT OF INDIA

MINISTRY OF ROAD TRANSPORT & HIGHWAYS

Regional Office, Chennai.

C-1-A, Rajaji Bhavan, Besant Nagar, Chennai- 600090.

Email: cerochennaiomorth@gmail.com, Tele Off: 24919341.

Dated: 25th February 2022

Invitation of public comments

Subject:- Permission proposal for laying 11KV 3x300 Sq.mm(1Run) underground Electrical Cable line along the road from Km 2/935 to 5/055(RHS) & crossing at Km 5/055 of Coimbatore -Karur-Tirchirappali-Chidambaram road of NH-81 in the state of Tamil Nadu-Reg.

The proposal is regarding request for permission for laying 11KV 3x300 Sq.mm(1Run) underground Electrical Cable line along the road from Km 2/935 to 5/055(RHS) & crossing at Km 5/055 of Coimbatore -Karur-Tirchirappali-Chidambaram road of NH-81 in the state of Tamil Nadu by the Executive Engineer, O& M/ TANGEDCO/CEDC/METRO, Ondipudur, Vasantham Nagar, Coimbatore submitted to this office by the SE (NH), Salem vide letter No. 243/2022/JDO/NH/ dated 02.02.2022. The proposal has been examined and the details are as under:

Stretch in Km	Length (Km)	ROW (m)	Dist. of Prop. Electrical Cable line from Centre of NH (m)
RHS (by Trench Method)			
Km. 2/935 to 5/055	2.120	Varies from 22.10m to 42.50m	Varies from 10.25m to 25.25m
Crossing (by HDD method)			
At Km. 5/055	0.431	44.10m	NA

2. The Right of Way in the stretch of NH proposed for laying Electrical Cable line is varying from 22.10m to 42.50m. The carriageway width of stretch from Km. 2/935 to 5/055 of NH-81 is varies from 17.80m to 20.30m. The Executive Engineer, O& M/ TANGEDCO/CEDC/METRO, Ondipudur, Vasantham Nagar, Coimbatore has proposed to lay the underground Public Utility at edge of the ROW for a length of 2120m by adopting open trench method along the National Highway and HDD method across the National Highway.


3. The Executive Engineer, O& M/ TANGEDCO/CEDC/METRO, Ondipudur, Vasantham Nagar, Coimbatore has furnished an undertaking to the effect that they will remove the laid Public Utility Electric cable line in future if required by NH wing of State Highways Department, Tamil Nadu/MoRTH, Government of India at any time for expansion of the NH at their own cost without claiming any compensation from NH wing of Tamil Nadu/MoRTH, Government of India and any right on the NH land. Further, mentioned that, the Executive Engineer, O& M/ TANGEDCO/CEDC/METRO, Ondipudur, Vasantham Nagar, Coimbatore will also restore the ROW surfaces to its original condition soon after removal of the Public utility Electric cable lines. Also, certified that the proposed Public Utility work will not affect the design, stability, traffic safety and future improvement of the proposed stretch.

4. As per the guidelines issued by the Ministry vide letter No.RW/NH-33044/29/2015/S&R(R) dated 22.11.2016 the application will be made available for public comments and the comments will be invited within 30 days from the day of uploading the same in the web site of Ministry of Road Transport & Highways for public comments.

5. In view of the above, comments of the public on the above proposal is invited to the below mentioned address:

**The Regional Officer, Chennai,
Ministry of Road Transport & Highways,
C-1-A, Rajaji Bhavan, Besant Nagar, Chennai- 600 090**

Yours Sincerely,



(Prashant Kumar Bajpai)
Assistant Executive Engineer
For Regional Officer

To:

1. The NIC, Transport Bhavan, New Delhi - for uploading in the Ministry's website.
2. The SE, NH Circle, Salem-for information please.

✓
(Prashant Kumar Bajpai)
Assistant Executive Engineer
For Regional Officer