



भारतीय राष्ट्रीय राजमार्ग प्राधिकरण
(सड़क परिवहन और राजमार्ग मंत्रालय, भारत सरकार)
National Highways Authority of India
(Ministry of Road Transport & Highways, Government of India)
क्षेत्रीय कार्यालय, मदुरै / Regional Office, Madurai

दूसरा व तीसरी तल, विजय कृष्ण प्लाज़ा, संख्या-1, लेक एरिया, मेलूर मेन रोड, माटुतावनी, मदुरै-625 007
2nd & 3rd Floor, Vijay Krishna Plaza, No.1, Lake Area, Melur Main Road, Mattuthavani, Madurai-625 107
दूरभाष / Tele : +91-452-258 8999 वेब / Website : www.nhai.gov.in ई-मेल / E-mail : romadurai@nhai.org



NHAI/15018/3.3/01/2022/RO-Madurai/E-424753/ 2805 09th December, 2022

INVITATION OF PUBLIC COMMENTS

Sub: NHAI, Madurai Region - PIU, karaikudi - Permission for erection of 22 KV Double circuit Over Head line EB Pole & line along the road from Km 148/445 to Km 152/080 on RHS & across NH at Km 152/080 in Thirumayam - Manamadurai section of NH-226 in the State of Tamil Nadu- In-Principle Approval Requested - Public Comments Invited - Reg.

The proposal received from PD, Karaikudi vide letter No. NHAI/PIU/Karaikudi/11031/TM/EP/2022/750 dated 22.04.2022 there by requesting permission for erection of 22 KV Double circuit Over Head line EB Pole & line along the road from Km 148/445 to Km 152/080 on RHS & across NH at Km 152/080 in Thirumayam - Manamadurai section of NH-226 in the State of Tamil Nadu proposed by, M/s First Energy TN 1 Pvt Ltd., Chennai in accordance with Ministry's latest guidelines dated 22.11.2016.

2) The alignment proposed by the, M/s First Energy TN 1 Pvt Ltd., chennai. requesting permission for erection of 22 KV Over Head line EB Pole & line along the road from Km 148/445 to Km 152/080 on RHS & across NH at Km 152/080 in Thirumayam - Manamadurai section of NH-226 in the State of Tamil Nadu detailed under;

Stretch in Km	Length in Meters	Available ROW (in Meter)	Distance of erection from C/L (in Meter)		Remarks
			LHS	RHS	
Along NH-226: Km 148/445 to Km 150/550 on RHS	2105	30	-	13	RSJ EB Poles to be erected along NH
Along NH-226: Km 150/550 to Km 152/080 on RHS	1530	45	-	28	RSJ EB Poles to be erected along NH
Across NH-226 At Km 152/080	45	45	-	-	Over Head Line with minimum vertical clearance of 15m from MCW using M+9 tower.

3) In this instant proposal as certified by PD the proposed Vertical Clearance along the road is 10 m and across the road 15m.

नई दिल्ली

NHAI/15018/3.3/01/2022/RO-Madurai/E-424753/2805 09th December, 2022

4) M/s First Energy TN 1 Pvt Ltd., Chennai has furnished necessary undertaking to the effect that they will relocate the Over Head line EB Poles as and when requested by the NHAI at their own cost. It is also mentioned that, the proposed erection of 22 KV Over Head line EB Poles along & across NH work will not to damage any other utility, if damaged they will pay the losses either to NHAI or to the concerned agency as per Ministry Guidelines dated 22.11.2016.

5) Accordingly, as per Policy Guidelines issued by Ministry vide letter No. RW/NH-33044/29/2015/S&R(R) dated 22.11.2016., the application is being uploaded on public domain for 30 days for seeking claims and objections (on grounds of public inconvenience, safety and general public interest).

In view of the above, comments of the public on the above proposal is invited to the below mentioned address:

The Regional Officer,
National Highways Authority of India,
No. 3rd Floor, Vijay Krishna Plaza,
No.1, Lake Area, Melur Main Road, Mattuthavani,
Madurai - 625 007.

This is issued with approval of Regional Officer-Madurai.


09/12/22

(Mahendra Meena)
Dy. Manager (Tech.,)

Copy to:

1. The NIC, New Delhi - for uploading in the Ministry's website.
2. The PD, Karaikudi - for information.