



भारतीय राष्ट्रीय राजमार्ग प्राधिकरण

(सड़क परिवहन एवं राजमार्ग मंत्रालय, भारत सरकार)

National Highways Authority of India

(Ministry of Road Transport & Highways, Govt. of India)

क्षेत्रीय कार्यालय-पश्चिम उ०प्र०, लखनऊ

Regional Office - West UP, Lucknow.

3/248, विशाल खण्ड, गोमती नगर, लखनऊ-226010 (उ.प्र.)

3/248, Vishal Khand, Gomti Nagar, Lucknow-226010 (UP)

दूरभाष / Phone : 0522-4960291

टेलीफैक्स / Fax : 0522-4950680

ई-मेल / E-mail : rowestup@nhai.org

rowestup@gmail.com

वेबसाइट / Website : www.nhai.gov.in

19001/1/RO-W-UP/NH-731/Ch.107+300 & 107+400/OH/344

Date: 06.08.2020

Invitation of Public Comments

Sub: Palia-Shahjahanpur-Hardoi-Lucknow National Highway-731 crossing between chainage 107+300 & 107+400 for construction of 400KV D/C (Twin) Rosa-Badaun Transmission Line between angle tower no.AP 7A/O (DD+O) & APB/O (DD+18).

The Authorized Signatory M/s Obra-C Badaun Transmission Limited, Bareilly (UP) has submitted the proposal for permission for overhead power line crossing proposal of Palia - Shahjahanpur-Hardoi-Lucknow National Highway-731 crossing between chainage 107+300 & 107+400 for construction of 400KV D/C (Twin) Rosa-Badaun Transmission Line between angle tower no.AP 7A/O (DD+O) & APB/O (DD+18) in the State of Uttar Pradesh.

2. From the submitted proposal, it is seen that the position of Tower is outside of NH ROW. Length of crossing Span is 235m & Towers are at a distance of 57m & 132m from either side of NH boundry while height of towers is 46.60m & 66.50m. Angle of crossing is $86^{\circ}11'3''$, Vertical Clearance between road level & the lowest conductor is 22.24m. Width of available ROW is 46m.

3. As per the guidelines, issued by the Ministry vide OM No.RW/NH-33044/29/ 2015/ S&R(R) dated 22.11.2016, the application shall be put out in the public domain for 30 days for seeking claims and objections (on grounds of public inconvenience, safety and general public interest).

4. In view of the above, comments of the public on the above application is invited to the below mentioned address, which should reach by this office within 30 days from the date of publication beyond which no comments shall be entertained.

**The General Manager cum Regional Officer,
National Highways Authority of India
Regional Office, UP-West, Lucknow
3/248, Vishal Khand, Gomti Nagar
Lucknow-226 010**

This issues with the approval of RO-West (UP).

Encl: As above.

(Signature)
(N P Singh)
DGM (T)
For RO-West, UP

Copy to:

1. Web Admin, NHAI-HQ- with request for uploading on the NHAI website.
2. The Technical Director, NIC, Transport Bhawan, New Delhi- with request for uploading on the Ministry's website.
3. The Authorized Signatory M/s Obra-C Badaun Transmission Limited, Bareilly for information.
4. The PD, PIU-Bareilly for information.

"Building a nation, not just Roads."

मुख्यालय : प्लॉट सं० जी-5 एवं 6, सेक्टर-10, द्वारका, नई दिल्ली - 110 075, दूरभाष : 91-11-25074100 / 200

Head Office : Plot No. G-5 & 6, Sector - 10, Dwarka, New Delhi - 110 075 Phone : 91-11-25074100/200

CHECK LIST

Project Director for processing the Proposal of overhead electrical line crossing national highways vested with NHA

Circular / Codes:-

Ministry Circular No NH-III/P/20/77 dated 08-04-1982

Indian Electricity Act 1910

Indian Electricity Rules 1956

IRC: 32-1969

IS:5613-1976 Part I to IV

For getting approval for layering of overhead electrical line along the National Highways NH-731, vested with NHA

S.NO	Item	Information/ status	Remarks
1	General Information	400 KV D/C (Twin) Rosa - Badaun Transmission Line	
1.1	Name and address of the applicant	Obra-C Badaun Transmission Limited	
1.2	National Highway No	NH-731	
1.3	State	Uttar Pradesh	
1.4	Location	Kaneg, Shahjahanpur District	
1.5	Type of electric including carrying voltage details and purpose	400 KV D/C (QUAD)	
1.6	Chain -age in Kilometers	107+300, 107+400	
1.7	Length in Meter	235	
1.8	Width of available ROW	46	
	(a). Left side from Center Line towards increasing chainage / KM Direction	23	
	(b) Right side from Center Line towards increasing chainage / KM Direction	23	
1.9	Proposal to lay Overhead		
	(a) Left side from Center Line towards increasing chainage / KM Direction	As above	
	(b) Right side from Center Line towards increasing chainage / KM Direction	As above	
	(c) Errection of Electrical line along the NH 7	NA	
1.10	Proposal to acquire land	NA	
	(a)Left side from Center Line		
	(b)Right side from Center Line		
1.11	Whether the proposal is a- in the same side where land is not to the acquired b- Crossing the National Highway If not then where to lay the overhead electrical line	Yes From Palia-Shahjahanpur-Hardoi-lucknow	
1.12	Details of Already laid services (overhead telecommunication line, overhead electric line etc), if any , along the proposed route / proposed crossing	NA	
1.13	NO of lanes (2/4/6/8 lanes) existing	04 lane	
1.14	Proposed number of lanes (2 lanes with paved shoulder 4/6/8 lanes)	N/A	
1.15	Service Road existing or not	N/A	
	If yes then which side		
	a) Left side from center line		
	b) Right side from center line		
1.16	Proposed Service Road	N/A	
	a) Left side from center line		
	b) Right side from center line		
1.17	Whether proposal to lay overhead electric line is after the service road or between	N/A	

Amit Kumar
परियोजना निदेशक
भारतीय राष्ट्रीय राजमार्ग प्राधिकरण
परियोजना कार्यान्वयन इकाई, बरेली (UP)



1.17	service road and main carriage way, or crossing for approval / rejection based on the Ministry circulars and relevant codes mentioned as above.		
1.19	<p>I- If crossings of the roads involved</p> <p>(a) Crossing angle for NH and provide length along the Highway</p> <p>(b) Structure (Tower, pole and for HT Line only tension towers) for crossings shall not be too near the existing structures on the National Highway, The minimum distance being 15 meter.</p> <p>(i)- Type of Existing / proposed structure for National Highways</p> <p>(ii)- What is the distance of tower, pole and tension tower lying from the existing / proposed structure for National Highways.</p>	<p>Yes</p> <p>(a) 86°11'38", 231.94 Meters</p> <p>(b) Tower no AP 7A & AP 8 placed at a distance of 57 m & 132 mtr Respectively</p>	
	<p>(c)- The overhead lines and their supporting poles / towers should ordinarily be placed at the extreme edge of the road land boundary. In any case, these shall be at least 10 meter away from the edge of the existing shoulders of extreme traffic lane. Where the existing road way is narrower than the minimum according to standard or where the widening is proposed for any reason the lateral clearance shall be reckoned with respect to ultimate road way.</p> <p>What is the horizontal clearance from the extreme edge of the road land boundary?</p>	<p>N/A.</p> <p>N/A</p>	
	<p>(d) The overhead lines and their supporting poles/ towers should originally be placed at the minimum distance of 5.0 m from the nearest line of avenue trees.</p> <p>What is the horizontal clearance from the nearest line of avenue trees?</p>	N/A	
	<p>(e)- in mountainous / hilly terrain the overhead lines should be erected preferably on the valley side as far away as practicable. In hilly region, label of ground at a suitable distance below the outer conductor on either side from the central line is also to be noted and marked in profile so as to ensure required ground clearance underneath conductor and side clearances in swung conditions. Is the proposal in hilly area?</p>	Plain terrain	
	The horizontal clearances in respect of poles erected for the purpose of street lighting in Urban situations shall be as under:-		
	<p>i- For roads with Minimum 300mm from the Raised kerbs 300mm from the edge of nearest kerb Preferably 600mm</p>	N/A	
	<p>ii- For roads with At least 1.5m from the edge of the carriage way, raised kerbs subject to minimum of 5.0 from the central line of the carriage way.</p>	N/A	
	(g) the Pylons of HT lines along crossing the road shall be located outside the NH land	N/A	
	(h) for crossing the line of same voltage or lower voltage, suspension/ tension tower with suitable extensions shall be used.	N/A	
	<p>(i) The vertical clearance of the overhead lines crossing the road shall be reckoned from the top of the crown of the road taking into account the anticipated final top level due to future raising of road level, strengthening of pavement etc. The actual ground clearance of High Tension line for voltage above 650 volts</p>	Ground Clearance shall be taken jointly with OCBTL and NHAI after completion	


 परियोजना निदेशक
 भारतीय राष्ट्रीय राजमार्ग प्राधिकरण
 परियोजना कार्यान्वयन इकाई, बरेली (उ०प्र०)




	varies depending upon the voltage transmitted and these are stipulated in Indian standard. Codes is 56130-1976 part 1 to IV and Indian Electricity Rules 1956 as under.		
<u>2</u>	Affidavit / Under taking to be obtained from (to be furnished by the applicant).	Yes	
<u>2.1</u>	Not to damage to other utility , if damaged then to pay the losses either to NHAI or to the concerned agency	Yes	
<u>2.2</u>	Under Taking for Renewal of Bank Guarantee if required.	N/A	
<u>2.3</u>	Confirming all standard conditions as laid down in ministry circular no- NH-III/P/20/77 dated 08-04-1982 Indian Electricity Act 1910 Indian Electricity Rules 1956 IRC :32-1969, IS : 5613-1976 part I to IV of (NHAI)	Yes	
<u>2.4</u>	Shifting of overhead Electrical line at their own cost as an when required by (NHAI)	Done by OCBTL electrical Department own cost	
<u>2.5</u>	Shifting of overhead Electrical line at their own cost as an when required due to 4/ 6 lanning/ widening of NH	Done by OCBTL electrical Department own cost	
<u>2.6</u>	Indemnity against all damage and claims whatsoever kind that may be to NHAI or to any third party in the row during installation, operation and maintenance	Done by OCBTL electrical Department own cost	
<u>2.7</u>	Traffic movement during laying of OFC/Cable to be managed by the applicant	Done by OCBTL electrical Department own cost	
<u>2.8</u>	If any claim is raised by the concessionaire then the same has to be paid by the applicant.	Done by OCBTL electrical Department own cost	
<u>2.9</u>	Prior approval of the NHAI shall be obtained before undertaking any work of installation, shifting or repairs , or alterations to the overhead electrical line located in the National Highway right of way	Yes	
<u>2.10</u>	Expenditure, if any , incurred by electric department for repairing any damage caused to the National Highway by the laying , maintenance or shifting of the overhead electrical line located in the National Highway right of the way	Yes.	
<u>2.11</u>	If the NHAI considers it necessary in future to move the utility line for any work of improvement or repairs to the road , it will be carried out as desired by the NHAI at the cost of the electric department owing the utility line within a reasonable time (not exceeding 60 days) of the intimation given	Yes	
<u>2.12</u>	Certificate from the applicant in the following format :- (i) Laying of overhead electrical will not have any deleterious effects on any of the bridge components and roadway safety for traffic. (ii) For 4/6 laning "we do undertake that I will relocate service road/ approach road, utilities at my own cost,	Yes	

Amit Kumar
परियोजना निदेशक
भारतीय राष्ट्रीय राजमार्ग प्राधिकरण
परियोजना कार्यान्वयन इकाई, दिल्ली (एन.एच. 30)



[Signature]

	notwithstanding the permission granted within such time as will be stipulated by NHAI" for future 6 laning or any other development .		
2.13	The transmission line installation shall be carried out by trained and experienced personnel and supervised by technically qualified persons competent to undertake such work.	Yes	
2.14	The applicant ensures the safety of the Highway traffic against the Hazards of the high voltage lines during installation , operation and maintenance	Yes	
2.15	Undertaking the compliance with Indian electricity rules and other authorities, regulations- all over headlines shall comply with the requirement of the Indian electricity act and rules made their under and the regulations or specification as laid down by NHAI .	Yes	
	Other documents and drawing to be furnished by the applicant	Yes	
3.1	Methodology for laying of overhead electric line.	Yes	
3.2	Draft license agreement	Yes	
3.3	Performance bank guarantee in favor of NHAI has to be obtain at the Rs 100/- per running meter (Parallel to NH) and Rs 1, 00,000/- per crossing of NH, for a period of one year initially (extendable if required till satisfactory completions of work) as a security for insuring/ making good the area, Clearing debris / loose earth etc produced in the right of way. No payment shall be payable by the NHAI to the license for clearing debris/ loose earth.	YES	
3.4	Strip plan/ route plan showing overhead electrical line, chainage with of ROW, distance of proposed, structure(tower, pole and for HT Line only tension towers) from the edge of ROW, important milestone, intersections, cross drainage works any other structure existing of proposed etc.	Yes	
4	Certificate from the Project Director		
4.1	Certificate for confirming that the proposal has been examined with respect to the structures and developmental work considered at this location and compliance of the standard conditions issued vide ministry circular no- NH-III/P/20/77 dated 08-04-1982 Indian Electricity Act 1910 Indian Electricity Rules 1956 IRC :32-1969, IS : 5613-1976 part I to IV of (NHAI) and NHAI's guideline.	Yes	
4.2	Certificate from PD In the following format:- (i)- "it is certified that any other location of the electric line would be extremely difficult and unreasonable costly and the installation of electric line within ROW will not adversely affect the design , stability & traffic safety of the highway nor the likely future improvement such as widening of the carriage way easing of kerb , etc." (ii) for 6- laning (a) Where feasibility is available " I do certify that there will no hindrance to propose 6 laning based on the feasibility report considering proposed structures at the said location " (b) In case feasibility report is not available "I do certify that sufficient ROW is available at site for accommodating of six - laning"	YES	
5	If NH section proposed to be taken up by NHAI on BOT basis-a-clause is to be inserted in the agreement "The permitted highway on which licensee has	YES	


 परियोजना निदेशक
 भारतीय राष्ट्रीय राजमार्ग प्राधिकरण
 परियोजना कार्यान्वयन इकाई, इंदौर (मध्य प्रदेश)



	been granted the right to lay overhead electrical line has also been granted as a right of way to the concessionaire under the concession agreement for up-gradation.		
<u>6</u>	Who will supervise the work of laying of overhead electrical line?	OCBTL	
<u>7</u>	Who will sign the agreement on behalf of overhead electrical line agency	General Manager,OCBTL	
<u>8</u>	Who will ensure that the defect in road portion after laying of overhead electrical are corrected and if not corrected that what action will be taken.	OCBTL	
<u>9</u>	Who will pay the claims for damages done / disruption in working of concessionaire, if asked by the concessionaire.	OCBTL	
<u>10</u>	A certificate from PD that he will enter the proposed permission in register of record of the permission in the prescribed performa (copy enclosed)	NHAI	
<u>11</u>	If any previous approval for laying of overhead electrical line then photocopy of register of records of permission accorded as maintained by PD may be enclosed.	NO	


परियोजना निदेशक
भारतीय राष्ट्रीय राजमार्ग प्राधिकरण
परियोजना कार्यान्वयन इकाई, बरेली (उ०प्र०)

