

No. CE-RO/Chennai/MoRTH/12017/NH-81/PER/55/2018-19
GOVERNMENT OF INDIA
MINISTRY OF ROAD TRANSPORT & HIGHWAYS
Chief Engineer cum Regional Officer,
C-1-A, Rajaji Bhavan, Besant Nagar, Chennai- 600090.
Email: cerochennaiorth@gmail.com, Telefax Off: 24919341, 24916032.

Dated: 16.03.2020

Invitation of public comments

Subject:-Permission proposal for erection of 230KV line with pole across on NH 67 (new NH-81) at Km 232/909.60(New Km 99/350) Coimbatore-Karur Section in the State of Tamil Nadu-Reg.

The proposal is regarding permission proposal for for erection of 230KV line with pole across on NH 67 (new NH-81) at Km 232/909.60(New Km 99/350) Coimbatore-Karur Section was submitted to this office by the SE, NH, Madurai vide letter No.478//2019/JDO dated 28.02.2020(received on 09.03.2020) has submitted the proposal to this office in accordance with Ministry's latest guidelines dated 22.11.2016.

2. The alignment proposed by M/s. SPRNG Renewable Energy Private Limited, had submitted the proposal for erection of 230KV line with pole across on NH 67 (new NH-81) at Km 232/909.60(New Km 99/350) Coimbatore-Karur Section. The license M/s. SPRNG Renewable Energy Private Limited, has submitted and agreement regarding granting of right of way for erection of 230KV electric cable line crossing and undertaking to comply with standard condition of Morth guidelines. i.e. in a span of 220.62m.(NH crossing length 34.00m as per drawing submitted)

3. The right of way erection of 230KV line crossing the aforesaid stretch. The carriageway width of aforesaid stretch is 10.00m. The SPRNG Renewable Energy Private Limited, has proposed to erection of 230KV line with pole across on NH 67 (new NH-81) at Km 232/909.60(New Km 99/350) Coimbatore-Karur Section i.e. length of overhead 220.62m. Further ,M/s SPRNG Renewable Energy Private Limited, has mentioned that the erection of 230KV Electric cable line above the Right of Way will be 37.69m above the carriageway top.

4. M/s. SPRNG Renewable Energy Private Limited, has furnished an undertaking to the effect that the SPRNG Renewable Energy Private Limited, will remove the laid 230KV overhead line in future if required by NH wing of State Highways Department/MoRTH Govt. of India at any time for expansion of the NH at their own cost without claiming any compensation from NH wing of Tamil Nadu/MoRTH Govt. of India and any right on the NH land. Further, mentioned that The SPRNG Renewable Energy Private Limited, will also maintenance thereof and against all claims, proceedings, damages, costs, charges and expenses whats ever in respect thereof in relation there to restore the surfaces to its original condition soon after erection of 230KV overhead lines. Also, certified that the proposed of 230KV line work will not affect the design, stability, traffic safety and future improvement of the proposed stretch.

5. As per the guidelines issued by the Ministry vide letter No.RW/NH-33044/29/2015/S&R(R) dated 22.11.2016 the application submitted by the applicant will be made available for public comments and the comments will be invited within 30 days from the day of uploading.

In view of the above, comments of the public on the above proposal requiring from distance criteria is invited to the below mentioned address:

The Chief Engineer cum Regional Officer,
Chennai
Ministry of Road Transport & Highways,
C-1-A, Rajaji Bhavan, Besant Nagar, Chennai- 600 090

Yours Sincerely,

Encl: As Above.



(Shiju . P. Varghese)
Assistant Executive Engineer
For Chief Engineer cum -RO

Copy to:

1. The NIC, New Delhi - for uploading in the Ministry's website.
2. The SE(NH),Madurai -for information
3. M/s SPRNG RENEWABLE ENERGY PVT LTD, Office no.001,Ground Floor, Tower P5,Pentagon,Magarpatta City,Hadapsar,Pune-411 028 for information



(Shiju . P. Varghese)
Assistant Executive Engineer
For Chief Engineer cum -RO