



No. RW/TRI/Utility/24/2018-19

Government of India

Ministry of Road Transport & Highways

Regional Office (Kerala & Lakshadweep Region)

Public Office Building, Opposite to Museum,

Thiruvananthapuram - 695033.

Phone No. 0471-2320879, 2326306; email : rokeralamorth@gmail.com

Dated: 16.08.2018

Invitation of public comments

Sub:- Proposal for permission for Trenching and laying of UG Cable from Chavara Substation to Neendakara Bridge (Km.482/200 to 487/500) on NH 66 (Old NH 47) under IPDS Scheme under Electrical Section Sakthikulangara under Kollam Division, in the State of Kerala

The proposal is seeking permission to lay UG Cable along the road from Km.482/200 to 487/500 on NH-66 (Old NH 47)(Chavara substation to Neendakara Bridge) under IPDS Scheme by KSEB Electrical Section Sakthikulangara submitted to this office vide SE,PWD NH South Circle, Thiruvananthapuram's letter dated 11.07.2019 accordance with Ministry's latest guidelines dated 22.11.2016.

2. The proposal for laying of UGC along the NH from Km.482/200 to 487/500 on NH-66 (Old NH 47) as under:

Stretch in Km.	Length (Km.)	ROW (m)	Dist. Of Prop. UGC line from centre of NH (m).
RHS			
482/200 to 487/500	5.3 km	30.00	15.00
NH Crossing			
At Km. 482/200	0.030Km	30.00	NA

3. The Assistant Executive Engineer, KSEB, Electrical Sub Division, Sakthikulangara has proposed to lay UGCC from Km.482/200 to 487/500 on NH-66 (Old NH47) by Open Trench method.

4. The Assistant Executive Engineer, KSEB, Electrical Sub Division, Sakthikulangara has furnished an undertaking that, they will shift the UGC line if required by MORTH/NHAI/PWD or any other Highways authorities within the time frame prescribed by NHAI/Highways Authority. Further, it is also mentioned by the Assistant Executive Engineer, KSEB, Electrical Sub Division, Sakthikulangara that the proposed UGC work will not affect the design, stability, traffic safety and future improvement of proposed stretch. In addition, all the undertakings as prescribed in the checklist has been furnished by the Assistant Executive Engineer, KSEB, Electrical Sub Division, Sakthikulangara.


5. As per the guidelines issued by the Ministry vide letter No.RW/NH-33044/29/2015/S&R (R) dated 22.11.2016, the application will be made available for public comments and the comments will be invited within 30 days from the date of uploading in the Ministry's web site.

6. In view of above, comments of the public on the above proposal is invited to the below mentioned address:

The Regional Officer
Ministry of Road Transport & Highways,
Public Office Building,
Thiruvananthapuram - 695033.

Encl: As above.


Yours faithfully


16/8/19
(V.V. Sastry)

Regional Officer cum Highway Administration

Copy to:

1. Senior Technical Director, NIC for uploading in the Ministry's website
2. The Superintending Engineer, Kerala PWD NH South Circle, Thiruvananthapuram for information please.


16/8/19
(V.V. Sastry)

Regional Officer cum Highway Administration



കേരളം KERALA

CB 605520

LIST OF UNDERTAKINGS

1. Undertaking for not to damage any other utility if damaged then to pay the losses either to the MORTH/NHAI/PWD or to concerned agency as decided by MORTH.
2. Undertaking for confirming all standard condition of MORTH circular number RW/NH-33044/29/2015S&R dated 22/11/2016.
3. Undertaking for indemnity against all damages and claims.
4. Undertaking for management of traffic movement during laying of utility line without hampering the traffic.
5. Undertaking that prior approval of the MORTH/NHAI/PWD shall be obtained before undertaking any work for installation shifting or repairing or alterations to the utility line located in the National Highway right of way.
6. Undertaking that expenditure if any incurred by PWD/MORTH/NHAI for repairing any damage caused to national highway by the laying maintenance or shifting of the utility line will be borne by the applicant agency owing the line.
7. Undertaking that text of license deed is as per verbatim of MORTH format (issued by ministry's circular number RW/NH/33044/29/2015S&R(R) dated 22/11/2016.
8. Undertaking that the utility line will be shifted by utility agency at the cost of the agency owing the utility line if the MORTH /NHAI/PWD consider it necessary in future to shift the utility line for expansion of road.
9. The type of cutting used for laying 6 KM UG Cable will be of Open Trench type (OT Type).
10. The restoration will be done by KSEBLtd at their own expenses as the road is in DLP and the DLP (Defect Liability period) will be till 29/12/2019.
11. Safety clearance as per rules will be maintained.

ASSISTANT EXECUTIVE ENGINEER
ELECTRICAL SUB-DIVISION
SAKTHIKULANGARA

740 RD-100/- Asst. Executive Engineer,
Electrical Sub Division
Sakthikulangara, Kollam.
3/5/19

2019




കേരളം केरल KERALA

CB 605519

Benet. T.

AEE, ESD,

Sakthikulengare


ASSISTANT EXECUTIVE ENGINEER
ELECTRICAL SUB-DIVISION
SAKTHIKULANGARA

739
15/19
Pr-100/- Asst. Executive Engineer,
Electrical Sub Division
Sakthikulangara, Kollam.


17 APR 2019



