



**भारतीय राष्ट्रीय राजमार्ग प्राधिकरण**  
(सड़क परिवहन और राजमार्ग मंत्रालय, भारत सरकार)  
**National Highways Authority of India**  
(Ministry of Road Transport & Highways, Government of India)  
**क्षेत्रीय कार्यालय, मदुरै / Regional Office, Madurai**

दूसरा व तीसरी तल, विजय कृष्ण प्लाज़ा, संख्या-1, लेक एरिया, मेलूर मेन रोड, माट्टुतावनी, मदुरै-625 007  
2<sup>nd</sup> & 3<sup>rd</sup> Floor, Vijay Krishna Plaza, No.1, Lake Area, Melur Main Road, Mattuthavani, Madurai-625 107  
दूरभाष / Tele : +91-452-258 8999 वेब / Website : www.nhai.gov.in ई-मेल / E-mail : romadurai@nhai.org



NHAI/15018/3.7/03/2022/RO-Madurai/2770

07<sup>th</sup> December, 2022

**INVITATION OF PUBLIC COMMENTS**

**Sub:** NHAI - Madurai Region - PIU-Tuticorin - Madurai - Aruppukottai section of NH 45B - Proposal for Erection of 230 KV Overhead Transmission line crossing at km 248+ 400 Proposal submitted by Superintending Engineer ,TANTRANSCO , GCC Madurai- In-Principle Approval Requested - Public Comments Invited - Reg.

The proposal received from PD, PIU-Tuticorin vide letter NHAI/PIU/TUTY/NH-45B/2022/745 dated 22.06.2022 thereby requesting Permission for Erection of 230KV and 110KV DC Tower line Crossing at Km.248+400 in Madurai - Aruppukottai section of NH 45B in the State of Tamil Nadu proposed by Superintending Engineer ,TANTRANSCO , GCC Madurai.

2) The alignment proposed by Superintending Engineer ,TANTRANSCO , GCC Madurai requesting Permission for Erection of 230KV Tower line Crossing at Km.248+400 in Madurai - Aruppukottai section of NH 45B in the State of Tamil Nadu as detailed under;

Stretch in Km	Length in Meters	Remarks
Across NH-45B: At Km 248+400 to 248+430	60	Laying of 230KV DC line tower with Zebra conductor

3) As mentioned in the PD letter, the ROW is 60 m at Km 248/400. As observed from the drawing, the Overhead tower are to be erected across NH at Km 248+400 to 248+430.

4) In this instant proposal, the as certified by PD, Tuticorin Vertical Clearance for the proposed erection overhead electrical 230KV overhead Transmission line is 18.26 m.

5) Superintending Engineer ,TANTRANSCO , GCC Madurai has furnished necessary undertaking to the effect that they will relocate the Over Head Transmission line and when requested by the NHAI at their own cost. It is also mentioned that, the proposed erection work of 230KV Over Head Transmission line across NH will not cause damage to any other utility, if damaged they will pay the

-1-

*(Signature)*

NHAI/15018/3.7/03/2022/RO-Madurai/2770

07<sup>th</sup> December, 2022

losses either to NHAI or to the concerned agency as per Ministry Guidelines dated 22.11.2016.

6) Accordingly, As per the MoRTH guidelines vide letter No. RW/NH-33044/29/2015/S&R(R) dated 22.11.2016. The application is being uploaded on public domain for 30 days for seeking claims and objections (on grounds of public inconvenience, safety and general public interest).

In view of the above, comments of the public on the above proposal is invited to the below mentioned address:

The Regional Officer,  
National Highways Authority of India,  
No. 3<sup>rd</sup> Floor, Vijay Krishna Plaza,  
No.1, Lake Area, Melur Main Road, Mattuthavani,  
Madurai - 625 007.

This is issued with approval of Regional Officer-Madurai.



(Mahendra Meena)  
Dy. Manager (Tech)

**Copy to:**

1. The NIC, New Delhi - for uploading in the Ministry's website.
2. The PD, Tuticorin - for information.